

O/o Executive Engineer (E),
BSNL Electrical Division
3rd Floor, Door Sanchar Bhawan
Unit-IX, Janpath, Bhubaneswar - 751022
Phone – (0674) -2544902, FAX- 2540617
Email – eebsnlbbsr@gmail.com



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)



E-TENDER DOCUMENT

NIT No: 24 /BSNL/BSR/2020-21

Name of work: Providing Electro-Mechanical Services, provision for Air conditioning, Automatic Fire Detection, Fire Alarm System, Fire Extinguishers etc for Orchid project labs and shifted site of Banana Project Labs at Regional Plant Resource Centre at Bhubaneswar (**S.H: SITC of Automatic Fire Detection and Fire Alarm system & Fire Extinguishers**)

Regd. Office : Bharat Sanchar Bhavan, Harish Chandra Mathur Lane, Janpath, New Delhi-110 001
Website: www.bsnl.co.in



BHARAT SANCHAR NIGAM LIMITED

(A GOVT OF INDIA ENTERPRISE)

O/o Executive Engineer (E), BSNL Electrical Division

3rd Floor, Door Sanchar Bhawan, Unit-IX, Janpath, Bhubaneswar - 751022

Phone – (0674) -2544902, FAX- 2540617, Email – eeebsnlbbsr@gmail.com

NIT NO- 24/BSNL/BSR/2020-21

NAME OF WORK: Providing Electro-Mechanical Services, provision for Air conditioning, Automatic Fire Detection, Fire Alarm System, Fire Extinguishers etc for Orchid project labs and shifted site of Banana Project Labs at Regional Plant Resource Centre at Bhubaneswar
(S.H: SITC of Automatic Fire Detection and Fire Alarm system & Fire Extinguishers)

INDEX

| S.No | Item | Page No. |
|------|--|----------|
| 1 | Cover page | 1 |
| 2 | Index | 2 |
| 3 | SECTION-1, Part-A: Detailed Notice Inviting e-tender (DNIT) | 3-8 |
| 4 | SECTION- 2: Tender Information | 9 |
| 5 | SECTION- 3 Part A & B: Scope of work & Technical Specifications | 10-21 |
| 6 | Section - 3 –Part C: Schedule of Requirements | 22-23 |
| 7 | SECTION- 4 Part A: General Instructions to Bidders (GIB) | 24-37 |
| 8 | SECTION- 4 Part B: Special Instructions to Bidders | 38-39 |
| 9 | SECTION- 4 Part C: E Tendering Instructions to bidders | 40-43 |
| 10 | SECTION-5 Part A: General (Commercial) Conditions of Contract | 44-57 |
| 11 | SECTION-5 Part B: Special (Commercial) Conditions of Contract | 58-65 |
| 12 | SECTION- 6: Undertaking & Declaration | 66-68 |
| 13 | SECTION- 7: Proformas for the Bid Security/EMD | 69-75 |
| 14 | SECTION- 8: Bidder's profile & Questionnaire. | 76-77 |
| 15 | SECTION-9 Part-A: BID FORM | 78 |
| 16 | SECTION-9 Part-B: Priced Schedule & List of BSNL Approved makes | 79-83 |
| 17 | Appendix-1 to Section 4 Part A of Chapter 4 (Standard Tender Enquiry Document) | 84-88 |

This Tender Document contains 88 pages



BHARAT SANCHAR NIGAM LIMITED

(A GOVT OF INDIA ENTERPRISE)

O/o Executive Engineer (E), BSNL Electrical Division, Bhubaneswar
3rd Floor, Door Sanchar Bhawan, Unit-IX, Janpath, Bhubaneswar - 751022
Phone – (0674) -2544902, FAX- 2540617, Email – eeebsnlbbsr@gmail.com

SECTION-1

DETAILED NOTICE INVITING TENDER (DNIT)

NIT NO- 24/BSNL/BSR/2020-21

E- Tender is hereby invited by the Executive Engineer (E), BSNL Electrical Division, Bhubaneswar, on behalf of CMD, Bharat Sanchar Nigam Limited (A Government of India Enterprise) on item rate basis for the following work:

| Sl. no | Name of the Work | Estimated Cost i/c GST | Bid Security / Earnest Money Deposit | Period of Contract |
|--------|---|---------------------------|--|-----------------------|
| 1. | Providing Electro-Mechanical Services, provision for Air conditioning, Automatic Fire Detection, Fire Alarm System, Fire Extinguishers etc for Orchid project labs and shifted site of Banana Project Labs at Regional Plant Resource Centre at Bhubaneswar. S.H: SITC of Automatic Fire Detection and Fire Alarm system and Fire Extinguishers. | ₹ 5,55,216/- | ₹ 11,104/- | 15 days |

2.0: PURCHASE OF TENDER DOCUMENT:

(i) Tender document can be free viewed by logging into the website, www.odisha.bsnl.co.in/tender OR <https://etenders.gov.in/eprocure/app>.

(ii) The official copy of tender document for participating in E-tendering shall be available for downloading from the e tendering portal: <https://etenders.gov.in/eprocure/app>.

2.1. Payment of Tender Cost : Not Applicable

3.0 AVAILABILITY OF TENDER DOCUMENT: The tender document shall be available for downloading from the e-tendering portal <https://etenders.gov.in/eprocure/app> from 15-Aug-2020 9.00AM and up to 25-Aug-2020, 03:00 PM.

3.1 In e-tendering process, physical copy of the tender document would not be available for sale.

4. ELIGIBILITY CRITERIA: - The bidder should have

a) Financial Norms:

Average annual turnover during the last 3 years, ending 31st March of the previous financial year, should be at least 30% of the estimated cost put to tender i.e. ₹ 1,66,565/-

AND

b) Physical Norms:

Experience of having successfully completed similar works in Central Government /State Government /Central Autonomous Body/Central Public sector Undertaking during last 7 years ending last day of month previous to the one in which applications are invited ,should be either of the following :-

i. Three similar successfully completed works costing not less than the amount equal to Rs.2,22,086/-

OR

ii. Two similar successfully completed works costing not less than the amount equal to Rs.3,33,130/-

OR

iii. One similar successfully completed works costing not less than the amount equal to Rs.4,44,173/-

c) Valid PAN

d) Valid GST Registration no. or exemption certificate no.

Note-1: Similar work stands for "SITC/PITC of Addressable Fire Alarm system etc."

4.1 . The bidders shall submit necessary documentary proof showing that they meet the eligibility criteria along with their tender bid. All documents submitted will also be self-attested by the bidder.

5. BID SECURITY/EMD:

5.1 The bidder shall furnish the bid EMD in one of the following ways:-

a) Demand Draft/ Banker's cheque drawn in favour of "A.O. (Cash), BSNL, O/o GMTD, Bhubaneswar "and payable at "Bhubaneswar". OR

b) Bank Guarantee from a scheduled bank drawn in favour of "A.O. (Cash), BSNL, O/o GMTD, Bhubaneswar" which should be valid for 120 days from the tender opening date.

b) FDR/TDR pledged in favour of "A.O. (Cash), BSNL, O/o GMTD, Bhubaneswar" which should be valid for minimum 120 days from the tender opening date.

c) **Alternative method for Submission of Bid Security / EMD:**

The Bid Security / EMD can also be submitted online through internet banking / RTGS / NEFT etc. to BSNL account as per the details given below:

| | |
|-----------------------------|--|
| Name of the Bank and Branch | UNION BANK OF INDIA, BHUBANEWAR |
| Accounts Name | A.O(Cash), BSNL, O/o GMTD Bhubaneswar |
| Account Number | 380801010035275 |
| IFC Code | UBIN0538086 |
| Address of the Bank | Ashok Nagar Branch, Bhubaneswar- 751009, Odisha |
| MICR Code | 751026002 |
| Contact No | Tel.No.0674-2541969 |

The scanned copies of the E-Payment receipt / Transaction slip towards Bid Security / EMD paid through online is to be uploaded in the e-Tendering Portal along with other requisite documents.

5.2 The MSE units shall be exempted from submission of Bid Security deposit/EMD on production of requisite proof in respect of valid certification from MSME for the tendered item.

(The MSE units are advised to check their eligibility for availing exemption from submission of Bid Security deposit/EMD with reference to the nature of activities / business / items & materials mentioned in their MSE certificate issued by competent authority)

5.3 **Validity period of Bid Security / EMD:**

The validity period of the EMD should be 30days beyond the Bid validity i.e. 90 days + 30 days= 120 days (bid validity period is 90 days).

6.0 **END DATE & TIME OF ONLINE SUBMISSION OF TENDER BIDS: ON OR BEFORE 25-AUGUST 2020, 3.00 PM .**

6.1 **Submission of Tender Documents:**

Tender Documents (Techno commercial bid, Financial bid, scan copy EMD instrument and certificates, declarations, undertakings and forms etc. to establish their eligibility for the tender) are to be submitted online by uploading in the e- tendering portal [https:// etenders.gov.in / eprocure /app](https://etenders.gov.in/eprocure/app) within the date and time as specified in **Clause 13.0** without any modifications and changing the name of the downloaded file.

6.2 ONLINE SUBMISSION OF SELF ATTESTED COPIES OF DOCUMENTS BY UPLOADING IN THE E-TENDERING PORTAL: (Non compliance will entail rejection of bids)

| Sl. No | Description of Documents |
|--------|--|
| 1 | Demand Draft/Banker's Cheque/ FDR / TDR /Bank Guarantee of any Nationalized/scheduled bank in favour of ""Accounts Officer Cash, BSNL, O/o the GMTD, BHUBANESWAR"" towards Bid Security / EMD. |
| 2 | Documentary proof of satisfying eligibility conditions against clause 4 a), 4b) & 4 d) of "Eligibility Criteria" of the NIT , as follows. |
| a) | Turn Over Certificate of the firm from Chartered Accountant for last 03 years. |
| b) | Work Completion / Experience certificate (s) of BSNL since last 07 years, issued not below the rank of Executive Engineer /AGM. |
| 3 | PAN card issued by Income Tax Department, Govt. of India. |
| 4 | Valid GST Registration Certificate issued by statutory authority. |
| 5 | MSME registration certificate for the tendered items/ works, if applicable |
| 6 | Undertaking & declaration duly filled & signed (section-6A & 6B) |
| 7 | Non-Relation Certificate duly filled & signed as per Section 6(C) |
| 8 | Bidder's Profile & Questionnaire as per Section-8 |
| 9 | Tender/ Bid form- Section 9 , Part A |
| 10 | Power of Attorney & authorization for signing tender documents. (If applicable) |
| 11 | Integrity pact (if applicable) |
| 12 | Technical Leaflets/Manuals/Specifications if any |

Note-2: *In case of mismatch between uploaded documents and hard copies submitted by the supplier /contractor, the documents uploaded in e-tendering portal will prevail and bids will be evaluated accordingly.*

6.2.1 OFFLINE SUBMISSION OF ORIGINAL EMD AND HARD COPIES OF SELF ATTESTED DOCUMENTS BY THE BIDDER (S) :-

The ORIGINAL EMD along with self attested copies of requisite documents as mentioned in clause 6.2 above should be submitted to **The Executive Engineer (E), BSNL Electrical Division Bhubaneswar before 25-Aug-2020, 05.00 PM**, failing which the bids will be treated as non responsive and the bids will not be opened.

6.3 The original financial instrument like Demand Draft/Banker's cheque/Bank Guarantee towards EMD and self attested copies of the valid credentials, registration certificates, declarations, undertakings and other requisite documents as mentioned in clause 6.2 above shall be submitted by the intending bidders **in a sealed envelope with due mention of name of work, date of opening of tenders, name of the tenderer, in the office of the Executive Engineer (E), BSNL Electrical Division, Bhubaneswar before the stipulated date & time as specified in clause 13.0.** The envelope shall bear the phrase: "Do Not Open Before (due date & time of opening of tender)".

- 6.4** If the tenderer is a firm in partnership / Limited company or Corporation, then the hard copies of “FORM-A” and partnership deed / Memorandum of Articles of Association and power of attorney / Authorisation to the person who signs the tender in case of companies etc. shall also be submitted along with hard copies of **other documents** as above.

7.0 OPENING OF TENDER BIDS:

Techno commercial bids of responsive bidders will be opened first online on 26-Aug-2020 03:30 PM. Thereafter financial bids of only technically qualified bidders will be opened on 27-Aug-2020, 11:30 AM or as will be notified after opening of Techno commercial bids.

8.0 PLACE OF OPENING OF TENDER BIDS:

The tenders shall be opened through „Public Online Tender Opening Event (POTOE). BSNL’s Tender Opening Officers as well as authorized representatives of bidders can attend the Public Online Tender Opening Event (TOE) from the comfort of their offices. Kindly refer clause 8 of Section-4 Part C of Tender document for further instructions.

Note 3: In case the date of opening of bid is declared to be a holiday, the date of opening of bid will get shifted automatically to next working day at the same scheduled time. Any change in bid opening date due to any other unavoidable reason will be intimated through the e tendering portal online / BSNL website.

- 8.1** Technical bids of the participating bidders will be opened first. EMD instruments and documents satisfying the eligibility, physical & financial criteria along with declarations, under takings, registrations certificates etc. will be verified and Technical bids will be evaluated.
- 9.0** Thereafter, the Price bids of those bidders will be opened only who are technically qualified in their technical bids and whose EMD and documents are found in order.
- 10.0** Incomplete, ambiguous, Conditional, unsealed (in case of manual tender) tender bids are liable to be rejected.
- 11.0** The Tender accepting authority of BSNL reserves the right to accept or reject any or all tender bids without assigning any reason. He is not bound to accept the lowest tender.
- 12.0** The bidder shall furnish a declaration in his tender bid that no addition / deletion / corrections have been made in the downloaded tender document being submitted and it is identical to the tender document appearing on the website.
- 12.1** In case of any correction/addition/ alteration/ omission in the tender document, the tender bid shall be treated as non-responsive and shall be rejected summarily.

Note 4: All documents submitted in the bid offer should be preferably in English. In case the certificate viz. experience, registration etc. is issued in any other language other than English, the bidder shall attach an English translation of the same duly attested by the bidder & the translator to be true copy in addition to the relevant certificate.

Note 5: All computer generated documents should be duly signed/ attested by the bidder / vendor organization.

13.0. IMPORTANT DATES FOR E-TENDER EVENTS:

| CRITICAL DATES | | |
|--|--|-----------------------|
| S.NO | EVENT | DATE & TIME |
| 1 | Document Download Start Date from E-tender Portal: https://etenders.gov.in/eprocure/app | 15-Aug-2020, 09.00AM |
| 2 | Document Download End Date | 25-Aug-2020, 03:00 PM |
| 3 | Clarification Start Date | 15-Aug-2020, 09:00 AM |
| 4 | Clarification End Date | 22-Aug-2020, 05:00 PM |
| 5 | Bid Submission Start Date | 15-Aug-2020, 09:00 PM |
| 6 | Bid Submission End Date | 25-Aug-2020, 03:00 PM |
| 7 | Original EMD, self attested hard copies of Credentials, Undertakings, Declarations and other Documents as per Clause 6.2 of Sec-1 (DNIT) submission Start Date | 17-Aug-2020, 11:00 AM |
| 8 | Original EMD, self attested hard copies of Credentials, Undertakings, Declarations and other Documents as per Clause 6.2 of Sec-1 (DNIT) submission End Date | 25-Aug-2020, 05:00 PM |
| 9 | Techno commercial Bid Opening Date (online) | 26-Aug-2020, 03:30 PM |
| 10 | Financial (Price) Bid Opening Date (online) | 17-Aug-2020, 11:30 AM |
| E-Tender Portal site address: https://etenders.gov.in/eprocure/app | | |

14.0 The tender opening committee (TOC) may ask the tenderers to produce the original documents for verification if required. In case the tenderer fails to furnish the same, they are likely to be disqualified and their price bids will not be opened.

Executive Engineer (E)
BSNL Electrical Division,
Bhubaneswar
Date: 10.08.2020

No- Plg-04/BSNL-EDB/180

Copy to-

- 1) Chief Engineer (E), BSNL Electrical Odisha Zone, BBSR for kind information.
- 2-3) E.E (E), BSNL Electrical Division, Cuttack / Sambalpur.
- 4) The A.O (Cash) , BSNL , O/o the GMTD, Bhubaneswar.
- 5) Notice Board/BSNL Web site/e tendering portal: <https://eprocure.gov.in/eprocure/app>

Executive Engineer (E)

SECTION-2

TENDER INFORMATION

1. Type of tender- :

- a) **No. of Bid Submission Stages** : Two Bid and single stage
- b) **No. of Envelopes for offline submission** : One number

Note 1:- The bidder has to submit Techno-commercial & Financial bid simultaneously online.

Note 2:- Techno commercial bids will be opened and evaluated first and thereafter financial bids of only techno-commercially compliant bidders will be opened.

2. Bid Validity Period / Validity of bid offer : 90 days from the tender opening date.

3. Payment terms:

Payments will be regulated as per clause.16 of SECTION – 5 Part B
“SPECIAL (COMMERCIAL) CONDITIONS OF CONTRACT (SCC)”

4. Time allowed for completion of works: 15 days

5. Engineer In charge: Executive Engineer (E)
BSNL Electrical Division, Bhubaneswar

SECTION- 3 Part A

SCOPE OF WORK

A. General:

Supply, Installation, Testing and Commissioning of Conventional type Automatic Fire Detection and Fire Alarm system and Fire Extinguishers.

B. Scope of work:

The repair works should be done as per the schedule of work in the NIT. The scope of works shall cover

- (i) Supply, Installation, Testing and Commissioning of Conventional Type Fire Detection and Fire Alarm system including supplying/fixing of CE certified Photoelectric/Ionization type Smoke detectors and Photoelectric ROR multi Detectors with base and accessories.
- (ii) SITC of 4 Zone and 8 Zone Microprocessor based LCD Display (16X2) UL listed/CE Certified conventional Fire Detection and Fire Alarm Control panel.
- (iii) Supply and fixing of Electronic Hotter cum Speakers, Manual call points/Response indicators etc.
- (iv) Providing Necessary wirings with 2X1.5sqmm Copper Conductor armoured cable and 2X1.5sqmm PVC insulated copper conductor cable etc.
- (v) Supply and fixing of 4.5 KG CO₂ Portable type Fire Extinguishers.
- (vi) Functional Testing of the system.

SECTION- 3 Part B
TECHNICAL SPECIFICATIONS

A. GENERAL

1. The works shall be done as per current BSNL/CPWD specifications for Electrical works as amended from time to time & Indian Electricity Rules as amended up to date.
2. The work shall be carried out under the supervision of qualified and Electrical license holder (HT) Supervisor.
3. The layout of the work will be given by Engineer-in-charge or his duly authorized representative at site of work.
4. All materials to be used on this work by the suppliers /contractors shall be got approved from the Engineer in – charge before installation at site/use at factory or workshop.
5. Any damages done to the building by the suppliers /contractors during the execution of works shall have to be made good at his cost & risk. If he does not do himself within a reasonable time determined by the Executive Engineer (E), then the same will be got done at his risk & cost departmentally after giving notice to him.
6. Bad workmanship will not be accepted and defects shall be rectified at contractor's cost to the satisfaction of the Engineer-in-charge. The progress of electrical works is to be coordinated in accordance with the availability and clearance of sites, no claim for idle staff / labour will be entertained by the department.
7. All the debris of the electrical works should be removed and the site should be cleared by the suppliers /contractors immediately after the occurring of debris, similarly any rejected materials should be immediately cleared-off from the site by the supplier/contractor.
8. The supplier /contractor shall make his own arrangement at his own cost for electrical / general tools and plants required for the work.
9. The entire installation/equipments shall be at the risk & responsibility of the supplier / contractor until these are tested and handed over to the department. However if there is any delay from the department side, the installation may be taken over in parts but the decision on the same shall rests with Engineer – in – charge which shall be binding on the supplier /contractor.
10. Notwithstanding the schedule of quantities, all items of interrelated works considered necessary to execute and complete the works are deemed to be included, shall be provided by the contractor at no extra cost.
11. The connections & inter-connections shall be done by the contractor wherever required for energization of the installation/equipment /machineries and nothing extra shall be paid on this account.

12. In case some items/ part of the items have already been executed, the successful tenderer shall have to bear the cost of the same for completing the work. The recovery for such items/part of the items shall be made at the rates tendered by the contractor for the particular item if existing in the agreement. If the item does not exist in the agreement, then the recovery rate shall be prevailing market rates for the items plus/minus enhancement/reduction.
13. Acceptable make of the materials shall be as per the makes and models mentioned in the schedule of work /Technical Specifications or as per the latest product directory of BSNL OR as per the direction of Engineer in charge.
14. The contractor shall have to obtain prior approval from Engineer – in – charge before placing order for any specific materials. The Engineer – in – charge may approve any of the makers of brands out of the above list.
15. All tools and plants, testing, Personal Protective Equipments (PPE) and Safety equipment/accessories required to carry out the works shall have to be arranged by the supplier / contractor at its own cost.

B. TECHNICAL

1.0 SCOPE:

This section indicates general description of work and various design parameters for the automatic fire detection and alarm system.

2.0 DRAWINGS:

The building drawings giving necessary details regarding the areas to be protected and any other particular information, if required, may be seen from the Executive Engineer (E) concerned.

3.0 DESIGN AND SELECTION:

- 3.1 Detectors which are normally used are broadly covered in two categories viz. Heat and Smoke type. Smoke type is again of two type viz. Photo Electric & Ionization.
- 3.2 Ionization and photoelectric detector shall be provided in the areas which are normally free from smoke. Heat detectors shall be provided for the areas like kitchen etc. which are prone to smoke.
- 3.3 The area to be protected by ionization and photo electric detector shall be generally in accordance with the Standards laid down below. Additional detectors if any shall be provided as per user's requirement.
 - (a) Each detector shall cover an area not exceeding 50 sqmtr in case of air conditioning rooms.
 - (b) Area separated by beams having depth of minimum 450 mm shall have separate detector irrespective of area.
 - (c) Maximum horizontal distance between centre to centre of smoke detector shall not exceed 7.5 meters.
 - (d) Ionization or photoelectric type detectors shall be provided in the ratio 1:1 for mixed monitoring purpose
 - (e) Heat detectors shall be provided for areas which are prone to smoke.

- 3.4 Each room including electrical rising main room shall necessarily be provided with at least one detector irrespective of its area.
- 3.5 Signal from detectors which are normally not visible shall be extended in the shape of response indicator to a suitable location which is easily accessible.
- 3.6 The Main control panel & local control panel shall be provided at easily accessible areas like corridors etc. where the same can be properly monitored. Standby batteries for power supply to the panels shall be provided near the panel.
- 3.7 A minimum of two speakers for audible alarm and or public announcement shall be provided on each floor and at least one speaker shall be provided on terrace.
- 3.8 The response indicator shall be lit by means of twin LEDs in red color and shall be housed in MS box.
- 3.9 For detectors above false ceiling, the response indicators shall be installed either right below on the false ceiling or on the nearby wall /column with bottom 300 mm below false ceiling. Alternatively all response indicators shall be located at convenient places as approved. The cover plate of the response indicators shall also boldly display the detectors number to which they correspond.
- 3.10 Each detector shall be numbered zone wise such as Z09/N-10 , wherein Z09 indicates zone number nine and N-10 indicates number 10 in that zone.
- 3.11 All the cables and wires shall be tagged or labeled with ferrules for proper identification at the termination end.
- 3.12 The specification of different types of detectors selected shall conform to the detailed specifications issued by the manufacturers.

4.0 STANDARDS

The entire system shall conform to IS:2189 as amended up to date, where IS standard is not available the BS: 5839 standard shall be followed. In case of conflict the requirements of these detailed specifications shall be given overriding priority. The wiring work shall be carried out conforming to C.P.W.D. specifications for electrical works (Internal) as amended up to date.

5.0 APPROVAL OF DRAWINGS:-

The contractor shall get the following drawings approved before start of the work.

- a. Floor plans showing location of detector indicating the proposed distances between the detectors.
- b. Floor plans indicating the location of main control panels, local control panels, manual call point's response indicators etc.
- c. Conduit/cable layout diagram clearly indicating details of detectors and other devices connected in a particular Zone.
- d. Drawing showing general arrangement of main control panel and local control panels.

6.0 TEST AT SITE:-

- 6.1 After physical completion of the installation functional testing shall be conducted by the firm in the presence of Engineer-In-charge or any representative of the department. Functional tests on the following items shall be conducted for this purpose.
 - a. Smoke detectors both ionization and photo electricity.
 - b. Response indicators.
 - c. Heat detectors.

- d. Hooters.
- e. Standby battery.
- f. Fire control panels.
- g. Public address system.

6.2 TESTING OF DETECTORS:

6.2.1 OPEN CIRCUIT TEST:

- (a) All the ionization/photo electric smoke detectors of a zone are looped and are terminated on PCB card in the control panel. Remove one terminal of detector to make open circuit in the detectors loop a corresponding fault indication of an open circuit will be displayed as on audible and visual alarm on the control panel. The audible alarm should be distinct from the fire alarm, trace the faulty detector in the Zone to check the faulty detector.
- (b) Open circuit conditions are created - at the last detector of individual zone.

6.2.2 SHORT CIRCUIT TEST:

Short the terminals of detector one by one in last detector of each zone to create a short circuit in the detector circuit in such a way so that every individual zone is checked for visual and a distinct audible alarm.

6.2.3 CLOSED CIRCUIT TEST:

By putting a cigarette smoke or allowing smoke of incense stick in to the chamber of detectors just about a distant feel apart, the detector senses the smoke within 10 to 15 second and the red LED on the body of the detector glows permanently giving an audio visual alarm on the control panel and distant hooters also gives audio signal. The audible alarm continues to operate until silenced manually. After pressing the alarm cancel push button on the control panel, the audio signal silenced respective zone is to be surveyed to plot the source of smoke conversely.

6.2.4 RESPONSE INDICATORS:

Similarly test smoke detectors installed in the false ceiling and simultaneous operation of respective response indicators are also ensured.

Afterwards, testing of smoke detection by ionization type smoke detectors will be followed by photo electric smoke detectors.

6.2.5 HEAT DETECTORS:

These are suitable for use in situation where sufficient heat is likely to be generated (for example, kitchen and pantry etc.). These are not suitable for fire protection of places where larger losses can be caused by small fire and where safety of life is involved. Hence used in closets or other unsupervised spaces. For testing of restorable type detectors a heat source, such as heat of soft coke burnt with smokeless a hair dryer or a shielded heat lamp is used unit if respond, making sure that the sensing element is not damaged. After each heat test, the detector is reset.

A heat detector with replaceable fusible alloy is tested first by removing the element to see whether contacts operate properly and then re-inserting them in proper position.

6.2.6 MANUAL CALL POINTS:

Inspect that on each floor, one or more manual call points are installed, preferably on the exit routes. It is installed at a height of 1.2 meters above the floor. Check that its housing is dust proof and moisture proof properly sealed with rubber lining red painted instructions given to break the glass with hammer provided in case any fire is observed. For testing unscrew the outer cover the respective LED in the control panel will flash along with audible alarm to attract the attention of the staff.

6.2.7 FAULT SIGNALS:

An immediate fault warning is checked by visual indicators on the zone control panel and audible alarm and visible indicator on main control panel. The audible alarm should be distinct from the fire alarm.

Check warning alarm in the following occurrences by: -

- a) Removing the fuse of main power supply.
- b) Disconnecting the standby power supply.
- c) Disconnecting the battery charging equipment.

Nothing shall be paid extra for arranging materials required for tests as reqd.

6.2.8 TAKING OVER OF INSTALLATION

After the installation has been completed in all respects and tested successfully as per the procedure laid down above, this shall be taken over by the client department for beneficial use. The minor defects and discrepancies which might be noticed during testing shall be attended by the contractor within a fortnight from the date of acceptance test.

7.0 GENERAL FEATURES FOR DETECTORS, HOOTERS, MANUAL CALL POINT OR PILL BOX AND PA SYSTEM:

7.1 IONIZATION SMOKE DETECTOR

7.1.1. OPERATIONAL PRINCIPLE

The ionization smoke detector shall consist of two ionization chambers i.e. inner and outer, both containing a sealed radiation source. The air inside the chamber is ionized by the radical rays emitted from the radiation source. The two chambers are connected in series.

At the time of fire the smoke would enter into the outer chamber and due to the smoke, the current in the ionization chamber is reduced. This effect is taken note of by the controls and signals are given accordingly. External LED also glow on alarm activation.

7.1.2 GENERAL FEATURES

- a. The detector shall respond to smoke due to smoldering and open fire.
- b. The detector shall be vibration and shock proof.
- c. The detector shall not contain any moving part.
- d. The detector shall be plug in type facilitating easy removal and installation of detector with hand while base is permanently installed.
- e. The detector shall operate at 24 V (max) D.C. and shall be of low voltage type.
- f. The detector shall be cent percent solid state using field effect transistors, integrated circuits and transistors technology.
- g. The detector shall have LED indicators for quick identification of location of fire /smokes.
- h. The detector shall have provision for connecting remote response indicators.

7.1.3 SPECIAL FEATURES

- a. The detector shall be compatible to work with photo electric smoke detectors with inter changeable base.
- b. The radioactive source strength in respect of each detector shall not exceed 1.0 micro curie.
- c. The detector shall be protected against reverse polarity of incoming supply.
- d. The detector shall consist of two ionization chambers containing Americium foil, dual radioactive source and electronic circuit connective contacts for base and easy to clean protective housing.
- e. The detector shall be highly reliable, stable and capable of giving fine performance under the site conditions of varying temperature, humidity and air velocity.
- f. The detector shall be self-hold type capable of maintaining the alarm signal until the system is reset at the control unit.
- g. The detector should have necessary protection against reverse polarity of incoming supply.

7.2 PHOTO ELECTRIC SMOKE DETECTOR

7.2 OPERATIONAL PRINCIPLE

The operation of detector is based on light scattering principle. Under normal conditions, light pulses are separated at such a rate that photo diode is not able to detect them, because of its position being outside the light path. When the smoke enters into the chamber, the light would be scattered off by the smoke and sufficient quantity of light would be detected by the diode resulting in activating an alarm on counting of six consecutive pulses on account of continued existence of smoke within the sensing chamber. External LED also glow in alarm actuation.

7.2.2 GENERAL FEATURES

- a. The detector shall respond to smoke due to smoldering and open fire.
- b. The detector shall be vibration and shock proof.
- c. The detector shall not contain any moving part.
- d. The detector shall be plug in type facilitating easy removal and installation of detector with hand while base is permanently installed.
- e. The detector shall operate at 24 V (max) D.C. and shall be of low voltage type.
- f. The detector shall be cent percent solid state using field effect transistors, integrated circuits and transistors technology.
- g. The detector shall have LED indicators for quick identification of location of fire/smokes.
- h. The detector shall have provision for connecting remote response indicators.

7.2.3 SPECIAL FEATURES

- a. The detector shall be compatible to work with ionization smoke detectors with inter changeable base.
- b. The detector shall be capable of detecting the smoke at various levels.
- c. The detector shall be protected against reverse polarity of incoming supply.
- d. The detector shall incorporate solid-state light emitting diode and high-speed light sensing photo diode within the sensing chamber in addition to electronic circuit connecting contacts and cleanable protective housing.

- e. The detector shall be highly reliable, stable and capable of giving fine performance under the site conditions of varying temperature, humidity and air velocity.
- f. The detector shall be self-hold type capable of maintaining the alarm signal until the system is reset at the control unit.
- g. The detector should have necessary protection against reverse polarity of incoming supply.

7.3 HEAT DETECTOR

7.3.1. OPERATIONAL PRINCIPLE

The detector function with a dual action using two distinct method of fire detection i.e. rate of rise and fixed temperature.

The rate of rise element consists of an air chamber, a flexible metal diaphragm, a moisture proof trouble free vent which is carefully calibrated at the factory. Air expands as it is heated and contract as it is cooled. For normal day to day fluctuations the expansion and contraction of the air with in the chamber is automatically compensated by the breathing action of vent. However, when fire occurs air temperature is raised very rapidly and the air in the chamber expands faster than it can be vented. This raised very rapidly and the air in the chamber expands faster than it can be vented. This creates a pressure which distorts the diaphragm and closes the electrical contracts. The rate of rise action is not related to any fixed temperature when the rate of temperature rise is very fast.

If the heat is subsequently removed the air within the chamber contracts relieving the pressure and the detector automatically restores itself to the normal open circuit position.

In the instance of a very slow smoldering fire where the temperature do not increases, rapidly enough to operate the rate of rise element, the fusible solder melts at a predetermined temperature and release the spring which closes the electrical contracts.

7.3.2 GENERAL FEATURES

- a. The heat detector shall function in dual action that is using two distance methods of fire detection i.e. one by sensing rate of temperature rise another by sensing fixed temp.
- b. The heat detector shall act as an open circuit device and designed to close and electrical circuit upon being activated.
- c. The fixed temperature-sensing feature shall be entirely independent of rate of temperature rise sensing feature.
- d. The detector shall have phosphor bronze spring held under tension by fusible soldered link in order to active fixed temperature sensing feature.

7.4 HOOTER

- a. The hooter shall be suitable for wall mounting and shall incorporate hooter card and speaker inside a metallic box.
- b. The hooter shall be mounted at about 2.4 meter above floor level.
- c. The hooter shall be actuated by the control panel and speaker by the PA system.
- d. The hooter shall be totally electronic solid state type speaker cum siren having interrupted tone for alert and continuous tone for evacuation alarm. The interrupted tone shall be ON for 3 seconds and OFF for one second.
- e. The hooter shall operate on designed operating voltage.

- f. The hooter shall be suitable for an audible range of 80db at 1 m with a frequency range of 500 HZ to 1000 HZ.

7.5 MANUAL CALL POINT OR PULL BOX

- a. The manual call point shall be aluminium or MS construction painted with fire red.
- b. The box shall be provided with front glass (minimum 30 sq cm.) and gasket to make it completely vermin and dust proof with hammer and chain. Those shall be so located to ensure that one or the other call box shall be readily accessible to all occupants without having to travel more than 22.5 meters.
- c. The glass front cover shall have written up – **“BREAK GLASS IN CASE OF FIRE”**.
- d. The box shall be suitable for wall mounting and shall be mounted at 1.2 meters above floor level.

7.6 PUBLIC ADDRESS SYSTEM:

- a. The main control panel shall be compatible with amplifier of 30 W RMS at 10% THD/75 W RMS (Max.) capacity with selector switches for alert & evacuation alarm and public Address to all the areas.
- b. The amplifier shall be capable of receiving 1 AUX input in the form of MP-3 player with USB reader & remote control in addition to permitted connection of two microphones.
- c. The amplifier shall work on A.C. or 24 Volts or D.C. power supply derived from the main control panel. Automatic changeover facility for uninterrupted service shall be provided.
- d. Master control for adjustment of volume shall be provided.
- e. Active bass and treble control with cut and boost for creating total quantity shall be provided.
- f. The amplifier unit shall have complete protection against overload, short circuit, wrong battery polarity and other accidental mistakes.
- g. LED array shall be provided for monitoring and indicating the output level.
- h. The amplifier shall have Hum and Noise level battery tone 60 db.

8. SPECIFICATION OF MICROPROCESSOR BASED CONTROL PANEL FOR FIRE DETECTION SYSTEM

The purpose of introducing microprocessor based control panel in fire detection system is to make the panel more compact by reducing the number of components , minimizing false alarms and the qty of cable required , better reliability and making it more user friendly . However the essential features of local control panel have been included in the microprocessor based panel.

8.1 GUIDELINES FOR DESIGN -

- (i) The transistor used in the circuits shall be derated by as much as 50% and shall operate at only 25% of their wattage to safeguard against thermal run away.
- (ii) No resistance shall be working at more than 1/3rd of its rated wattage and shall give good stability and resistance to moisture, vibration, temperature and dust.
- (vii) The standby power supply should be capable of maintaining the system in normal operation for a period of not less than 48 hours after the failure of normal mains supply after which sufficient capacity would remain to provide full load operation for at least 1 hour. The full load would be defined as that caused by the operation of all the alarm sounders operating simultaneously, operation of a detector in at least 25 percent of zones (with a minimum of two zones) and the operation of the fault indicator. The operation of trigger devices in further zones should not result in cancellation of fire alarms existing at that time.

- (viii) The power supply unit shall have solid state battery charger circuit for charging of sealed maintenance free battery whenever the battery is discharged below the predetermined level. The rate of battery charging should be such that, having discharged to its final voltage, the battery can comply the recommendations of Para 2 above after a charging period of 24 hours. The charger shall sufficiently charge the battery in 8 hours so as to supply the maximum system load at an adequate voltage for at least 2 hours.
- (ix) The printed circuit board and all the components in the panel shall be suitably protected against Atmospheric corrosion.
- (x) Circuit and design of the panel shall be such that the operation (or) failure of one indicator does not prevent the proper and independent operation of other indications.

8.2 ADDITIONAL DESIGN FEATURES -

1. All the devices in a zone viz. detector, sounders, manual call points shall be operated on same two wires of zone.
2. Where the panel is used with conventional system, the microprocessor based control panel must be compatible with conventional main control panel as well as local control panel and detectors of approved makes.

8.2.1 GENERAL –

- (i) The panel shall be fabricated from 16 gauge (1.6 mm) CRCA sheet, completely dust and vermin proof with Neoprene gasket, wall mounting and front open able type with hinged door.
- (ii) The panel shall have glass door enclosure with lock and key arrangement.
- (iii) Suitable knockouts shall be provided for termination of conduits and cable glands.
- (iv) The panel shall be powder coated with approved colour and finish.
- (v) All components and their wiring shall be arranged so as to be conveniently attended to from the front of the panels.

8.2.2 All indicating lamps shall be LED type and of the following colours. The zone indicators indicating FIRE should consist of two LEDs –

- (i) FIRE warning indicator should be clearly labeled and coloured red.
- (ii) FAULT warning indicator should be clearly labeled and coloured amber with provision for identifying open /short separately.
- (iii) The feather touch switches and indicating lamps shall be located in the front fascia of the panel and shall be unambiguously labeled.
- (iv) The primary alarm circuit shall be solid state.
- (v) The PCBs shall be easily removable. The connections of The PCBs shall be through interface cord of plug – in – type.
- (vi) An audible signal along with its silencing switch shall be provided on the control panel.
- (xi) The Earthing terminal shall be provided on the frame of the control panel.
- (xii) The panel shall have ventilating louvers with wire mesh.
- (xiii) Laminated wire diagram shall be pasted at a suitable place inside the panel.

8.2.3 FEATURES –

- (i) The control panel shall continuously monitor OPEN / SHORT leads in each zone, fire detectors / manual call points with audio alarm distinct the alarm for FIRE and FAULT and shall visually indicate FIRE / FAULT in corresponding zone.
 - (ii) For multi-storeyed building separate panels may be installed on each floor with individual power supply and batteries to reduce the interdependence of one panel over the other panel. However a repeater panel may be provided at the ground floor with sounder to indicate the FIRE/FAULT condition at various floors.
3. The manual controls for switching OFF/ON, MAINS/STANDBY power provided shall not be accessible to outsiders.
 4. The panel shall have the following visual indications for –
 - a. System on – green
 - b. Stand by on – green
 - c. Charger on – green
 - d. Isolation of a zone for testing purpose.
 5. Audio – Visual indication shall be provided for the following –
 - a. The operation of fire detector in any zone.
 - b. Short circuit or disconnection of leads in any zone.
 - c. Failure or disconnection of normal power supply.
 - d. Failure or disconnection of standby power supply.
 - e. Failure or disconnection of battery charging equipment.
 - f. Battery voltage low.
 - g. Common indication for earth fault in the panel / zone.
 6. The panel shall have the following supervisory facility –
 - a. Switch for acknowledgement.
 - b. Switch for manual reset of panel after normal of fire condition.
 7. Means shall be provided in the panel to prevent battery from discharging through the charging equipment in the event of its breakdown or failure.
 8. Facilities shall be provided to test the zones individually by simulating fire and fault condition. On test mode the panel shall automatically reset after a predetermined time, once the fault or fire is cleared. The testing authority shall be able to test continuously all the zones without the necessity of resetting the panel every time.
 9. Each zone shall be capable of isolation for maintenance or test purposes leaving the remaining zones in healthy condition so that fire and fault detection in other zones is not affected.
 10. Facility for testing all the LEDs shall also be available.
 11. Fuses shall be provided for AC, DC and charger circuit close to the source of supply in an easy accessible place.
 12. The user shall be able to acknowledge the fire / fault audio visual alarm and reset the panel directly without the use of any password or key.
 13. Only on test condition, Fire and Fault shall reset automatically. On actual conditions, any audio alarm in the panel due to fault condition (except fire), if not acknowledged within two minutes, should be made to stop automatically by providing a timer.
 14. Silencing the sounder shall not prevent fire alarm being activated in any other zone simultaneously.
 15. Any fault signal including fault testing which the panel might be experiencing shall not prevent the fire alarm being given if any detector activates at the same time in other zone.

16. When fire is detected, the corresponding zone LEDs shall flash when the alarm is first signaled and will glow steadily after the silence button is pressed.
17. Three NO and NC contacts shall be provided for remote monitoring.
18. When a fire is detected, all alarms in all zones will give continuous dual tone for evacuate condition.
19. It shall be possible to program on the panel for isolating the power supply to zones for maintenance purpose.

POWER SUPPLY -

1. The entire system shall be suitable to operate on 230 + 10 %, 50 HZ single phase AC supply with 12/24 V sealed maintenance free battery as secondary source.
2. The power supply unit shall consist of solid state power rectifier of adequate capacity so as to provide 12/24 V stabilized DC power as output while receiving 230 V + 10% , 50 HZ single phase AC supply.
3. Battery voltage low alarm shall be activated at 10.5 V for 12 V battery and 21V FOR 24V BATTERY.
4. The unit shall have automatic change over facility from mains to battery and vice versa.
5. The battery shall be housed in the control panel itself.
6. Battery charging voltage shall not be greater than 13.6V for 12V battery and 27.2 V for 24 V battery.
7. The battery shall be isolated from MS sheet enclosures by means of rubber pad.

IMPORTANT NOTE:

The above general specifications are for reference as the prototype of the microprocessor based fire control panel has been approved in respect of different manufacturers and the firm shall supply the microprocessor based panel as per approved prototype. Wherever the prototype approved specification of the individual manufacturer are silent then above specifications shall prevail to that extent.

SECTION- 3 Part C
SCHEDULE OF REQUIREMENTS

NIT NO- 24/BSNL/BSR/2020-21

NAME OF WORK: Providing Electro-Mechanical Services, provision for Air conditioning, Automatic Fire Detection, Fire Alarm System, Fire Extinguishers etc for Orchid project labs and shifted site of Banana Project Labs at Regional Plant Resource Centre at Bhubaneswar **(S.H: SITC of Automatic Fire Detection and Fire Alarm system & Fire Extinguishers)**

| SI No | Description of items | Quantity |
|-------|--|----------|
| 1 | Supply, installation, testing and commissioning of UL listed, CE certified 2 wire conventional Photo electric / Ionization type Smoke detector with base made of ABS plastic with all accessories, suitable for operation on 24v DC, internal protection class: IP23, dual pulsing LED with 360 ⁰ visibility, relative humidity: ≤95%;non-condensing and EN54 compliance of approved make etc. as required. | 80nos |
| 2 | Supply, installation, testing and commissioning of UL listed, CE certified 2 wire conventional Multi detector (fixed cum rate of rise heat Detector using a thermistor, raises an alarm when the detector reaches 59 ⁰ C (Fixed) or when the change in temperature exceeds the rate of rise of 11 ⁰ C/min) with base made of ABS plastic and all accessories, suitable for operation on 24 v DC, internal protection class: IP23, dual pulsing LED with 360 ⁰ visibility, relative humidity: ≤95%;non-condensing and EN54 compliance of approved make etc. as required. | 3nos |
| 3 | SITC of dual LED response indicators made of ABS plastic, wall/ceiling mounted, operating voltage 24V DC, 5mm LED lamp glow light colour red compatible with all detectors etc. as required. (Make- Apollo / Honeywell / GST/ system sensor/ Ravel /Agni) | 20nos |
| 4 | SITC of manual push button station (pill box) made of 16/20 SWG MS CRCA sheet, powder coated, signal red colour with 2mm thick break glass area not less than 30sq.cm, diffuse type LED, nickel plated brass hammer with SS chain, facility for cable entry from top, sign writing "In case of Fire Break Glass" suitable for operation on 24V DC supply etc. as required. (Make- Apollo / Honeywell / GST/ system sensor/ Ravel /Agni) | 6nos |
| 5 | Supply, installation, testing and commissioning of electronic hooter cum speaker made of 16/18SWG CRCA sheet duly powder coated with PO red colour, output not less than 80db @25mtr, LMT with adjustable sound output of 2.5 watt,5 watt, suitable knock out for cable entry from top suitable for operation on 100/70 volt RMS AC supply etc. as required. (Make- Apollo / Honeywell / GST/ system sensor/ Ravel /Agni) | 6nos |
| 6 | Supply, installation testing and commissioning of following Zones UL listed Microprocessor based Fire Alarm Control Panel Made of 16/18 SWG CRCA sheet powder coated, finish suitable for operation with 220V 50HZ AC mains power supply with standby battery backup 24Volt DC power supply and built in charger (without batteries) , normal operating voltage 24 v DC, compatible with all types of conventional detectors, manual call points and normally opened dry contact devices, 16X2 Dot matrix display, fully compatible with UL-864 and NFPA-72 etc. complete as required as per details specifications. | |
| 6.1 | 4 Zone | 1no |
| 6.2 | 8 Zone | 1no |

| | | |
|------|--|-----------|
| 7 | SITC of 2nos 12V sealed maintenance free battery of not less than 7AH capacity with all accessories etc as reqd.(Excide /Amco/Superior) | 2 sets |
| 8 | Supplying and fixing of 600x450mm laminated floor plan mounted on the hard board showing area covered by each zone along with each control panel etc as reqd. | 2nos |
| 9 | P/F fire exit sign board on ceiling/wall with suitable bracket of angle iron/flat as required made of 20 gauge MS sheet and aluminium frame of nominal size of 400x200x150mm illumination by miniature fluorescent tube operated on DC emergency supply, exit sign board shall be painted in red on 2mm thick acrylic sheet. | 6nos |
| 10 | Supplying & Fixing of mounted photo luminescent signage's non-toxic, non-radioactive maintenance free self glowing safety signage's comprising of supplied chargeable crystals to glow in the dark with high intensity luminous 1.2 mm aluminum sheet properties by chemical coated (Vinyl & Tap not accepted) and covered with UV protection layer printed in multi language ad graphic symbol as per requirement etc as required. (Make Glo-line). | 800sqinch |
| 11 | S/F ABS round box / MS Box on ceiling for fixing the detectors etc as reqd. | 40nos |
| 12 | Supply and laying of 2 core 1.5sqmm FRLS PVC insulated and PVC sheathed copper conductor armoured cable on surface/recess for looping the fire alarm devices & providing power supply to sounder cum strobes etc. as required. (ISI) | 500mtrs |
| 13 | Supplying and making indoor end termination with brass compression gland and aluminium lugs for following size of PVC insulated and sheathed/XLPE aluminium conductor cable of 1.1 KV grade as required. a) 2 core, 6 Sq. mm (19mm) | 150nos |
| 14 | Supplying and drawing of following sizes FRLS PVC insulated copper conductor single core cable in the existing surface/recessed steel conduit as required (ISI). a) 2X1.5sqmm | 150mtrs |
| 15 | Supplying and fixing of following sizes UPVC single compartment trunking/mini trunking on surface of wall/ceiling along with all accessories i.e. external angles, couplers, cable retainers etc. for drawing of wire/cable of fire detection and alarm system etc. as required.(Make: MK/Legrand/Schnieder) | |
| 15.1 | 100mmX50mm | 10mtrs |
| 15.2 | 50mmX50mm | 10mtrs |
| 15.3 | 32mmX12.5mm | 50mtrs |
| 16 | Supplying and fixing of following sizes medium class UPVC pipes on surface of wall/ceiling with all accessories and GI saddles etc. for drawing of wire/cable of fire detection and alarm system etc. as required. (Make: Precision/Universal/supreme/kinjal/ISI) | |
| 16.1 | 20mm dia | 75mtrs |
| 16.2 | 25mm dia | 50mtrs |
| 17 | S/f of CO ₂ type fire extinguisher of 4.5 Kg. capacity confirming to IS 2878/86 made from ISI marked seamless cylinder confirming to IS 7285 duly approved by the chief controller of explosive fitted with ISI marked controlled valve confirming to IS3224 with high pressure 1 meter discharge hose & horn complete with initial charging complete with handle, wall mounting bracket and fixing the same on suitable clamps etc. as required. (Make: Ceasefire/Safex /superior) | 16nos |
| | | |

SECTION-4 Part A
GENERAL INSTRUCTIONS TO BIDDERS (GIB)

(Special Instruction to Bidders in Section -4 Part B will supersede the instructions in this section in case of any conflict)

1.0 DEFINITIONS

- (a) **"The Purchaser"** means the Bharat Sanchar Nigam Ltd.(BSNL), New Delhi
- (b) **"The Bidder"** means the individual or firm who participates in this tender and submits its bid. (**Tenderers**)
- (c) **"The Supplier/Contractor"** means the individual or firm supplying the goods / Services or to execute the works under the contract.
- (d) **"The Goods"** means all the equipment, machinery, and/or other materials which the Supplier/Contractor is required to supply to the purchaser under the contract.
- (e) **"The Advance Purchase Order"** or **"Letter of Intent"** means the intention of Purchaser to place the Purchase Order on the bidder. (**Acceptance letter or LOI**).
- (f) **"The Purchase Order"** means the order placed by the purchaser on the Supplier/Contractor signed by the purchaser including all attachments and appendices thereto and all documents incorporated by reference therein. The purchase order shall be deemed as "Contract" appearing in the document. (**Award letter/Work Order**).
- (g) **"The Contract Price"** means the price payable to the Supplier/Contractor under the purchase order for the full and proper performance of its contractual obligations.
- (h) **"Successful Bidder(s)"** means the bidder(s) to whom work in this tender is awarded.
- (i) **"Client Department OR User Department"** means RPRC Bhubaneswar.

2.0 ELIGIBILITY CONDITIONS:

- 2.1 Kindly refer to clause 4 of Section – 1 i.e. Detailed NIT.

3.0 COST OF BIDDING

- 3.1 The bidder shall bear all costs associated with the preparation and submission of the bid. The purchaser will, in no case, be responsible or liable for these costs, regardless of the conduct or outcome of the bidding process.

4.0 DOCUMENTS REQUIRED

- 4.1 The goods/services required to be supplied/ provided, bidding procedures and contract terms and conditions are prescribed in the Bid Documents. The contents of the Bid documents are specified in the covering letter.
- 4.2 The Bidder is expected to examine all instructions, forms, terms and specifications in the Bid Documents and clarifications/ amendments/ addenda, if any. Failure to furnish all information required as per the Bid Documents or submission of the bids not substantially responsive to the Bid Documents in every respect will be at the bidder's risk and may result in rejection of the bid.

5.0 CLARIFICATION OF BID DOCUMENTS

- 5.1. A prospective bidder, requiring any clarification on the Bid Documents shall notify BSNL in writing by FAX or by E-mail of the purchaser as indicated in the invitation of Bid. The purchaser shall respond in writing to any request for the clarification of the Bid Documents, **which it receives 05 days prior to the date of opening of the Tenders.** Copies of the query (without identifying the source) and clarifications by the purchaser shall be uploaded on the BSNL Tender website.
- 5.2 Any clarification issued by BSNL in response to query raised by prospective bidders shall form an integral part of bid documents and shall amount to an amendment of the relevant clauses of the bid documents.

6.0 AMENDMENT OF BID DOCUMENTS

- 6.1 The purchaser may, for any reason, whether at its own initiative or in response to a clarification requested by a prospective bidder, may modify bid documents by amendments prior to the date of submission of Bids with due notification to prospective bidders on BSNL tender website.
- 6.2 The amendments shall be notified in by Addendum through BSNL Tender website and these amendments will be binding on the prospective bidders.
- 6.3 In order to afford prospective bidders a reasonable time to take the amendment into account in preparing their bids, the purchaser may, at its discretion, extend the deadline for the submission of bids suitably.

7.0 DOCUMENTS COMPRISING THE BID

The bid prepared by the bidder shall ensure availability of the following components:

- a) Documentary evidence establishing that the bidder is eligible to bid and is qualified to perform the contract if its bid is accepted in accordance with the clause 2 & 10.
- b) Bid Security furnished in accordance with clause 12.
- c) A Clause by Clause compliance as per clause 11.2(c)
- d) A Bid form and price schedule completed in accordance with clause 8 & 9.
- e) Tender Cost in accordance with Clause.2.2 of Section-1 (Detailed NIT)

8.0 BID FORM

- 8.1 The bidder shall complete the bid form and appropriate Price Schedule furnished in the Bid Documents, indicating the goods to be supplied/Services to be provided, brief description of the goods/Services, quantity and prices as per section-9.

9.0 BID PRICES

- 9.1 The bidder shall give the total composite price inclusive of all Levies, packing, forwarding, freight and insurance etc but excluding GST and octroi / entry tax which will be paid extra at actual wherever applicable. The basic unit price and all other components of the price need to be individually indicated up to two decimal points only against the goods it proposes to supply under the contract as per the price schedule given in Section 9 Part-B .

The offer shall be firm in Indian Rupees. No Foreign exchange will be made available by the purchaser.

- 9.2 Prices indicated in the Price Schedule shall be entered in the following manner:
- (a) The Basic Unit price (Ex-Factory Price) of the goods, GST and other applicable taxes, Freight, Forwarding, Packing, Insurance and any other Levies/ Charges already paid or payable by the Supplier/Contractor shall be quoted separately item wise if applicable.
 - (b) The Supplier/Contractor shall quote as per price schedule given in Section 9 part B for all the items given in schedule of requirement at Section 3 part C.
- 9.3 A bid submitted with an adjustable price quotation will be treated as non- responsive and rejected.
- 9.4 The prices quoted by the bidder shall be in sufficient detail to enable the purchaser to arrive at the price of equipment/ system offered.
- 9.5 "DISCOUNT if any, offered by the bidders shall not be considered unless specifically indicated in the price schedule. Bidders desiring to offer discount shall therefore modify their offers suitably while quoting and shall quote clearly net price taking all such factors like Discount, free supply, etc. into account".
- 9.6 The price approved by BSNL for procurement will be inclusive of levies and taxes, packing, forwarding, freight and insurance as mentioned in clause 9.1 subject to other terms and condition as stipulated in clause 22.2 of Section 4 Part A. and clause 11 of Sec-5 Part A of Bid-document. Unloading charges at the consignee end shall be borne by the Supplier/Contractor and no separate charges shall be paid for transportation to individual sites for installation.
- 9.7 The freight by sea for transportation of equipment/Stores from the nearest port in the mainland to Andaman & Nicobar Islands will be reimbursed to the Supplier/Contractor at the concessional rates levied by Ministry of Water and Surface Transport on production of proof.

10.0 DOCUMENTS ESTABLISHING BIDDER'S ELIGIBILITY AND QUALIFICATION

- 10.1. The bidder shall furnish, as part of the bid documents establishing the bidder's eligibility, the documents as per clause-6.1 to 6.3 of Section-1 (DNIT) or whichever is required as per terms and conditions of Bid Documents (i.e. only those documents to prove eligibility and qualification of specific bidder)
- 10.2 Documentary evidence for financial and technical capability
- a) The bidder shall furnish audited Annual Report and/or a Turn over certificate from its Chartered Accountants showing the Turn over for last 3 years.
 - b) The bidder shall furnish documentary evidence about technical and production capability necessary to perform the contract.
- 10.3 In order to enable the purchaser to assess the proven-ness of the system offered, the bidder shall provide documentary evidence regarding the system being offered by him.

11.0 DOCUMENTS ESTABLISHING GOODS' / SERVICES CONFORMITY TO BID DOCUMENTS

- 11.1 Pursuant to clause 7, the bidder shall furnish, as part of its bid, documents establishing the conformity of its bid to the Bid Documents of all goods and services which he proposes to supply under the contract.
- 11.2 The documentary evidences of the "goods and services" conformity to the Bid Documents may be, in the form of literature, drawings, data etc. and the bidder shall furnish:
- (a) a detailed description of goods with essential technical and performance characteristics;
 - (b) a list, giving full particulars including available sources and current prices of all spare parts, special tools, etc., necessary for the proper and continuous functioning of the goods for a period of three years following commencement of use of the goods by the purchaser and
 - (c) a clause-by-clause compliance on the Technical Specifications and Commercial Conditions demonstrating substantial responsiveness to the Technical Specifications and Commercial Conditions. A bid without clause-by-clause compliance of the Scope of Work, Technical Specifications, SOR (Section-3 Part A, B & C), General (Commercial) Conditions & Special (Commercial) Conditions (Section- 5 Part A & B), shall not be considered.
- 11.3 For the purpose of compliance to be furnished pursuant to the clause 11.2(c) above, the bidder shall note that the standards for the workmanship, material and equipment and reference to the brand names or catalogue number, designated by the purchaser in its Technical specifications are intended to be descriptive only and not restrictive.

12.0 BID SECURITY /EMD

12.1 The bidder shall furnish, as part of its bid, a bid security as mentioned in Section-1 (DNIT).

12.2 THE MSE BIDDERS ARE EXEMPTED FROM PAYMENT OF BID SECURITY:

- a) A proof regarding valid registration with body specified by Ministry of Micro, Small & Medium Enterprise for the tendered items will have to be attached along with the bid.
- b) The enlistment certificate issued by MSME should be valid on the date of opening of tender.
- c) If a vendor registered with body specified by Ministry of Micro, Small & Medium Enterprise claiming concessional benefits is awarded work by BSNL and subsequently fails to obey any of the contractual obligations, He will be debarred from any further work/ contract by BSNL for one year from the date of issue of such order.

- 12.3** The bid security is required to protect the purchaser against the risk of bidder's conduct, which would warrant the forfeiture of bid security pursuant to Para12.7.
- 12.4. A bid not secured in accordance with Para 12.1 & 12.2 shall be rejected being non-responsive at the bid opening stage and shall be returned to the bidder.
- 12.5 The bid security of the unsuccessful bidder will be discharged /returned as promptly as possible and within 30 days of finalization of the tender or expiry of the period of the bid validity period prescribed by the purchaser pursuant to clause13.
- 12.6 The successful bidder's bid security will be discharged upon the bidder's acceptance of the purchase order satisfactorily in accordance with clause 27 and furnishing the performance security.

12.7 THE BID SECURITY MAY BE FORFEITED:

- a) If the bidder withdraws or amends its bid or impairs or derogates from the bid in any respect during the period of bid validity specified by the bidder in the bid form or extended subsequently, or
- b) If the bidder does not accept the PO/ AWO and/ or does not submit PBG & sign the contract/ agreement in accordance with clause 28.

Note:-The bidder shall mean individual company/ firm or the front bidder and its technology/ consortium partner, as applicable.

13.0 PERIOD OF VALIDITY OF BIDS

- 13 .1 Bid shall remain valid for period specified in clause 2 of Tender Information. A bid valid for a shorter period shall be rejected being non- responsive.
- 13.2 In exceptional circumstances, BSNL may request the consent of the bidder for an extension to the period of bid validity. The request and the response thereto shall be made in writing. The bid security provided under clause 12 shall also be suitably extended. The bidder may refuse the request without forfeiting its bid security. A bidder accepting the request and granting extension will not be permitted to modify its bid.

14.0 FORMAT AND SIGNING OF BID

- 14.1. The bidder shall submit his bid, through sealed envelopes physically complying all eligibility conditions, other terms and conditions of tender document to be read along with the clarifications and amendments issued in this respect. All the documents must be authenticated by hand signatures by the authorized person. The letter of authorization shall be indicated by written power-of-attorney accompanying the bid.

Note:- The purchaser may ask the bidder(s) to supply, besides original bid, additional copy of bids as required by him.

- 14.2. The bid shall contain no interlineations, erasures or overwriting except as necessary to correct errors made by the bidder in which case such corrections shall be signed by the person or persons signing the bid. All pages of the original bid, except for un-amended printed literatures, shall be signed by the person or persons signing the bid.

14.3 Power of Attorney

- (a) The power of Attorney should be submitted and executed on the non-judicial stamp paper of appropriate value as prevailing in the concerned states(s) and the same be attested by a Notary public or registered before Sub-registrar of the state(s) concerned.
- (b) The power of Attorney be executed by a person who has been authorized by the Board of Directors of the bidder in this regard, on behalf of the Company/ institution/ Body corporate.
- (c) In case of the bidder being a firm, the said Power of Attorney should be executed by all the partner(s) in favour of the said Attorney.
- (d) Attestation of the specimen signatures of authorized signatory by the Company's/ firm's bankers shall be furnished. Name, designation, Phone number, mobile number, email address and postal address of the authorized signatory shall be provided.

15.0 SEALING AND MARKING OF BIDS

- 15.1 The bid should be submitted as per Clause 6 of Detailed NIT (Section-1)
- 15.2 The envelope will contain documents of bidder's satisfying the eligibility/Technical & commercial conditions as per clause 2&10 with bid security & Tender cost as per clause and bid containing Price Schedules as per Section 9 Part B.
- 15.2 If the envelope not sealed and marked as required at para 15.1 and 15.2, the bid shall be rejected.

16.0 SUBMISSION OF BIDS

- 16.1. Bids must be submitted by the bidders on or before the specified date & time indicated in Clause 6.4 of Section-I i.e. DNIT.
- 16.2 The Purchaser may, at its discretion, extend this deadline for the submission of bids by amending the Bid Documents in accordance with clause 6 in which case all rights and obligations of the purchaser and bidders previously subject to the deadline will thereafter be subjected to the extended deadline.
- 16.3 The bidder shall submit its bid offer against a set of bid documents purchased by him for all or some of the systems/ equipment as per requirement of the Bid Documents. He may include alternate offer, if permissible as per the bid. However, not more than one independent and complete offer shall be permitted from the bidder.

17.0 LATE BIDS

- 17.1 No bid shall be accepted after the specified deadline for submission of bids prescribed by the purchaser.

18.0 MODIFICATION AND WITHDRAWAL OF BIDS

- 16.1 The bidder will not be allowed to modify, revise or withdraw his bid after submission prescribed for submission of bid.

19.0 OPENING OF BIDS

19.1 The purchaser shall open bids physically in the presence of the authorized representatives of bidders present who chose to attend, at time & date specified in Clause-7 of DNIT (Section-1) on due date. The bidder's representatives, who are present, shall sign the tender register. Authority letter to this effect shall be submitted by the authorized representatives of bidders before they are allowed to participate in bid opening. (A Format is given in enclosed Section 7 C).

19.2 A maximum of two representatives of any bidder shall be authorized and permitted to attend the bid opening.

19.3 Name of envelopes to be opened & information to be read out by Bid Opening authority
(i) In Single stage bidding & single envelope system; techno-commercial bid & financial Bid will be opened on the date of tender opening given in NIT.

(ii) The following information should be read out at the time of bid opening:-

- a) Name of the Bidder
- b) Name of the item
- c) EMD amount & validity and acceptability
- d) Information in respect of eligibility of the bidder.
- e) Details of bid modification/ withdrawal, if applicable.
- f) Name of the item
- g) Quantities/prices quoted in the bid
- h) Discount, if offered
- i) Taxes & levies

19.4 The date fixed for opening of bids, if subsequently declared as holiday by BSNL, the revised date of schedule will be notified. However, in absence of such notification, the bids will be opened on next working day, time and venue remaining unaltered.

20.0 CLARIFICATION OF BIDS

20.1 To assist in the examination, evaluation and comparison of bids, the purchaser may, at its discretion ask the bidder for the clarification of its bid. The request for the clarification and the response shall be in writing. However, no post bid clarification at the initiative of the bidder shall be entertained.

20.2 If any of the documents, required to be submitted along with the technical bid is found wanting, the offer is liable to be rejected at that stage. However the purchaser at its discretion may call for any clarification regarding the bid document within a stipulated time period. In case of non-compliance to such Queries, the bid will be out rightly rejected without entertaining further correspondence in this regard.

21.0 PRELIMINARY EVALUATION

21.1 Purchaser shall evaluate the bids to determine whether they are complete, whether any computational errors have been made, whether required sureties have been furnished, whether the documents have been properly signed and whether the bids are generally in order.

- 21.2 Arithmetical errors shall be rectified on the following basis. Based on the quoted percentage of duties and taxes, Freight etc. the amounts quoted thereof shall be worked out and rounded off to 2 decimal points. In case the unit price quoted does not tally with its breakup, the same shall be corrected by summing up the breakups. If there is a discrepancy between the unit price and total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected by the purchaser.
- 21.3 If there is a discrepancy between words and figures, the amount in words shall prevail. If the Supplier/Contractor / Contractor does not accept the correction of the errors, its bid shall be rejected.
- 21.4 Prior to the detailed evaluation pursuant to clause 22, BSNL will determine the substantial responsiveness of each bid to the Bid Document. For purposes of these clauses, a substantially responsive bid is one which confirms to all the terms and conditions of the Bid Documents without material deviations. Purchaser's determination of bid's responsiveness shall be based on the contents of the bid itself without recourse to extrinsic evidence.
- 21.5 A bid, determined as substantially non-responsive will be rejected by purchaser and shall not subsequent to the bid opening be made responsive by the bidder by correction of then non-conformity.
- 21.6 The purchaser may waive any minor infirmity or non-conformity or irregularity in a bid which doesn't constitute a material deviation, provided such waiver doesn't prejudice or affect the relative ranking of any bidder.

22 EVALUATION AND COMPARISON OF SUBSTANTIALLY RESPONSIVE BIDS

- 22.1 The Purchaser shall evaluate in detail and compare the bids previously determined to be substantially responsive pursuant to clause 21.
- (a) **The evaluation and comparison of responsive bids shall be done on the basis of total quoted amount including GST and on the prices of the goods/services offered along with all applicable taxes, packing, Forwarding, Freight & Insurance charges etc. of the Bid-document after arithmetical correction in the manner laid down in clause 21.2 above.**
- (b) Duties, Taxes & Cesses for which the firm has to furnish GST Challans/Tax Invoices will be indicated separately in the PO.
- (c) Vendors should furnish the correct HSN/SAC classification/Customs tariff Head in the price Schedule. If the credit for the Duties, Taxes and Cesses under provision/rules under GST law is found to be not admissible at any stage subsequently owing to wrong furnishing of Tariff Head, then the Supplier/Contractors will be liable to refund such non admissible amount, if already paid, along with penalty and interest if charged by the concerned authority.
- (d) In case the Duties & Taxes which are non eligible for Input tax credit as per the quotes indicated in the price schedule by the Supplier/Contractors and subsequently at any stage it is found that Credit for such duties, Taxes and Cesses is admissible as per provision of GST law, then the Supplier/Contractors will be liable to refund the

amount equivalent to such Duties, Taxes and Cesses if already paid to them provided the credit can be claimed within the time prescribed under the applicable legislation and BSNL has all documents to claim such credit. The refund is also subject to the bidder performing necessary act for enabling BSNL to claim the credit viz. upload the information on GSTN. However the purchaser may allow the Supplier/Contractor to submit necessary documents in this regard which may enable the purchaser to avail the input tax credit provided such credit is still available for the amount so paid as per provision of GST law.

- (e) The purchaser reserves the right to ask the bidders to submit documentary proof confirming the correct HSN or SAC classification/Customs Tariff Head from the CGST/SGST/IGST officer or Customs authority where the HSN or SAC classification/Custom Tariff Head furnished against the particular tendered item by different bidders differs from each other or the same is found apparently not furnished in accordance with GST Act/ Customs Tariff notifications.
- (f) If the Supplier/Contractor fails to furnish necessary supporting documents i.e. Tax invoices / Customs invoices etc. in respect of the Duties, taxes and Cesses which are eligible for input tax credit, the amount pertaining to such Duties, Taxes and Cesses will be deducted from the payment due to the firm.
- (g) If the Supplier/Contractor fails to perform necessary compliances which would any manner restrict BSNL to claim input tax credit, then the amount pertaining to such Duties, Taxes and Cesses will be deducted from the payment due to the Supplier/Contractor.
- (h) If the Supplier/Contractor does not disclose the correct details on the invoice or on the GSTN viz. GSTIN, place of supply etc. which restricts BSNL to claim input tax credit then the amount pertaining to such Duties, Taxes and Cesses will be deducted from the payment due to the Supplier/Contractor.

23.0 CONTACTING THE PURCHASER

- 23.1 Subject to Clause 20, no bidder shall try to influence the Purchaser on any matter relating to its bid, from the time of the bid opening till the time the contract is awarded.
- 23.2 Any effort by a bidder to modify its bid or influence the purchaser in the purchaser's bid evaluation, bid comparison or contract award decision shall result in the rejection of the bid.

24.0 PLACEMENT OF ORDER

- 24.1. The Purchaser shall consider placement of orders for commercial supplies/services only on those eligible bidders whose offers have been found technically, commercially and financially acceptable and whose goods/services have been type approved/ validated by the purchaser. The Purchaser reserves the right to counter offer price(s) against price(s) quoted by any bidder.
- 24.2 The ordering price of any bidder shall not exceed the lowest evaluated package price. However, at a later stage if there is any increase in Govt. duties/taxes within scheduled delivery date (SDD), the unit prices with applicable revised duties/taxes will be paid to Supplier/Contractors keeping other levies & charges unchanged.

- 24.3. The purchaser reserves the right for the placement of order of entire tendered quantity on the bidder with the lowest evaluated price.
- 24.4 In the event of L2 and so on bidders refusing to accept its package de rated to the price of L1 bidder, BSNL reserves the right to place the order for entire quantity to the L1 bidder. It is mandatory for the L1 bidder to accept such an offer (second APO/PO) at evaluated L-1 price and shall perform the whole contract as envisaged in the tender document. The additional quantity, due to non-acceptance of respective quantity by L2 and/or L3 and so on bidders, as envisaged in clause3 (Distribution of Quantity) in section 4 Part B, shall be supplied/work will be carried out by the L-1 bidder as part of whole contract.

25. PURCHASER'S RIGHT TO VARY QUANTITIES

- a) BSNL reserves the right to increase or decrease up to 25% of the quantity of goods and services specified in the schedule of requirements without any change in the unit price or other terms and conditions at the time of award of work.
- b) BSNL also reserves the right for placement of additional order or up to 50% of the additional quantities of goods and services contained in the running tender/ contract within the currency of contract at the same rate or a rate negotiated (downwardly) with the existing vendors considering the reasonability of rates based on prevailing market conditions and the impact of reduction in duties and taxes etc and supplies to be obtained within delivery period scheduled afresh.
- c) In exceptional situation where the requirement is of an emergent nature and it is necessary to ensure continued supplies from the existing vendors, the purchaser reserves the right to place repeat order up to 100% of the quantities of goods and services contained in the running tender/contract at the same rate or a rate negotiated (downwardly)with the existing vendors considering the reasonability of rates based on prevailing market conditions and the impact of reduction in duties and taxes etc. Exceptional situation and emergent nature should be spelt out clearly detailing the justification as well as benefits accrued out of it and loss incurred in case this provision is not invoked and approved by the authority competent to accord administrative and financial approval for the procurement calculated on the basis of total procurement i.e. initial and proposed add-on quantity.

26. PURCHASER'S RIGHT TO ACCEPT ANY BID AND TO REJECT ANY OR ALL BIDS

The Purchaser reserves the right to accept or reject any bid, and to annul the bidding process and reject all bids, at any time prior to award of contract without assigning any reason whatsoever and without thereby incurring any liability to the affected bidder or bidders on the grounds of purchaser's action.

27.0. ISSUE OF ADVANCE PURCHASE ORDER

- 27.1. The issue of an Advance Purchase Order/Acceptance letter shall constitute the intention of BSNL to enter into contract with the bidder.

- 27.2 The bidder shall within 14 days of issue of the advance purchase order/Acceptance letter, give its acceptance along with performance security in conformity with the proforma provided with the bid document at Section-7B.
- 27.3 L-1 bidder may be issued Advanced Purchase Order (APO)/Purchase Order (PO) in two stages. The first APO/PO shall be issued for L-1 quantity as defined in clause above. The second APO/PO may be issued to L-1 bidder only when BSNL exercises the right for placement of order on balance tendered quantity on the bidder with the lowest evaluated price in conformity to Clause 24.3 & 24.4 of Section 4 Part A.

28.0 SIGNING OF CONTRACT

- 28.1 The issue of Purchase order shall constitute the award of contract on the bidder.
- 28.2 Upon the successful bidder furnishing performance security pursuant to clause 27, the Purchaser shall discharge the bid security in pursuant to clause 12, except in case of L-1 bidder, whose EMBG/EMD shall be released only after finalization of ordering of complete tendered quantity in pursuance to clause no. 24.4 & 27.3 of this section.
- 28.3 The successful tenderer/contractor, on acceptance of his tender by the Accepting Authority, shall, within 07 days from the date of issue of award letter, sign the contract consisting of the notice inviting tender, all the documents including drawings, if any, forming the tender as issued at the time of invitation of tender and acceptance thereof together with any correspondence leading thereto.

29.0 ANNULMENT OF AWARD

Failure of the successful bidder to comply with the requirement of clause 27 shall constitute sufficient ground for the annulment of the award and the forfeiture of the bid security in which event the Purchaser may make the award to any other bidder at the discretion of the purchaser or call for new bids.

30.0 QUALITY ASSURANCE REQUIREMENTS

NIT approving authority may require the Supplier/Contractor to have Quality Management System supported and evidenced by any combination of the following measures or any other measures:

- a) A Quality Policy.
- b) A management representative with authority and responsibility for fulfilling QA requirements and for interfacing with purchaser in the matters of Quality.
- c) Procedure for controlling design/ production engineering, materials, choice of components/vendors, manufacturing and packaging process for supplying quality products.
- d) System of Inward Good Inspection.
- e) System to calibrate and maintain required measuring and test equipment.
- f) System for tracing the cause for non-conformance (traceability) and segregating product which don't conform to specifications.
- g) Configuration management and change-control mechanism.

- h) A quality plan for the product.
- i) Periodical internal quality audits.
- j) A 'Quality Manual' detailing the above shall be furnished.

31.0 REJECTION OF BIDS

31.1 While all the conditions specified in the Bid documents are critical and are to be complied, special attention of bidder is invited to the following clauses of the bid documents. Non-compliance of any one of these shall result in outright rejection of the bid.

- a) Clauses 12.1, 12.2 & 13.1 of Section- 4 Part A: The bids will be rejected at opening stage if Bid security is not submitted as per Clauses 12.1 & 12.2 and bid validity is less than the period prescribed in Clause 13.1 mentioned above.
- b) Clause 2 & 10 of Section-4 Part A: If the eligibility condition as per clause 2 of Section 4 Part A is not met and/ or documents prescribed to establish the eligibility as per Clause 10 of section 4 Part A are not enclosed, the bids will be rejected without further evaluation.
- c) Clause 11.2 (c) of Section-4 Part A: If clause-by-clause compliance as well as deviation statements as prescribed are not given, the bid will be rejected at the stage of primary evaluation.
- d) While giving compliance to Section-5 Part A, General Commercial conditions, Section-4 Part B, Special Instructions to Bidders, Section- 5B Special (Commercial) Conditions of Contract and Section-3 Technical Specifications ambiguous words like "Noted", "Understood", "Noted & Understood" shall not be accepted as complied. Mere "Complied" will also be not sufficient, reference to the enclosed documents showing compliances must be given.
- e) Section-9 Price Schedule: Prices are not filled in as prescribed in price schedule.
- f) Section-4 Part A clause 9.5 on discount which is reproduced below:- "Discount, if any, offered by the bidder shall not be considered unless specifically indicated in the price schedule. Bidders desiring to offer discount shall therefore modify their offer suitably while quoting and shall quote clearly net price taking all such factors like Discount, free supply etc. into account".

31.2 Before outright rejection of the Bid by Bid-opening team/ tender opening authority for non-compliance of any of the provisions mentioned in clause 31.1(a), 31.1(b) of Section-4 PartA, the bidder company is given opportunity to explain their position, however if the person representing the company is not satisfied with the decision of the Bid opening team / tender opening authority, he/they can submit the representation to the Bid opening authority immediately but in no case after closing of the tender process with full justification quoting specifically the violation of tender condition if any.

31.3 Bid opening authority will not return the bids submitted by the bidders on the date of tender opening even if it is liable for rejection and will preserve the bids in sealed cover as submitted by taking the signatures of some of the desirous representatives of the participating bidder/companies present on the occasion.

31.4 The bid opening authority will mention the number of bids with the name of the company found unsuitable for further processing on the date of tender opening and number of representations received in Bid opening Minutes and if Bid opening team is satisfied with the argument of the bidder/company mentioned in their representation and feel that there is prima-facie fact for consideration, the in-charge of the bid opening team will submit the case for review to Officer competent to approve the tender as early as possible preferably on next working day and decision to this effect should be communicated to the bidder company within a week positively. Bids found liable for rejection and kept preserved on the date of tender opening will be returned to the bidders after issue of P.O. against the instant tender.

31.5 If the reviewing officer finds it fit to open the bid of the petitioner, this should be done by giving three (working) days notice to all the participating bidders to give opportunity to participants desirous to be present on the occasion.

32.0 ACTION BY PURCHASER AGAINST BIDDER(S)/VENDOR(S) IN CASE OF DEFAULT

In case of default by Bidder(s)/ Vendor(s) such as

- a) Does not supply the equipment in time;
- b) Equipment does not perform satisfactory in the field in accordance with the specifications;
- c) Does not start or carry out the work in time.
- d) **Or any other default whose complete list is enclosed in Appendix-1.**

Purchaser will take action as specified in Appendix-1 of this section.

33.0 Deleted

34.0 NEAR-RELATIONSHIP CERTIFICATE

34.1 The bidder should give a certificate that none of his/ her near relative, as defined below, is working in the units where he is going to apply for the tender. In case of proprietorship firm certificate will be given by the proprietor. For partnership firm certificate will be given by all the partners and in case of limited company by all the Directors of the company excluding Government of India/ Financial institution nominees and independent non-Official part time Directors appointed by Govt. of India or the Governor of the state and full time Directors of PSUs both state and central. Due to any breach of these conditions by the company or firm or any other person the tender will be cancelled and Bid Security will be forfeited at any stage whenever it is noticed and BSNL will not pay any damage to the company or firm or the concerned person.

34.2 The Company or firm or the person will also be debarred for further participation in the concerned unit.

34.3 The near relatives for this purpose are defined as:-

- (a) Members of a Hindu undivided family.
- (b) They are husband and wife.

- (c) The one is related to the other in the manner as father, mother, son(s)&Son's wife (daughter in law), Daughter(s) and daughter's husband (son in law), brother(s) and brother's wife, sister(s) and sister's husband (brother in law).
- (d) The format of the certificate is given in Section 6 (C).

35.0 VERIFICATION OF DOCUMENTS AND CERTIFICATES

The bidder will ensure that all the documents and certificates, including experience/performance and self certificates submitted by him are correct and genuine before enclosing them in the bid. The onus of proving genuineness of the submitted documents would rest with the bidder.

If any document/ paper/ certificate submitted by the participant bidder is found / discovered to be false / fabricated / tempered / manipulated either during bid evaluation or during award of contract or thereafter, then the Purchaser will take action as per Clause-1of Appendix-1 of this section.

SECTION-4 Part B

SPECIAL INSTRUCTIONS TO BIDDERS

Provisions in the Special Instructions to Bidders and Eligibility Conditions (SIB) (SECTION-4 Part B) shall supersede the corresponding provisions in the General Instructions to Bidders (GIB) (SECTION-4 Part A) in case of conflict.

1. **Eligibility Criteria:** As prescribed in the Detailed Notice inviting tender forming part of this document.

2. **BID Security/EMD:**

The bank guarantee/DD for bid security or Micro & Small Enterprise (MSE) registration certificate for claiming exemption from submission of bid security, as prescribed in clauses 12.1 & 12.2 of Section-4 A of the bid document should be submitted by the bidder in a separate cover. The bank guarantee/DD so submitted shall be as per the format given in Section-7 (A) on prescribed judicial paper with stamps of proper value and should contain full address of the issuing branch of the bank with its telephone number and FAX number.

3.0 Stores & Safety:

The contractor from his own sources shall arrange all the stores and materials required for the satisfactory completion of the work at work site. Lockable space for storing the materials may be provided by BSNL/client department on request from the contractor/Firm. However, safe custody of material stored at site will be the responsibility of the contractor/Firm.

4.0 Packing & Forwarding

Before dispatch to site, the equipment / components / materials shall be properly packed with polythene sheet and wooden planks for protection and avoiding transit damages and damage against storage in open area at transporters premises or at work site.

5.0 Coordination at site

At the site of work as more than one agency may be working, full cooperation shall be extended to other agencies during progress of work. Further, work shall be carried out in such a way so that it may not cause abnormal noise and hindrance to the officers of the BSNL/client department engaged in erection as well as doing normal routine work.

6.0 Extra/Substitute/Deviated items of works:

In a situation where the requirement is of an immediate nature and/or it is necessary to ensure continued supplies or substitute the items taken in running contract or addition of extra items from the existing vendors, the competent authority in BSNL (with in their delegated financial powers) may decide to place such orders with in a ceiling of maximum 100% of the contract value and at a rate negotiated with the existing vendors considering the prevailing market conditions.

7.0 Bye-laws, liabilities against damages and accidents

- a) The contractor shall comply with all bye-laws and regulations of local and statutory authorities having jurisdiction over the works and shall be responsible for payment of all fees and other charges and giving/ receiving all necessary notices and keep the Engineer-in-charge informed about the notices issued and received.
- b) **SAFETY PROCEDURES:** It is contractor's liability to follow all safety procedures in accordance with relevant I.S. amended up to date during execution of work at site.
- c) **COMPLIANCE OF EPF ACT:** The agency has to comply with the provision of EPF and miscellaneous provisions Act - 1952 and employees Provident Fund scheme-1952 as amended up to date in respect of labourers / employees engaged by them for this work. Any consequences arising due to non-complying of provisions as specified above shall be of the sole responsibility of the firm only.
- d) **DAMAGES TO INSTALLATIONS:** Any damage to the installation(s)/building during the execution of work due to the carelessness on the part of staff shall be the responsibility of firm & shall be replaced/rectified by the firm without any extra cost.
- e) **ACCIDENTS DURING EXECUTION OF WORKS:** Any accident or damage during execution of work will be the responsibility of the Contractor/Firm & the Department will not entertain any claim, compensation, penalty etc. on this account or on account of non observance of any other requirement of law relevant to his work.

10. TERMINATION OF CONTRACT ON DEATH OF CONTRACTOR

Without prejudice of any of the rights or remedies under this contract, if the contractor dies, the Engineer in charge on behalf of the BSNL shall have the option of terminating the contract without compensation to the contractor.

11. INDULGING OF CONTRACTOR IN CRIMINAL/ANTISOCIAL ACTIVITIES AND CASES UNDER INVESTIGATION / CHARGE SHEETED BY CBI OR ANY OTHER GOVERNMENT AGENCIES ETC. :

If the CBI/Independent External Monitor (IEM) / Income Tax /Sales Tax/ Central Excise/ Custom Departments recommend such a course – Action will be taken as per the directions of CBI or concerned department.

Section- 4 Part C

E-tendering Instructions to Bidders

General

These Special Instructions (for e-Tendering) supplement 'Instruction to Bidders', as enclosed in Sec 4 Part A of the Tender Documents. Submission of Bids through online process is mandatory for this Tender.

For conducting electronic tendering, BSNL Electrical Zone, Odisha is using the portal <https://etenders.gov.in/eprocure> of Government of India.

1. Broad outline of activities from Bidders prospective:

1. Procure a Digital Signing Certificate(DSC)
2. Register on Electronic Tendering System[®] (ETS)
3. Create Users and assign roles on ETS
4. View Notice Inviting Tender (NIT) on ETS
5. Download Official Copy of Tender Documents from ETS
6. Clarification to Tender Documents on ETS
 - Query to BSNL(Optional)
 - View response to queries posted by BSNL, as addenda.
7. Bid-Submission on ETS
8. Attend Public Online Tender Opening Event (TOE) on ETS Opening of Techno-commercial Part
9. View Post-TOE Clarification posted by BSNL on ETS (Optional)Respond to BSNL's Post-TOE queries
10. Attend Public Online Tender Opening Event (TOE) on ETS Opening of Financial-Part (Only for Technical Responsive Bidders)

2. Digital Certificates

For integrity of data and its authenticity/ non-repudiation of electronic records, and be compliant with IT Act 2000, it is necessary for each user to have a Digital Certificate (DC). also referred to as Digital Signature Certificate (DSC), of Class 2 or above, issued by a Certifying Authority (CA) licensed by Controller of Certifying Authorities (CCA) [refer<http://www.cca.gov.in>].

3. Registration

To use the Electronic Tender[®] portal <https://etenders.gov.in/eprocure>, vendor needs to register on the portal. Registration of each organization is to be done by one of its senior persons who will be the main person coordinating for the e-tendering activities. In ETS terminology, this person will be referred to as the Super User (SU) of that organization. For further details, please visit the website/portal, and click on the 'Supplier Organization' link under 'Registration' (on the Home Page), and follow further instructions as given on the site. Pay Annual Registration Fee as applicable.

Note: After successful submission of Registration details and Annual Registration Fee (as applicable). Please contact <https://etenders.gov.in/eprocure> ETS Helpdesk (as given below), to get your registration accepted/activated.

| | |
|----------------------------|---|
| Tender Wizard ETS Helpdesk | Central Public Procurement Portal (CPPP) |
| Telephone | 0120-4200462, 0120-4001002/005, 0120-6277787 |
| Website | https://etenders.gov.in/eprocure/app |

| | |
|-----------------------|---|
| BSNL Contact-1 | |
| BSNL's Contact Person | Shri.S.S. Panda, Executive Engineer(E) |
| Telephone/ Mobile | TELEPHONE – (0674) -2544902, FAX- 2540617 MOBILE: 9437964001 |
| E-mail ID | eebsnlbbsr@gmail.com |

| | |
|-----------------------|---|
| BSNL Contact-2 | |
| BSNL's Contact Person | Shri. S K Mohanty, SDE(E), BSNL Electrical Sub Division-II, Bhubaneswar |
| Telephone/ Mobile | 0674-2536332 / 9437966222 |
| E-mail ID | sdebsnlbbsr2@gmail.com |

4. **Bid related Information for this Tender**

The entire bid-submission would be online on ETS. Broad outline of submissions are as follows:

- Submission of Bid Security/ Earnest Money Deposit(EMD)
- Submission of digitally signed copy of Tender Documents/ Addendum /addenda
- Submission of self attested copies of documents as per list at Sl. no.6.2 of DNIT (Section-1, Part A).

5. **Offline Submissions:**

The bidder is requested to submit the following documents offline to the **Executive Engineer (E), BSNL Electrical Division, Bhubaneswar** on or before the date & time specified in the detailed NIT. The envelope shall bear (name of the work), the tender number and the words 'DO NOT OPEN BEFORE' (due date & time).

1. **EMD-Bid Security in Original.**
2. **Power of attorney in accordance with clause 14.3 of Section-4 Part A.**
3. **Integrity Pact.(If applicable)**
4. **Self attested copies of documents, under takings and Declarations listed at clause 7.0 of DNIT (Section-1, Part A).**
5. **Downloaded Tender document (Except PRICE BID/BOQ) duly signed and sealed by the bidder or his power of attorney holder.**

6. **Special Note on Security of Bids**

Security related functionality has been rigorously implemented in ETS in a multi-dimensional manner. Starting with 'Acceptance of Registration by the Service Provider', provision for security has been made at various stages in Electronic Tender's software. Security related aspects as regard Bid Submission are outlined below:

As part of the Electronic Encrypter™ functionality, the contents of both the 'Electronic Forms' and the 'Main-Bid' are securely encrypted using a Pass-Phrase created by the Bidder himself. Unlike a 'password', a Pass-Phrase can be a multi-word sentence with spaces between words (e.g. I love this World). A Pass-Phrase is easier to remember, and more difficult to break. It is recommended that a separate Pass-Phrase be created for each Bid-Part. This method of bid-encryption does not have the security and data-integrity related vulnerabilities which are inherent in e-tendering systems which use Public-Key of the specified officer of a Buyer organization for bid-encryption. Bid-encryption in ETS is such that the Bids cannot be decrypted before the Public Online Tender Opening Event (TOE), even if there is connivance between the concerned tender-opening officers of the Buyer organization and the personnel of e-tendering service provider.

Typically, 'Pass-Phrase' of the Bid-Part to be opened during a particular Public Online Tender Opening Event (TOE) is furnished online by each bidder during the TOE itself, when demanded by the concerned Tender Opening Officers who will open the bid. Else Tender Opening Officer may authorize the bidder to open his bid himself.

There is an additional protection with SSL Encryption during transit from the client-end computer of a Supplier organization to the e-tendering server/ portal.

7. **Public Online Tender Opening Event(TOE)**

ETS offers a unique facility for 'Public Online Tender Opening Event (TOE)'. Tender Opening Officers as well as authorized representatives of bidders

Can attend the Public Online Tender Opening Event(TOE) from the comfort of their offices. For this purpose, representatives of bidders (i.e. Supplier organization) dully authorized are requested to carry a Laptop and Wireless Connectivity to Internet.

Every legal requirement for a transparent and secure 'Public Online Tender Opening Event (TOE)' has been implemented on ETS. As soon as a Bid is decrypted with the corresponding 'Pass-Phrase' as submitted online by the bidder himself (during the TOE itself), salient points of the Bids are simultaneously made available for downloading by all participating bidders. The work of taking notes during a manual 'Tender Opening Event' is therefore replaced with this superior and convenient form of 'Public Online Tender Opening Event(TOE)'.

ETS has a unique facility of 'Online Comparison Chart' which is dynamically updated as each online bid is opened. The format of the chart is based on inputs provided by the Buyer for each Tender. The information in the Comparison Chart is based on the data submitted by the Bidders in electronic forms. A detailed Technical and/ or Financial Comparison Chart enhances Transparency. Detailed instructions are given on relevant screens. ETS has a unique facility of a detailed report titled 'Minutes of Online Tender Opening Event (TOE)' covering all important activities of 'Online Tender Opening Event (TOE)'. This is available to all participating bidders for 'Viewing/ Downloading'.

There are many more facilities and features on ETS. For a particular tender, the screens viewed by a Supplier will depend upon the options selected by the concerned Buyer.

NOTE: In case of internet related problem at a bidder's end, especially during 'critical events' such as – a short period before bid-submission deadline, during online public tender opening event, during e-auction, it is the bidder's responsibility to have backup internet connections. In case there is a problem at the e-procurement/ e-auction service-provider's end (in the server, leased line, etc) due to which all the bidders face a problem during critical events, and this is brought to the notice of BSNL by the bidders in time, then BSNL will promptly re-schedule the affected event(s).

8. Other Instructions

For further instructions, the vendor should visit the home-page of the portal <https://etenders.gov.in/eprocure> and go to the User-Guidance Center.

The help information provided through 'ETS User-Guidance Center' is available in three categories – Users intending to Register / First-Time Users, Logged-in users of Buyer organizations, and Logged-in users of Supplier Organizations. Various links are provided under each of the three categories.

Note: It is strongly recommended that all authorized users of Supplier organizations should thoroughly peruse the information provided under the relevant links, and take appropriate action. This will prevent hiccups, and minimize teething problems during the use of ETS.

The following 'FOUR KEY INSTRUCTIONS for BIDDERS' must be assiduously adhered to:

1. Obtain individual Digital Signing Certificate (DSC or DC) well in advance of your first tender submission deadline on ETS.
2. Register your organization on ETS well in advance of your first tender submission deadline on ETS
3. Get your organization's concerned executives trained on ETS well in advance of your first tender submission deadline on ETS
4. Submit your bids well in advance of tender submission deadline on ETS as there could be last minute problems due to internet timeout, breakdown, etc.

While the first three instructions mentioned above are especially relevant to first-time users of ETS, the fourth instruction is relevant at all times.

9. Minimum Requirements at Bidders end

- i) Computer System with good configuration.
- ii) Internet connectivity.
- iii) Microsoft Internet Explorer.
- iv) Digital Certificate(s) for users.

SECTION-5 Part A
GENERAL (COMMERCIAL) CONDITIONS OF CONTRACT

2. APPLICATION

The general condition shall apply in contracts made by the purchaser for the procurement of goods/Services.

3. STANDARDS

The goods/services to be supplied /work to be executed under this contract shall conform to the standards prescribed in the Technical Specifications mentioned in section -3.

4. PATENT RIGHTS

The Supplier/Contractor shall indemnify the purchaser against all third-party claims of infringement of patent, trademark or industrial design rights arising from use of the goods/services or any part thereof in Indian Telecom Network.

5. PERFORMANCE SECURITY

5.1 All Supplier/Contractors (including MSEs who are registered with the designated MSME bodies, like National Small Scale Industries Corporation etc. shall furnish performance security to the purchaser for an amount equal to **5% of the value of Advance purchase order** (Acceptance letter OR LOI) / Purchase Order (Award letter) **within 14days** from the date of issue of Advance Purchase Order (Acceptance letter OR LOI) / award letter by the Purchaser.

5.2 The proceeds of the performance security shall be payable to the Purchaser as compensation for any loss resulting from the Supplier/Contractor's failure to complete its obligations under the contract.

5.3 The performance security Bond shall be in the form of **Bank Guarantee** issued by a scheduled Bank and in the proforma provided in '**Section-7(B)**' of this Bid Document.

5.4 The performance security Bond will be discharged by the Purchaser after completion of the Supplier/Contractor's performance obligations including any warranty obligations under the contract.

6. INSPECTION AND TESTS

6.1 The Purchaser or its representative shall have the right to inspect and test the goods/materials/equipments/Apparatus & plants as per prescribed test schedules for their conformity to the specifications. Where the Purchaser decides to conduct such tests on the premises of the Supplier/Contractor or its sub contractor(s), all reasonable facilities and assistance like Testing instruments and other test gadgets including access to drawings and production data shall be furnished to the inspectors at no charge to the purchaser.

- 6.2 Should any inspected or tested goods/materials/equipments/Apparatus & plants fail to conform to the specifications the purchaser may reject them and the Supplier/Contractor shall either replace the rejected goods/materials/equipments/Apparatus & plants or make all alterations necessary to meet Specification / requirements free of cost to the purchaser.
- 6.3 Notwithstanding the pre-supply tests and inspections prescribed in clause a. & 5.2 above, the goods/materials/equipments/Apparatus & plants on receipt in the Purchaser's premises will also be tested during and after installation before "take over" and if any equipment or part thereof is found defective, the same shall be replaced free of all cost to the purchaser as laid down in clause 5.4 below.
- 6.4 If any equipment or any part thereof, before it is taken over under clause 5.5, is found defective or fails to fulfill the requirements of the contract, the inspector shall give the Supplier/Contractor/Contractor notice setting forth details of such defects or failure and the Supplier/Contractor/Contractor shall make the defective equipment good, or alter the same to make it comply with the requirements of the contract forthwith and in any case **within a period not exceeding the contract period**. These replacements shall be made by the Supplier/Contractor free of all charges at site. Should it fail to do so within this time, the purchaser reserves the discretion to reject and replace at the cost of the Supplier/Contractor/Contractor the whole or any portion of goods/materials/equipments/Apparatus & plants as the case may be, which is defective or fails to fulfill the requirements of the contract. The cost of any such replacement made by the purchaser shall be deducted from the amount payable to the Supplier/Contractor/Contractor.
- 6.5 When the performance tests called for have been successfully carried out, the inspector / ultimate consignee will forthwith issue a Taking Over Certificate. The inspector/ultimate consignee shall not delay the issue of any "taking Over Certificate" contemplated by this clause on account of minor defects in the equipment which do not materially affect the commercial use thereof provided that the Supplier/Contractor/Contractor shall undertake to make **good the same in a time period not exceeding the contract period / extended contract period**. The Taking Over Certificate shall be issued by the ultimate consignee **within six weeks** of successful completion of tests. In this case, BCPC (Bills Copy Payable Challan) shall be equivalent to "Taking Over Certificate", issuance of which shall certify receipt of goods/materials/equipments/Apparatus & plants in safe and sound condition. However, they shall not discharge the Supplier/Contractor/Contractor of their warranty obligation. BCPC in respect of last consignment against the purchase order will be equivalent to "Taking Over Certificate". This clause shall be applicable only when the material is supplied in Stores.
- 6.6 Nothing in clause 5 shall in any way release the Supplier/Contractor/Contractor from any warranty or other obligations under this contract.

7. DELIVERY AND DOCUMENTS

- 7.1 Delivery of the goods/materials/equipments/Apparatus & plants and documents shall be made by the Supplier/Contractor/Contractor in accordance with the terms specified by the purchaser in its schedule of requirements and special conditions of contracts, and the above shall remain at the risk of the Supplier/Contractor/Contractor until delivery/execution of works has been completed. The delivery of the equipment shall be to the ultimate consignee as given in the purchase order.
- 7.2 The delivery of the goods/services/equipments and documents or execution of works shall be completed within time frame stated in note 7 of Clause 6 of Section-2 (Tender information).
- 7.3 All Technical assistance for installation, commissioning and monitoring of the equipment shall be provided by the Supplier/Contractor at no extra cost during laboratory evaluation, validation/ type approval and field trial, if any.
- 7.4 **The extension of delivery period against the purchase order, if any, should be granted subject to the condition that BSNL shall have the absolute right to revise the price(s) and also to levy penalty for the delayed supplies.**

7.0 TRAINING :

- 7.1 The bidder shall provide training for installation and maintenance staff of the purchaser free of cost where required.
- 7.2 The bidder shall specify in its bid the number of trainees, quantum of proposed training, pre-training qualifications required of the trainees and duration of the proposed training.
- 7.3 The bidder shall provide all training material and documents.
- 7.4 Conduct of training of the purchaser's personnel shall be at the Supplier/Contractors' plant and/or on-site in assembly start-up operation, maintenance and/or repair of the supplied goods.

8.0 INCIDENTAL SERVICES

The Supplier/Contractor may be required to provide any or all of the following services:

- (a) Performance or supervision of on-site assembly and/or start-up of the supplied Goods;
- (b) Furnishing of tools required for assembly and/or maintenance of supplied Goods;
- (c) Performance of supervision or maintenance and/or repair of the supplied Goods, for a period of time agreed by the parties provided that this service shall not relieve the Supplier/Contractor of any warranty obligations under this contract.

9.0 WARRANTY

- 9.1 The Supplier/Contractor shall warrant that the stores /equipments / accessories to be supplied shall be new and free from all defects and faults in materials used, workmanship and manufacture and shall be of the highest grade and consistent with the established and generally accepted standards for materials of the type ordered and shall perform in full conformity with the specifications and drawings. The Supplier/Contractor shall be responsible for any defect that may develop under the conditions provided by the contract and under proper use, arising from faulty material, design or workmanship such as corrosion of the equipment, inadequate quantity of material to meet equipment requirements, inadequate contact protection, deficiencies in circuit design and/ or otherwise and shall remedy such defects at its own cost when called upon to do so by the Purchaser who shall state in writing in what respect the stores are faulty. This warranty shall survive inspection or payment for/ and acceptance of goods, but shall expire (except in respect of complaints notified prior to such date) twelve months after the stores have been taken over under clause 5.5 above or as per original manufacturer's warranty policy whichever is more.
- 9.2 If it becomes necessary for the Supplier/Contractor to replace or renew any defective portion(s) of the equipment under this clause, the provisions of the clause 10.1 shall apply to the portion(s) of the equipment so replaced or renewed or until the end of the above mentioned period, whichever may be later. If any defect is not remedied by the Supplier/Contractor within a reasonable time, the Purchaser may proceed to get the defects remedied from other Supplier/Contractor etc., at the Supplier/Contractors risk and expenses, but without prejudice to any other rights which the purchaser may have against the Supplier/Contractor in respect of such defects.
- 9.3 Replacement under warranty clause shall be made by the Supplier/Contractor free of all charges at site including freight, insurance and other incidental charges.

10.0 PAYMENT TERMS

- 10.1.1 Payment of specified percentage of the price as stated in clause 5 of Section -2 (Tender Information) shall be made on receipt of goods by consignee or after successful completion of works. For claiming this payment the following documents are to be submitted to the paying authority.
- 10.1.2 Invoice clearly indicating break up details of composite price i.e. Basic, GST, any other Duties and Taxes, Freight /Packing Charges etc.
- 10.1.3 Acknowledged Delivery Challan in original.
- 10.1.4 The sea freight receipt as per the rates approved by the Ministry of Water and Surface Transport, if applicable.
- 10.1.5 Proof of payment of Octroi/ entry tax etc., if applicable.

Note :-1) If the Supplier/Contractor fails to furnish necessary supporting documents i.e. GST invoice/Customs invoices etc. and also fails to upload the information on GSTN in respect of the Duties/taxes for which input tax credit is available, the amount

pertaining to such Duties/Taxes will be deducted from the payment due to the Supplier/Contractor.

- 2) Tax amount will be paid to the Supplier/Contractor only after Supplier/Contractor declares the details of the invoices in its return in GSTR 1 and GSTR -3 uploaded by the Supplier/Contractor and the same is reflected in GSTR-2A of BSNL on GSTN portal.
 - 3) TDS/TCS shall be deducted at the prescribed rate, if any(as the case maybe)
 - 4) BSNL can adjust/forfeit Bank Guarantee obtained from the Supplier/Contractor against any loss of input tax credit to BSNL on account of Supplier/Contractor's default.
 - 5) In case BSNL has to pay GST on reverse charge basis, the Supplier/Contractor would not charge GST on its invoices. Further, the Supplier/Contractor undertakes to comply with the provisions of GST law as may be applicable.
- 10.2 In those cases where such shortages/damages are intimated to the Supplier/Contractor in writing, the balance payment shall be released only after the cases are settled in accordance with the provision of the P.O.

Note: The actual payment conditions for new products or procurements having installation and AMC services may be decided on case to case basis and incorporated in special conditions of the contract."

10.3 A certificate stating that the tendered item (stores) are meant for the use of BSNL shall be provided by the purchaser on the request of the bidder as and when asked for.

10.4 No payment will be made for goods rejected at the site on testing.

10.5 The bidder has to give the mandate for receiving payment ~~costing Rs.5 lakhs and above~~ electronically and the charges, if any, levied by bank has to be borne by the bidder/contractor/Supplier/Contractor. The bidder company is required to give the following information for this purpose:-

- (a) Beneficiary Bank Name:
- (b) Beneficiary branch N
- (c) IFSC code of beneficiary Branch
- (d) Beneficiary account No.:
- (e) Branch Serial No. (MICR No.):

11.0 PRICES

11.1.1.1 Prices charged by the Supplier/Contractor for goods delivered and services performed under the contract shall not be higher than the prices quoted by the Supplier/Contractor in its Bid except for variation caused by change in taxes/ duties as specified in Clause-12.2 mentioned below.

11.1.1.2 For changes in taxes/ duties during the scheduled delivery period, the unit price shall be regulated asunder:

11.1.1.2.1 Prices will be fixed at the time of issue of purchase order as per taxes and statutory duties applicable at that time

11.1.1.3 In case of reduction of taxes and other statutory duties during the scheduled delivery period, purchaser shall take the benefit of decrease in these taxes/

duties for the supplies made from the date of enactment of revised duties/taxes.

11.1.1.4 In case of increase in duties/taxes during the scheduled delivery period, the purchaser shall revise the prices as per new duties/ taxes for the supplies, to be made during the remaining delivery period as per terms and conditions of the purchase order.

11.2 Any increase in taxes and other statutory duties/ levies, after the expiry of the delivery date shall be to the Supplier/Contractor's account. However, benefit of any decrease in these taxes/duties shall be passed on to the Purchaser by the Supplier/Contractor. The total price is to be adjusted (by reducing the basic price) with increased duties and taxes as per price mentioned in PO.

12.0 CHANGES IN PURCHASE ORDERS

12.1 The purchaser may, at any time, by a written order given to a Supplier/Contractor, make changes within the general scope of the contract in any one or more of the following:

12.1.1 drawings, designs or specifications, where Goods to be supplied under the contract are to be specifically manufactured for the Purchaser;

12.1.2 the method of transportation or packing;

12.1.3 the place of delivery; or

12.1.4 the services to be provided by the Supplier/Contractor.

12.2 If any such change causes an increase or decrease in the cost of, or the time required for the execution of the contract an equitable adjustment shall be made in the contract price or delivery schedule, or both, and the contract shall accordingly be amended. Any proposal by the Supplier/Contractor for adjustment under this clause must be made within thirty days from the date of the receipt of the change in order.

13.0 SUBCONTRACTS: DELETED

14.0 DELAYS IN THE SUPPLIER/CONTRACTOR'S PERFORMANCE

14.1 Delivery of the Goods and performance of the services shall be made by the Supplier/Contractor in accordance with the time schedule specified by the purchaser in its purchase order. In case the supply is not completed in the stipulated delivery period, as indicated in the Purchase Order, purchaser reserves the right to short-close/ cancel this purchase order and/ or recover liquidated damage charges. The cancellation/ short-closing of the order shall be at the risk and responsibility of the Supplier/Contractor and purchaser reserves the right to purchase balance unsupplied item at the risk and cost of the defaulting vendors.

14.2 Delay by the Supplier/Contractor in the performance of its delivery obligations shall render the Supplier/Contractor liable to any or all of the following sanctions:

14.2.1 forfeiture of its performance security,

14.2.2 imposition of liquidated damages, and/or

14.2.3 Short closure of the contract in part or full and/ or termination of the contract for default.

- 14.3 If at any time during the performance of the contract, the Supplier/Contractor encounters condition impeding timely delivery of the goods and performance of service, the Supplier/Contractor shall:
- 14.3.1 Promptly notify to the Purchaser in writing the fact of the delay, its likely duration and its cause(s). As soon as practicable after receipt of the Supplier/Contractor's notice, the purchaser shall evaluate the situation and may at its discretion extend the period for performance of the contract (by not more than 20 weeks or as per provisions of clause 16.2 Section-5A as per provision given below:
- 14.3.2 The vendor has to submit their request for extension along with the undertaking as per clause 24 Section-5A (Fall Clause) **at least two weeks before the expiry of delivery period.** The vendor shall also submit un conditional acceptance of the conditions for delivery period extension i.e. applicability of liquidated damages, prices to be provisional and to be regulated as per clauses 12.3 and 24 of section- 5A and submission of additional BG, wherever applicable. The decision regarding extension shall be communicated within two weeks of the receipt of request and after receipt of the unconditional acceptance and the undertaking mentioned above.
- 14.3.3 In case extension is being granted beyond 20 weeks then the vendor shall submit additional BG while seeking extension. For piecemeal items the amount of additional BG shall be 5% of the value of balance quantity of items to be supplied for which extension in delivery period has been sought. In case of infrastructure/turnkey projects other than as stated above, 1% of the total project value shall be the value for additional BG. The additional BG shall be valid for six months beyond extension of delivery period sought and shall be discharged after the full ordered quantity has been supplied to the ultimate consignee within the last extended delivery period on submission of inspection certificate from QA and consignee receipt without prejudice to the other remedies available to the purchaser.
- 14.3.4 If the vendor fails to deliver the full ordered quantity even during extended delivery period then the PO shall be short-closed and the Performance Bank Guarantee as well as additional BG shall be forfeited.
- 14.3.5 Format of (i) letters conveying conditions of DP extension and (ii) DP extension letter are at Section 7 Part A & Part B.
- 14.4 If the supplies are not completed in the extended delivery period, the purchase order shall be short-closed and both the Performance securities shall be forfeited.

15.0 LIQUIDATED DAMAGES

- 15.1 The date of delivery of the stores / date of completion of works stipulated in the acceptance of the tender should be deemed to be the essence of the contract and delivery/completion must be completed not later than the dates specified therein. Extension will not be given except in exceptional circumstances. Should, however, deliveries/completion be made after expiry of the contracted delivery/completion period, without prior concurrence of the purchaser and be accepted by the consignee, such delivery will not deprive the purchaser of its right to recover liquidated damage under clause 16.2 below

16.2 While granting extension of delivery period as per clause 15.3, the liquidated damages shall be levied as follows:

- (a) Should the Supplier/Contractor fails to deliver the store/complete the work or any consignment thereof within the period prescribed and agreed for delivery/completion of work, the purchaser, without prejudice to other remedies available to the purchaser shall be entitled to recover ,as agreed liquidated damages for breach of contract, a sum equivalent to 0.5% of the value of the delayed supply/completion of work and/ or undelivered material/supply / /uncompleted works for each week of delay or part thereof for a period up to 10 (TEN) weeks, and thereafter at the rate of 0.7% of the value of the delayed supply and/ or undelivered material/ supply /uncompleted works for each week of delay or part thereof for another TEN weeks of delay.
- (b) DP extension/EOT beyond 20 weeks would not be generally allowed. The extension beyond 20 weeks may be decided in most exceptional circumstances on case to case basis, by the tender approving authority, stating reasons and justifications for grant of extension of delivery / work completion period beyond 20 weeks.
- (c) In the case of package supply/ turnkey projects when the delayed portion of the supply materially hampers installation and commissioning of the systems, LD charges shall be levied as above on the total value of the concerned package of the Purchase Order.
- (d) Quantum of liquidated damages assessed and levied by the purchaser and decision of the purchaser thereon shall be final and binding on the Supplier/Contractor, further the same shall not be challenged by the Supplier/Contractor either before Arbitration tribunal or before the court. The same shall stand specifically excluded from the purview of the arbitration clause, as such shall not be referable to arbitration. The total value of the liquidated damages as per above sub-clauses shall be limited to a maximum of 12% (Twelve percent) i.e .LD shall be levied up to 20weeks only as per provision at Para(a).

16.3 In cases where the scheduled delivery period is distributed month-wise or is in installments, the liquidated damages shall be imposed for delay in each scheduled month/ installment. Liquidated damages shall be calculated separately for quantities to be supplied in every month/ installment and the corresponding delay. If the Supplier/Contractor supplies full quantity before the expiry of the scheduled delivery period of the last month/ installment but there is delay in month-wise/ installment-wise supply, then also liquidated damages shall be levied on the supplies against the earlier months/ installments that have been delayed. Twenty (20) weeks for the purpose of additional BG and grant of DP extension shall be counted from the last month/installment.

16.4 Deleted

16.0 FORCE MAJEURE

- 16.1 If, at any time, during the continuance of this contract, the performance in whole or in part by either party of any obligation under this contract is prevented or delayed by reasons of any war or hostility, acts of the public enemy, civil commotion, sabotage, fires, floods, explosions, epidemics, quarantine restrictions, strikes, lockouts or act of God (hereinafter referred to as events) provided notice of happenings of any such eventuality is given by either party to the other within 21 days from the date of occurrence thereof, neither party shall by reason of such event be entitled to terminate this contract nor shall either party have any claim for damages against other in respect of such non-performance or delay in performance, and deliveries under the contract shall be resumed as soon as practicable after such an event come to an end or cease to exist, and the decision of the Purchaser as to whether the deliveries have been so resumed or not shall be final and conclusive. Further that if the performance in whole or part of any obligation under this contract is prevented or delayed by reasons of any such event for a period exceeding 60 days, either party may, at its option, terminate the contract.
- 16.2 Provided, also that if the contract is terminated under this clause, the Purchaser shall be at liberty to take over from the Supplier/Contractor at a price to be fixed by the purchaser, which shall be final, all unused, undamaged and acceptable materials, bought out components and stores in course of manufacture which may be in possession of the Supplier/Contractor at the time of such termination or such portion thereof as the purchaser may deem fit, except such materials, bought out components and stores as the Supplier/Contractor may with the concurrence of the purchaser elect to retain.

17.0 ACTION BY PURCHASER AGAINST BIDDER(S)/VENDOR(S) IN CASE OF DEFAULT.

- 17.1 In case of default by Bidder(s)/ Vendor(s) such as
- 17.1.1 Failure to deliver and/ or commission any or all of the goods /completion of works within the time period(s) specified in the contract, or any extension thereof granted by the purchaser pursuant to clause 15 of this section;
 - 17.1.2 Failure to perform any other obligation(s) under the Contract; and
 - 17.1.3 Equipment does not perform satisfactorily in the field in accordance with the specifications;
 - 17.1.4 Or any other default whose complete list is enclosed in Appendix-1 of Section-4, Part-A: Purchaser will take action as specified in Appendix-1 of Section-4, Part-A.

18.0 Clause deleted.

19.0 ARBITRATION (Applicable in case of supply orders/Contracts with firms, other than Public Sector Enterprise) (Not applicable in cases valuing less than Rs. 5 lakhs)

Except as otherwise provided elsewhere in the contract, if any dispute, difference, question or disagreement arises between the parties hereto or their respective representatives or assignees, in connection with construction, meaning, operation, effect, interpretation of the contract or breach thereof which parties unable to settle mutually, the same shall be referred to Arbitration as provided hereunder:

- (1) A party wishing to commence arbitration proceeding shall invoke Arbitration Clause by giving 60 days' notice to the designated officer of the other party. The notice invoking arbitration shall specify all the points of disputes with details of the amount claimed to be referred to arbitration at the time of invocation of arbitration and not thereafter. If the claim is in foreign currency, the claimant shall indicate its value in Indian Rupee for the purpose of constitution of the arbitral tribunal.

- (2) The number of the arbitrators and the appointing authority will be as under:

| Claim amount (excluding claim for counter claim, if any) | Number of arbitrator | Appointing Authority |
|---|--|---|
| Above Rs. 5 lakhs to Rs. 5 crores | Sole Arbitrator to be appointed from a panel of arbitrators of BSNL. | BSNL (Note: BSNL will forward a list containing names of three empanelled arbitrators to the other party for selecting one from the list who will be appointed as sole arbitrator by BSNL) |
| Above Rs. 5 crores | 3 Arbitrators | One arbitrator by each party and the 3 rd arbitrator, who shall be the presiding arbitrator, by the two arbitrators. BSNL will appoint its arbitrator from its panel. |

- (3) Neither party shall appoint its serving employee as arbitrator.
- (4) If any of the Arbitrators so appointed dies, resigns, becomes incapacitated or withdraws for any reason from the proceedings, it shall be lawful for the concerned party/arbitrators to appoint another person in his place in the same manner as aforesaid. Such person shall proceed with the reference from the stage where his predecessor had left it both parties consent for the same; otherwise, he shall proceed denovo.
- (5) Parties agree that neither party shall be entitled for any pre-reference or pendent-lite interest on its claims. Parties agree that any claim for such interest made by any party shall be void.
- (6) Unless otherwise decided by the parties, Fast Track procedure as prescribed in Section 29 B of the Arbitration Conciliation Act, 1996 for resolution of all disputes shall be followed, where the claim amount is up to Rs. 5 crores.

[29B. Fast track procedure – (1) Notwithstanding anything contained in this Act, the parties to an arbitration agreement, may, at any stage either before or at the time of appointment of the arbitral tribunal, agree in writing to have their dispute resolved by fast track procedure specified in sub-section(3).

- (7) The parties to the arbitration agreement, while agreeing for resolution of dispute by fast track procedure, may agree that the arbitral tribunal shall consist of a sole arbitrator who shall be chosen by the parties.
- (8) The arbitral tribunal shall follow the following procedure while conducting arbitration proceedings under sub-section(1):-
- (a) The arbitral tribunal shall decide the dispute on the basis of written pleadings, documents and submissions filed by the parties without oral hearing;
- (b) The arbitral tribunal shall have power to call for any further information or clarification from the parties in addition to the pleadings and documents filed by them;
- (c) An oral hearing may be held only, if, all the parties make a request or if the arbitral tribunal considers it necessary to have oral hearing for clarifying certain issues;
- (d) The arbitral tribunal may dispense with any technical formalities, if an oral hearing is held, and adopt such procedure as deemed appropriate for expeditious disposal of the case.
- (9) The award under this section shall be made within a period of six months from the date the arbitral tribunal enters upon the reference.
- (10) If the award is not made within the period specified in sub-section (4), the provisions of sub- sections (3) to (9) of Section 29 A shall apply to the proceedings.
- (11) The fees payable to the arbitrator and the manner of payment of the fees shall be such as may be agreed between the arbitrator and the parties.]
- (12) The arbitral tribunal shall make and publish the award within time stipulated as under:

| | |
|-------------------------------------|---|
| Amount of Claims and Counter Claims | Period for making and publishing of the award (counted from the date the arbitral tribunal enters upon the reference) |
| Up to Rs. 5 crores | Within 6 months (Fast Track procedure) |
| Above Rs. 5 crores | Within 12 months |

However, the above time limit can be extended by the Arbitrator for reasons to be recorded in writing with the consent of parties and in terms of provisions of the Act.

- (13) In case of arbitral tribunal of 3 arbitrators, each party shall be responsible to make arrangements for the travel and stay, etc. of the arbitrator appointed by it. Claimant shall also be responsible for making arrangements for travel/stay arrangements for the Presiding Arbitrator and the expenses incurred shall be shared equally by the parties.

In case of sole arbitrator, BSNL shall make all necessary arrangements for his travel/stay and the expenses incurred shall be shared equally by the parties.

- (14) The Arbitration proceeding shall be held at New Delhi or Circle or SSA Headquarter (as the case maybe).

- (15) Subject to the aforesaid conditions, provisions of the Arbitration and Conciliation Act, 1996 and any statutory modifications or re-enactment thereof shall apply to the arbitration proceedings under this clause.

- II. Following Arbitration Clause may be incorporated in Contracts POs, APOs, Tenders, EOIs, etc. between BSNL and Central/State Government (s) as the case may be in terms of DPE guidelines for settlement of commercial disputes between Public Sector Enterprises inter-se and Public Sector Enterprise(s) and Government Department(s) through Permanent Machinery of Arbitrators (PMA) in the Department of Public Enterprises.

In the event of any dispute or difference relating to the interpretation and application of the provisions of the contracts, such dispute or difference shall be referred by either party for Arbitration to the sole Arbitrator in the Department of Public Enterprises to be nominated by the Secretary to the Government of India in-charge of the Department of Public Enterprises. The Arbitration and Conciliation Act, 1996 shall not be applicable to arbitration under this clause. The award of the Arbitrator shall be binding upon the parties to the dispute, provided, however, any party aggrieved by such award may make a further reference for setting aside or revision of the award to the Law Secretary, Department of Legal Affairs, Ministry of Law & Justice, Government of India. Upon such reference the dispute shall be decided by the Law Secretary or the Special Secretary/Additional Secretary, when so authorized by the Law Secretary, whose decision shall bind the Parties finally and conclusively. The Parties to the dispute will share equally the cost of arbitration as intimated by the Arbitrator.

Further, with regard to already signed/existing contracts, existing Arbitration clause for sole arbitrator can be invoked in case the parties waive, subsequent to disputes having arisen between them, the applicability of sub-section (5) of section 12 by an express agreement in writing.

III. APPLICABLE LAW AND JURSDICTION

- (a) The supply order for Goods 'or' Services, including all matters connected with this supply order shall be governed by the Indian law both substantive and procedural, for the time being in force and shall be subject to the exclusive jurisdiction of Indian Courts at the place from where the Purchase Order has been placed.
- (b) Foreign companies, operating in India or entering into Joint Ventures in India, shall have to obey the law of land and there shall be no compromise or excuse for the ignorance of the Indian legal system in anyway.

© The venue of arbitration shall be BSNL CO New Delhi and/or Circle/SSA HQ or the office of the Arbitrator situated at New Delhi or at the respective Territorial Circle/SSA HQ as the case may be.

21. SET OFF

Any sum of money due and payable to the Supplier/Contractor (including security deposit refundable to him) under this contract may be appropriated by the purchaser or the BSNL or any other person(s) contracting through the BSNL and setoff the same against any claim of the Purchaser or BSNL or such other person or person(s) for payment of a sum of money arising out of this contract or under any other contract made by the Supplier/Contractor with the Purchaser or BSNL or such other person(s) contracting through the BSNL.

22. INTIMATION OF SUPPLY STATUS

The bidders, who are given Purchase Orders, must give the details of the supplies made against all the Purchase Orders regularly to the concerned officers of BSNL.

23. DETAILS OF THE PRODUCT

The bidder should furnish the name of its collaborator (if applicable), brand name, model number and type of the products offered in this tender. The technical literatures of the products should also be submitted. No change in either technology or product shall be permitted after opening of bids.

24. FALL CLAUSE

24.1 The prices once fixed will remain valid during the scheduled delivery period except for the provisions in clause 12.1 of Section-5A. Further, if at any time during the contract

(a) It comes to the notice of purchaser regarding reduction of price for the same or similar equipment/service;

And / or

(b) The prices received in a new tender for the same or similar equipment/service are less than the prices chargeable under the contract.

24.2 The purchaser, for the purpose of delivery period extension, if any, will determine and intimate the new price, taking into account various related aspects such as quantity, geographical location etc., and the date of its effect for the balance quantity/ service to the vendor. In case the vendor does not accept the new price to be made applicable during the extended delivery period and the date of its effect, the purchaser shall have the right to terminate the contract without accepting any further supplies. This termination of the contract shall be at the risk and responsibility of the Supplier/Contractor and the purchaser reserves the right to purchase the balance unsupplied quantity/ service at the risk and cost of the defaulting vendor besides considering the forfeiture of its performance security.

- 24.3 The vendor while applying for extension of time for delivery of equipment/services, if any, shall have to provide an undertaking as "We have not reduced the sale price, and/ or offered to sell the same or similar equipment/ service to any person/ organization including Department of central/state Government or any central/ state PSU at a price lower than the price chargeable under the contract for scheduled delivery period."
- 24.4 In case under taking as in Clause 24.3 is not applicable, the vendor will give the details of prices, the name(s) of purchaser, quantity etc. to the purchaser, while applying extension of delivery period.

25. COURT JURISDICTION

- 25.1 Any dispute arising out of the tender/ bid document/ evaluation of bids/ issue of APO shall be subject to the jurisdiction of the competent court at the place from where the NIT/ tender has been issued.
- 25.2 Where a contractor has not agreed to arbitration, the dispute/ claims arising out of the Contract/ PO entered with him shall be subject to the jurisdiction of the competent Court at the place from where Contract/ PO has been issued. Accordingly, a stipulation shall be made in the contract asunder.
"This Contract/ PO is subject to jurisdiction of Court at Bhubaneswar only".

26. General Guidelines:-

"The General guidelines as contained in Chapter 5, 6 and 8 of General Financial Rules as amended from time to time on works, procurement of goods and services and contract management respectively may also be referred to as guiding principles".

SECTION – 5 Part B

SPECIAL (COMMERCIAL) CONDITIONS OF CONTRACT (SCC)

Provisions in the Special Commercial Conditions of Contract (SCC) (SECTION-5 Part B) shall supersede the corresponding provisions in the General Commercial Conditions of Contract (GCC) (SECTION-5 Part A) in case of conflict.

The firm shall read carefully the following conditions and shall quote accordingly confirming all the points in their offer. Modification in tender conditions will not be permitted at any stage of tender/agreement formation/execution of work.

1. **Definitions** : The 'Contract' means the documents forming the tender and acceptance thereof and the formal agreement executed between the competent authority on behalf of BSNL and the contractor, together with the documents referred to therein including these conditions, the specifications, designs, drawings and instructions issued from time to time by the Engineer-in-Charge and all these documents taken together, shall be deemed to form one contract and shall be complementary to one another.
2. In the contract the following expressions shall, unless the context otherwise requires, have the meanings, hereby respectively assigned to them :-
 - i) The expression "works" or "work" shall, unless there be something either in the subject or context repugnant to such construction, be construed and taken to mean the works by or by virtue of the contract contracted to be executed whether temporary or permanent, and whether original, altered, substituted or additional.
 - ii) The 'site' shall mean the land/building/or other places on, into or through which work is to be executed under the contract or any alternate land, building, path or street which may be allotted or used for the purpose of carrying out the contract.
 - iii) The 'Contractor' shall mean the individual, firm or company, whether incorporated or not, undertaking the works and shall include the legal personal representative of such individual or the persons composing such firm or company, or the successors of such firm or company and the permitted assignees of such individual, firm or company.
 - iv) BSNL means the Bharat Sanchar Nigam Ltd. having its corporate office at Harish Chandra Mathur Lane, Janpath, New Delhi-110001 and its successors.
 - v) The 'Engineer-in-charge' means the Engineer officer who shall supervise and be in-charge of the work and who shall sign the contract on behalf of BSNL.
 - vi) Accepting Authority shall mean the authority who accepts the tender on behalf of BSNL.
 - ix) Tendered value means the value of the entire work as stipulated in the letter of award.

3. Scope and Performance : Where the context so requires, words imparting the singular only also include the plural and vice versa. Any reference to masculine gender shall whenever required include feminine gender and vice versa.
4. The contractor shall be furnished, free of cost, one certified copy of the contract documents except standard specifications, schedule of rates and such other printed and published documents, together with all drawings as may be forming part of the tender papers. None of these documents shall be used for any purpose other than that of this contract.
5. Works to be carried out : The work to be carried out under the Contract shall, except as otherwise provided in these conditions, include all labour, materials, tools, plants, equipment and transport which may be required in preparation of and for and in the full and entire execution and completion of the works. The descriptions given in the schedule of quantities shall, unless otherwise stated, be held to include wastage on materials, carriage and cartage, carrying and return of empties, hoisting, setting, fitting and fixing in position and all other labours necessary in and for the full and entire execution and completion of the work as aforesaid in accordance with good practice and recognised principles.
6. Sufficiency of Tender : The contractor shall be deemed to have satisfied himself before tendering as to the correctness and sufficiency of his tender for the works and of the rates and prices quoted in the Schedule of Quantities, which rates and prices shall, except as otherwise provided, cover all his obligations under the contract and all matters and things necessary for the proper completion and maintenance of the works.
7. Discrepancies & adjustments of Error : The several documents forming the contract are to be taken as mutually explanatory of one another, detailed drawings being followed in preference to small scale drawing and figured dimensions in preference to scale and special conditions in preference to General Conditions.
 - 7.1 In the case of discrepancy between the schedule of quantities/requirements, the specifications and/or the drawings, the following order of preference shall be observed :-
 - i) Description of Schedule of Quantities/Requirements.
 - ii) Particular Specification and Special condition, if any
 - iii) Drawings
 - iv) BSNL Specifications
 - v) C.P.W.D. Specifications
 - vi) Indian Standard Specifications of B.I.S
 - 7.2 If there are varying or conflicting provisions made in any one document forming part of the contract, the Accepting Authority shall be the deciding authority with regard to the intention of the document and his decision shall be final and binding on the contractor.

7.3 Any error in description, quantity or rate in Schedule of Quantities or any omission there from shall not vitiate the Contract or release the contractor from the execution of the whole or any part of the works comprised therein according to drawings and specifications or from any of his obligations under the contract.

8.0 SIGNING OF CONTRACT:

8.1 The successful tenderer /contractor, on acceptance of his tender by the Accepting Authority, shall, within 07 days from the date of formal award of work by the Engineer in Charge, sign the contract consisting of the notice inviting tender, all the documents including drawings, if any, forming the tender as issued at the time of invitation of tender and acceptance thereof together with any correspondence leading thereto.

8.2 The agreement to be signed on non-judicial stamp paper and the cost to be decided as per the prevailing local bye-laws or zonal head of the circle.

9.0 This Contract/ PO is subject to jurisdiction of Court at Bhubaneswar only.

10.0 BID BOND GAURANTEE OR EARNEST MONEY DEPOSIT (EMD)

10.1 Purpose

The Bid Bond Guarantee also known as Earnest Money Deposit (EMD) or Earnest Money Bank Guarantee (EMBG).The purpose of EMD is to get a commitment by the Bidder to honour its bid during the bid validity period.

10.2 Value

The value of EMD will be @2% of the total estimated cost of the equipment/ stores including services proposed to be procured in the tender subject to a maximum of Rupees Two Crore.

10.3 Validity Period

The validity period of the EM BG should be 30days beyond the Bid validity i.e. n+30 days, where 'n' is number of days invalidity period of offer e.g.90+30 = 120 days, if the bid validity period is 90 days.

10.4 Extension of Validity Period

In case, where BSNL finds that it is not able to place Advance Purchase Order within the validity period of the bid, BSNL can request all bidders to extend the validity of their respective bids and the EMBGs by a reasonable period. In such cases, extension of validity of Bid Security Bond by 30 days beyond the extended validity date of bids should also be asked for. While BSNL can make the request for extension, the bidder is free to either extend the validity or refuse the request to extend the Validity.

10.5 Release of EMD

10.5.1 EMD of all unsuccessful Bidders should be released on placement of Purchase Order (PO) on the successful bidders. This should be done within one month of release of Purchase Order(s).

10.5.2 In case of successful Bidders, the EM BG shall be released on receipt of their acceptance of Advance Purchase Order and furnishing the performance security.

10.5.3 Where BSNL requests the Bidder to extend the validity of the Bid beyond the stipulated period given in the Bid documents, and the bidder refuses to extend the validity of its bid, the EMD of such Bidders shall be returned within one month of receipt of such communication. In such cases, the bidder shall not be considered for further evaluation or ordering.

10.6 Encashment of EMD

10.6.1 EMD of a bidder shall be forfeited, if the bidder withdraws or amends its bid or impairs or derogates from the bid in any respect during the period of bid validity specified by the bidder on the Bid Form or extended subsequently.

10.6.2 When BSNL places an Advance Purchase Order / purchase order on the successful bidder on its quoted price and the bidder refuses to accept it within the scheduled period as stated in APO, EMD shall be forfeited.

10.6.3 The decision of BSNL in this regard will be final & binding.

10.7 Acceptable forms of EMD

The EMD should be in the form of a Bank Guarantee drawn from a scheduled bank in favour of BSNL. EMD in the form of Account Payee Demand Draft, Fixed Deposit Receipt or Banker's Cheque, safeguarding BSNL's interest in all respects, shall also be acceptable. However, no interest shall be payable on EMD received in form of DD/banker's cheque.

11.0 PERFORMANCE GUARANTEE:

11.1 The contractor is required to furnish performance guarantee to an amount equal to 5% of the contract value in the form of Bank guarantee (of a Nationalized / scheduled Bank in a standard format)/CDR/FDR/DD within two weeks from the date of issue of award letter. The validity period of the performance security shall be **12 months** from the date of actual completion of works.

11.2 In case the time for contract period gets enlarged ,the contractor shall get the validity of Performance Guarantee extended to cover such enlarged time to cover up the contract period.

11.3 For repairing, maintenance and emergency nature works where time of completion is less than 02 weeks, a sum @ 10% of the gross amount of the bill shall be deducted as Security Deposit from the bill of the contractor in the absence of performance Guarantee

11.4 In the event of the contract being determined or rescinded under provision of any of the Clause/Condition of the agreement, the Performance guarantee shall stand forfeited in full and shall be at the disposal of the BSNL.

12. SECURITY DEPOSIT:

- (j) In addition to performance Guarantee, a sum @ 10% of the gross amount of the bill shall be deducted from each running bill of the contractor till the sum will amount to security deposit of 10% (i/c 5% PG) of the tendered value of the work or value of work done whichever is more.

- (i) Additional performance Guarantee @ 5% of the gross amount of the bill can be deposited by the contractor in lieu of the above Security Deposit.

8.0 RELEASE OF SECURITY DEPOSIT & PERFORMANCE GURANTEE:

This Security Deposit/Performance Guarantee shall be released after an observation period of 12 months after the date of actual completion of work subject to compliance of the clauses, terms and conditions of the contract including warranty and defect liability.

9.0 DATE OF COMPLETION

Date of Successful Installation, Testing and commissioning shall be taken as completion date of the work.

10.0 HANDING OVER:

After satisfactory supplies of the goods/materials/equipments or completion of the work, the goods/materials/equipments/installations are to be handed over to the user department/section/authority in good working conditions, as per the direction of Engineer in charge. Any defects/discrepancies noticed during handing over and taking over process will be rectified by the supplier/contractor at his risk and cost within 15 days from the date of preparation of handing over notes. In case of failure, the same will be rectified by BSNL at the risk and cost of the concerned supplier/contractor and amount will be recovered from the outstanding dues of the supplier/contractor with BSNL.

11.0 PAYMENT SYSTEMS :

- 12.1 Payment will be made after successful completion of the work as per terms, conditions and Technical specifications of the Contract.
- 12.2 However, upon receiving the request of the supplier / Contractor, interim payment on account of amount admissible shall be made by the Engineer-in-charge certifying the sum to which the supplier / contractor is considered entitled by way of interim payment at such rates as decided by the Engineer-in-charge . The contractor shall not be entitled to be paid any interim payment if the gross work done since the last payment is less than Rupees Twenty thousand.
- 12.3 The final bill shall be submitted by the supplier / contractor within three months of physical completion of the work or within one month of the date of the final completion Certificate furnished by the Engineer-in-charge whichever is earlier. No further claims shall be made by the contractor after submission of the final bill and these shall be deemed to have been waived and extinguished. Payment of those items of the bill in respect of which there is no dispute and of items in dispute, for quantities and rates as approved by Engineer-in-charge, will, as far as possible be made **Soon after allotment of funds by BSNL Corporate office OR Directly payment to the Supplier/Contractor by the client department as per the MOU.**

12.4 No payments will be made for defective/rejected materials and substandard works.

12.5 Payment of GST to Govt. within the stipulated time and filing of GST return will be the sole responsibility of the supplier/vendor.

12.6 DOCUMENTS TO BE SUBMITTED BY THE FIRM FOR PROCESSING THEIR BILLS

The Supplier /Contractor has to submit the following documents for processing their bills:

- i) Tax Invoice indicating proper HSN/SAC code of material supplied/works executed.
- ii) Delivery challan / Goods receipt /work completion certificate.
- iii) Computerised measurement books in triplicate.
- iv) Warranty documents of materials/goods and technical leaflets/manuals etc.
- v) Test Certificates Control panels.
- vi) Completion plan and layout

13. TAX DEDUCTED AT SOURCE:

BSNL shall deduct income tax/TDS, labour welfare cess and other statutory deductions from payments due to the supplier / contractor as per the prevailing rules of the State/Central Government.

14. CURRENCY OF CONTRACT

The currency of contract shall be as given in the detailed NIT. However, if deliveries of goods/completion of works are to be made after expiry of the stipulated time period, without prior concurrence of the purchaser and will be accepted by the purchaser, such delivery/completion of work will not deprive the purchaser of its right to recover liquidated damage under clause 16.2 of Sec. 5, Part.A.

15. OPERATION OF THE CONTRACT

An award letter will be issued by Executive Engineer (E) along with schedule of work and agreement shall be framed by EE (E) concerned. The agreement so executed containing all the terms and conditions of tender shall be final & binding on both the parties and any action, if required, to be taken shall be taken as per this contract.

16. TERMINATION OF CONTRACT

Right is reserved by BSNL for terminating the contract due to serious default. This includes abnormal delay in completion of the works, major break down or accident or loss due to negligence on the part of firm, disobedience and abandoning the site etc. In such a case full 10% of the performance Guarantee shall be forfeited by BSNL in addition to recovery of other penalty amount from the bills of the contractor as imposed under the other clauses of the contract. The decision of BSNL in this regard shall be final and binding.

17. CURTAILMENT OF QUANTITIES:

BSNL reserves the right to enforce curtailment in the assigned quantum of work for any supplier / contractor on the grounds of defaults/delay in regard to execution of the individual work assigned as well as on the ground of non availability of sites during the currency of contract.

18. DEFECT LIABILITY & GUARANTEE:

The Contractor has to give guarantee of the repaired work if any defect or failure, which arise due to faulty materials, workmanship or design within the defect liability period. The defect liability period shall be 12 months from the date of commissioning of the system. If during this period any repaired transformers are found defective, these shall be promptly replaced or rectified by the Contractor at his own cost including to and from transportation cost.

19. E-WAY BILL:

It shall be the responsibility of Supplier / Contractor to obtain e-way bill in case of movement of goods exceeding limit as prescribed under the GST Act. The Supplier / Contractor would indemnify BSNL in case of any non-compliance or default or due to lack of diligence on the part of the Supplier / Contractor to comply with the e-waybill requirement. **NO CONCESSIONAL FORMS WILL BE ISSUED BY BSNL.**

20. COMPUTERISED MEASUREMENT BOOKS (CMB'S) AND BILLS TO BE SUBMITTED BY THE CONTRACTOR / FIRM

20.1 **Application and format of the computerised MB:** A bound volume of computerised measurements to be furnished by the contractor, duly machine numbered for the pages, and with an MB number given by the Division Office. The pages of these Measurement Books shall be of A-4 size. All these Measurement Books belonging to a Division shall be serially numbered, and a record of these Computerised Measurement Books shall be maintained in a separate Register in Form CPWA 92. The same format as in existing Measurement Books shall be used for the Computerised Measurement Books. The measurements shall be carried forward from the previous recorded measurements as per the existing procedure.

20.2 **Mode Of Measurements:** The measurements shall be recorded and entered in computerised format in the first instance by the contractor, and a hard copy shall be submitted to the Department. These measurements shall then be 100% checked by JTO (E). If JTO (E) is not available, S D E (E) shall perform 100% check of the measurements. The contractor shall incorporate all such changes or corrections, as may be done during these checks, to his draft computerised measurements, and submit to the department the corrected computerized measurements in the form of a book, duly hard bound in red colour on the lines of the conventional Measurement Books and with its pages machine numbered. The SDE (E) and the Executive Engineer (E) shall test check these computerised measurements as per the existing instructions. This book shall be treated as a Computerised Measurement Book. JTO (E), SDE (E) and EE (E) shall record the necessary certificates for their checks and test checks as per the

existing procedure in this Computerised Measurement Book. The Computerised Measurement Book shall be allotted a serial number as per the Register of Computerised Measurement Books.

- 20.3 **Cutting or over-writing in the computerised MB not allowed:** The Computerized Measurement Book given by the contractor, duly bound, with its pages machine numbered, shall have no cutting or over-writing. It is the responsibility of JTO (E) or SDE (E) as the case may be to ensure that the checks and test checks done by them in the initial draft measurements are correctly incorporated in the Computerized Measurement Book before they record their certificates. In case of any error, the Computerised Measurement Book shall be cancelled, and the contractor shall re-submit a fresh Computerized Measurement Book. This should be done before the corresponding computerised bill is submitted to the Division for payment. The contractor shall submit Computerised Measurement Books in triplicate for the purpose of reference and record in the various offices of the department.
- 20.4 **Computerised Bill to be submitted by the contractor:** The contractor shall submit his running and final bills in a computerised form in the same format as the existing conventional bills, with all the pages machine numbered, and hard bound, and with all the entries made as per the existing procedure. The contractor shall submit the computerized bills in triplicate as may be required for the purpose of reference and record in the various offices of the department. The bill shall be carried forward from the previous running account bill and these computerised bills shall be processed by the various offices for payment.

SECTION-6

UNDERTAKING & DECLARATION

6(A) - For understanding the terms & condition of Tender & Spec. of work

a) Certified that:

1. I/ We have read, understood and agree with all the terms and conditions, specifications included in the tender documents & offer to execute the work at the rates quoted by us in the tender form.
2. If I/ We fail to enter into the agreement & commence the work in time, the EMD/SD deposited by us will stand forfeited to the BSNL.

b) The tenderer hereby covenants and declares that:

1. All the information, Documents, Photo copies of the Documents/ Certificates enclosed along with the Tender offer are correct.
2. If anything is found false and/or incorrect and/or reveals any suppression of fact at any time, BSNL reserves the right to debar our tender offer/ cancel the LOA/ Purchase/ work order if issued and forfeit the EMD/ SD/ Bill amount pending with BSNL. In addition, BSNL may debar the contractor from participation in its future tenders.

Date:

Signature of Tenderer

Place:.....

Name of Tenderer:.....

Along with date & Seal

6 (B) – UNDERTAKING - REGARDING EPF & ESI

"I,.....Son of.....

.....Resident of

hereby give an undertaking that,

* I/ We have registered as per the EPF and ESI and Miscellaneous provisions Act, 1952 and our registration no is _____ . We undertake to keep it valid during the currency of contract.

Any consequence arising due to non-complying of EPF & ESI Act provision shall be sole liability of the undersigned contractor. In case at any stage, it is found that the information given by me is false / incorrect, BSNL shall have the absolute right to take any action as deemed fit/without any prior intimation to me".

* Strike out whichever is not applicable

(Seal of the firm) (Dated Signature of Contractor)

6 (C) – NEAR-RELATIONSHIP CERTIFICATE

(Format of the Certificate to be given as per the clause 34.4 of Section-4 Part-A by the bidder in respect of status of employment of his/ her near relation in BSNL)

The format of the certificate to be given is "I----- s/o-----
-----r/o.-----

-----hereby certify that none of my relative(s)as defined in the tender document is/are employed in BSNL unit as per details given in tender document. In case at any stage, it is found that the information given by me is false/ incorrect, BSNL shall have the absolute right to take any action as deemed fit/without any prior intimation tome."

Signature of the tenderer
With date and seal

SECTION- 7

PROFORMAS

**7(A) For the BIDSECURITY/EMD Guarantee
(To be typed on Rs.100/- non-judicial stamp paper)**

Sub: Bid Security/EMD guarantee.

Whereas M/s.....R/o..... (Here after referred to as Bidder) has approached us for giving Bank Guarantee of Rs...../- (hereafter known as the "B. G. Amount") valid up to/...../ 20.... (hereafter known as the "Validity date") in favour of **AO Cash, BSNL, O/o GMTD, Bhubaneswar** for participation in the tender of work of

.....Vide tender no.....

Now at the request of the Bidder, We Bank
..... Branch having

(Address) and Regd. Office address as
(Hereinafter called 'the Bank') agrees to give this guarantee as hereinafter contained:

2. We the Bank do hereby undertake to pay the amounts due and payable under this guarantee without any demur, merely on a demand from the BSNL stating that the amount claimed is due by way of loss or damage caused to or would be caused to or suffered by the BSNL by reason of breach by the said bidder(s) of any of terms or conditions contained in the said Agreement or by reason of the bidder (s) failure to perform the said Agreement. Any such demand made on the bank shall be conclusive as regards the amount due and payable by the Bank under this guarantee where the decision of the BSNL in these counts shall be final and binding on the bank. However, our liability under this guarantee shall be restricted to an amount not exceeding the "B. G. Amount".
3. We undertake to pay to the BSNL any money so demanded notwithstanding any dispute or disputes raised by the bidder(s) in any suit or proceeding before any court or tribunal relating thereto our liability under this present being absolute and unequivocal. The Payment so made by us under this bond shall be valid discharge of our liability for payment there under and the bidder(s) shall have no claim against us for making such payment.
4. We the Bank further agree that the guarantee here in contained shall remain in full force and effect during the period that would be taken for the performance of the said agreement and that it shall continue to be enforceable till all the dues of the BSNL under or by virtue of the said Agreement have been fully paid and its claims satisfied or discharged or till BSNL Certifies that the terms and conditions of the said Agreement have

been fully and properly carried out by the said bidder(s) and accordingly discharge this guarantee. Unless a demand or claim under this guarantee is made on us in writing or before the expiry of Validity date from the date hereof, we shall be discharged from all liability under this guarantee thereafter.

5. We the Bank further agree with the BSNL that the BSNL shall have the fullest liberty without our consent and without affecting in any manner our obligations here under to vary any of the terms and conditions of the said Agreement or to extend time of performance by the said bidder(s) from time to time or to postpone for any time or from time to time any of the powers exercisable by the BSNL against the said bidder(s) and to forbear or enforce any of the terms and conditions relating to the said agreement and we shall not be relieved from our liability by reason of any such variation, or extension being granted to the said Bidder(s) or for any forbearance, act or omission on the part of the BSNL or any indulgence by the BSNL to the said bidder(s) or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.
6. Notwithstanding anything herein contained;
 - (a) The liability of the Bank under this guarantee is restricted to the "B. G. Amount" and it will remain in force up to its Validity date specified above.
 - (b) The guarantee shall stand completely discharged and all rights of the BSNL under this Guarantee shall be extinguished if no claim or demand is made on us in writing on or before its validity date.
7. In case BSNL demands for any money under this bank guarantee, the same shall be paid through banker's Cheque in favour of **AO Cash, BSNL, O/o GMTD, Bhubaneswar**
8. The Bank guarantees that the below mentioned officer who have signed it on behalf of the Bank have authority to give this guarantee under its delegated power.

Place:

Date:

(Signature of the Bank Officer)

Rubber stamp of the bank:

Authorized Power of Attorney Number:

Name of the Bank officer:

Designation:

Complete Postal address of Bank:.....

Telephone Numbers

Fax numbers.....

7(B) For the Performance Guarantee
(To be typed on Rs.100/- Non-judicial stamp paper)

Dated:.....

Sub: Performance guarantee.

Whereas Executive Engineer (Elect.) R/o(here after referred to as has issued an APO no. Dated:...../...../20... awarding the work of

.....
.....
to M/s.....R/o.....(here after referred to as "Bidder") and has asked him to submit a performance guarantee in favour of **AO Cash, BSNL, O/o GMTD, Bhubaneswar** of Rs./- (hereafter referred to as "P.G. Amount") valid up to/...../20.....(hereafter referred to as "Validity Date")

Now at the request of the Bidder, We..... Bank Branch having (Address) and Regd. Office address as
(Hereinafter called 'the Bank") agreed to give this guarantee as hereinafter contained:

2. We, "the Bank" do hereby undertake and assure to the BSNL that if in the opinion of the BSNL, the Bidder has in any way failed to observe or perform the terms and conditions of the said agreement or has committed any breach of its obligations there-under, the Bank shall on demand and without any objection or demur pay to the BSNL the said sum limited to P.G. Amount or such lesser amount as BSNL may demand without requiring BSNL to have recourse to any legal remedy that may be available to it to compel the Bank to pay the same.
3. Any such demand from the BSNL shall be conclusive as regards the liability of Bidder to pay to BSNL or as regards the amount payable by the Bank under this guarantee. The Bank shall not be entitled to withhold payment on the ground that the Bidder had disputed its liability to pay or has disputed the quantum of the amount or that any arbitration proceeding or legal proceeding is pending between Bidder and BSNL regarding the claim.
4. We, the Bank further agree that the guarantee shall come into force from the date of its issue and shall remain in full force and effect up to its Validity date.
5. The Bank further agrees that the BSNL shall have the fullest liberty without the consent of the Bank and without affecting in any way the obligations hereunder to vary any of the terms and conditions of the said agreement or to extend the time for performance of the said agreement from any of the powers exercisable by BSNL against the Bidder and to forebear to enforce any of the terms and conditions relating to the

said agreement and the Bank shall not be relieved from its liability by reason of such failure or extension being granted to Bidder or through any forbearance, act or omission on the part of BSNL or any indulgence by BSNL to Bidder or any other matter or thing whatsoever which under the law relating to sureties would but for this provision have the effect of relieving or discharging the guarantor.

6. Notwithstanding anything herein contained;
 - (a) The liability of the Bank under this guarantee is restricted to the P.G. Amount and it will remain in force up to its Validity date.
 - (b) The guarantee shall stand completely discharged and all rights of the BSNL under this Guarantee shall be extinguished if no claim or demand is made on us in writing on or before its validity date.
7. In case demands for any money under this bank guarantee, the same shall be paid through banker's Cheque in favour of " **AO Cash, BSNL, O/o GMTD, Bhubaneswar** " payable at **Bhubaneswar**.
8. The Bank guarantees that the below mentioned officer who have signed it on behalf of the Bank have authority to give this guarantee under its delegated power.

Place:

Date:.....

(Signature of the Bank Officer)

Rubber stamp of the bank

Authorized Power of Attorney Number:

Name of the Bank officer:

Designation:

Complete Postal address of Bank:.....

.....

Telephone Numbers

Fax numbers.....

7 (C) For Letter of Authorization for attending Bid Opening Event.

(To be typed preferably on letter head of the company)

Subject: Authorization for attending Bid opening

I/ We Mr. /Ms. have submitted our bid for the tender no
..... in respect of
..... (Item of work) which is due to open
on (Date) in the Meeting Room, O/o
.....

We hereby authorize Mr./Ms.& Mr./Ms..... (Alternative) whose
signatures are attested below, to attend the bid opening for the tender mentioned above on our
behalf.

.....
Signature of the Representative Signature of Bidder/ Officer authorized to sign
on behalf of the Bidder

.....
Name of the Representative

.....
Signature of the alternative Representative

.....
Name of the alternative Representative

Above Signatures Attested

-
- Note 1: Only one representative will be permitted to attend the Bid opening
2. Permission for entry to the hall where bids are opened may be refused in case
authorization as prescribed above is not received.

7(D) Model Amendment Letter Intimating Conditions for Extension of Delivery Period

(Refer to Appendix (i) to clause 15.3 of Section-5 PartA)

Registered Ack Due

To

M/s

.....

Address of BSNL

.....

Sub: This office contract no..... dated placed on you for supply of.....

Ref :Your letter no..... dated

We are in receipt of your letter, wherein you have asked for extension/ further extension of time for delivery/ execution/ installation/commissioning.

In view of the circumstances stated in your above referred letter, the time of delivery can be extended from _____(original/ last delivery period) to _____(presently agreed delivery period) subject to your unconditional acceptance of the following terms and conditions:

1. That, liquidated damages shall be levied in accordance with agreed clause 16.2 & 16.3 Section-5 Part A of terms and conditions of the tender/ PO.
2. That, notwithstanding any stipulation in the contract for increase in price on any ground, no such increase, whatsoever, which takes place after current last date of Delivery shall be admissible on such of the said goods as are delivered afterthesaiddateasperclause12Section-5PartA.
3. That, the prices during this extended delivery period shall be provisional and shall be governed as per agreed clauses 12 and 24 of Section 5 Part A and shall be finalized in accordance with the current PO price or the current PO price with latest budget/ duty impact or the prices in the new tender (T.E. no.....) from the date of its opening, on whichever is lower basis.
4. An additional BG of Rs._ in accordance with clause 15.3, Section- 5PartA of the contract with validity up to _____.
- 5.An undertaking as required vide clause 24.3, Section-5A. Otherwise furnish the details as requisite in clause24.4 section 5 Part A”

Please intimate your acceptance of this letter along with the additional BG within ten days of the issue of this letter failing which the contract will be cancelled at your risk and expense without any further reference to you. This letter shall form part and parcel of the agreement/ contract/ APO/ PO and all other terms & conditions of the contract remain unaltered.

Yours faithfully,

(.....)

for and on behalf of.....

Note : The entries which are not applicable for the case under consideration are to be deleted.

7(E)- Model Amendment Letter for Extension of Delivery Period

Appendix (ii) to clause 15.3 of Section-5 Part A

To Registered Acknowledgement Due

M/s

.....

Address of BSNL

Sub: This office contract no..... dated placed on you for supply of.....

Ref: 1. Your letter no..... dated..... requesting DP extension

2. This office letter no. dated intimating conditions for DP extension

3. Your letter no..... dated accepting the conditions for DP extension

In your above letter under reference (1), you have asked for extension/ further extension of time for delivery/ execution/ installation/ commissioning. The terms and conditions for extension of delivery period were conveyed to you vide this office letter under reference (2).

In view of the circumstances stated in your above referred letter, and upon your unconditional acceptance of the terms and conditions of this extension vide your letter under reference (3), the time of delivery is hereby extended from(last delivery period) to_____ (presently agreed delivery period) on the terms and conditions in letter under reference (2) above and agreed by you vide letter under reference (3)i.e.:

- (a) Liquidated damages shall be levied in accordance with agreed clause 16.2 & 16.3 Section-5 PartA of terms and conditions of the tender/PO.
- (b) Notwithstanding any stipulation in the contract for increase in price on any ground, no such increase, whatsoever, which takes place after current last date of Delivery/ completion of work shall be admissible on such of the said goods as are delivered after the said date as per clause12 Section-5Part A.
- (c) The prices during this extended delivery period shall be governed as per clauses 12 and 24 of Section-5 Part A and shall be finalized in accordance with current PO price or the current PO price with latest budget/duty impact or the prices in the new tender (T.E.no.....) from the date of its opening, on whichever is lower basis.

The letters under reference above and this letter shall form part and parcel of agreement/ contract/ APO/ PO and all other terms & conditions of the contract remain un altered.

Yours faithfully,

for and on behalf of.....
(.....)

Copy to :
..... (All concerned)

Note:- The entries which are not applicable for the case under consideration are to be deleted.

SECTION- 8

Tenderer / Bidder's profile & Questionnaire.

(To be filled in and submitted by the bidder)

A) Tenderer's Profile

1. Name of the Individual/Firm:
2. Present Correspondence Address
-
-
- Telephone No. Mobile No.....
- FAX No.
3. Address of place of Works/Manufacture :
-
-
- Telephone No. Mobile No.
4. State the Type of Firm: Sole proprietor-ship/partnership firm/ Private limited company/
(Tick the correct choice): .
5. Name of the sole proprietor/ partners/ Director(s) of Pvt. Ltd Co.:

| S. No. | Name | Father's Name | Designation |
|--------|------|---------------|-------------|
| 1. | | | |
| 2. | | | |
| 3. | | | |
| 4. | | | |
| 5. | | | |

6. Name of the person authorized to enter into and execute contract/
agreement and the capacity in which he is authorized (in case of
partnership/ private Ltd company):
.....
.....
7. Permanent Account No.:.....

8. Details of the Bidder's Bank for effecting e-payments:
 (a) Beneficiary Bank Name:.....
 (b) Beneficiary branch Name:.....
 (c) IFSC code of beneficiary Branch.....
 (d) Beneficiary account No.:.....
 (e) Branch Serial No.(MICR No.):.....
9. Whether the firm has Office/ works (i.e. manufacture of the tendered item) in Delhi? If so state its Address

B) Questionnaire

1. Do you think any other detail/ material is required to complete the work specified in the specification? Yes/No.
 1.1 If Yes, Give details

2. Do you think any other item of work need be included in tender form to complete the work specified in the specification? Yes/No.
 2.1 If Yes, Give details

3. Kindly indicate the maximum Quantity of tendered material which you are capable of supplying within the scheduled delivery period.

| Name of the tendered Item | Qty that can be supplied by the firm within scheduled delivery period. |
|---------------------------|--|
| | |
| | |

4. Suggestion for improvement of the tender document.

Place.....

Signature of contractor

Date.....

Name of contractor.....

SECTION-9 Part-A

BID FORM

To
The Executive Engineer (Electrical)
BSNL Electrical Division, Bhubaneswar

From,

Bidder's Reference No:..... Dated.....

Ref: Your Tender Enquiry No.dated

1. Having examined the above mentioned tender enquiry document including amendment/ clarification/ addenda Nos. datedthe receipt of which is hereby duly acknowledged, we, the undersigned, offer to supply and deliver in conformity with the said drawings, conditions of contract and specifications for the sum shown in the schedule of prices attached herewith and made part of the financial Bid.
2. Bid submitted by us is properly sealed and prepared so as to prevent any subsequent alteration and replacement.
3. We agree to abide by this Bid for a period of.....days from the date fixed for Bid opening or for subsequently extended period, if any, agreed to by us. This bid shall remain binding upon us up to the aforesaid period.
4. We understand that you are not bound to accept the lowest or any bid, you may receive.
5. If our Bid is accepted, we will provide you with a performance guarantee from a Scheduled Bank for a sum @ 5% of the contract value for the due performance of the contract.
6. If our Bid is accepted, we undertake to complete delivery of all the items and perform all the services specified in the contract in accordance with the delivery schedule specified in the Section-2 (Tender Information).
7. Until a formal Purchase Order of Contract is prepared and executed, this Bid together with your written acceptance thereof in your notification of award shall constitute a binding contract between us.

Dated:day of.....20...

Witness:

Signature

Name

Address:

Signature

Name
In the capacity of.....

Duly authorized to sign the bid
for and on behalf of

PRICE BID

Name of work: Providing Electro-Mechanical Services, provision for Air conditioning, Automatic Fire Detection, Fire Alarm System, Fire Extinguishers etc for Orchid project labs and shifted site of Banana Project Labs at Regional Plant Resource Centre at Bhubaneswar
(S.H: SITC of Automatic Fire Detection and Fire Alarm system & Fire Extinguishers)

NIT No: 24/ BSNL/BSR/2020-21

Name of Agency:

| SI No | Description of items | Quantity | Units | RATE inclusive of all & GST In Figures | | AMOUNT inclusive of all and GST | |
|-------|--|----------|-------|---|---|---------------------------------------|-------|
| | | | | Rs. | P | in | Rs. P |
| 1 | Supply, installation, testing and commissioning of UL listed, CE certified 2 wire conventional Photo electric / Ionization type Smoke detector with base made of ABS plastic with all accessories, suitable for operation on 24v DC, internal protection class: IP23, dual pulsing LED with 360 ⁰ visibility, relative humidity: ≤95%;non-condensing and EN54 compliance of approved make etc. as required. | 80nos | Each | | | | |
| 2 | Supply, installation, testing and commissioning of UL listed, CE certified 2 wire conventional Multi detector (fixed cum rate of rise heat Detector using a thermistor, raises an alarm when the detector reaches 59 ⁰ C (Fixed) or when the change in temperature exceeds the rate of rise of 11 ⁰ C/min) with base made of ABS plastic and all accessories, suitable for operation on 24 v DC, internal protection class: IP23, dual pulsing LED with 360 ⁰ visibility, relative humidity: ≤95%;non-condensing and EN54 compliance of approved make etc. as required. | 3nos | Each | | | | |
| 3 | SITC of dual LED response indicators made of ABS plastic, wall/ceiling mounted, operating voltage 24V DC, 5mm LED lamp glow light colour red compatible with all detectors etc. as required. (Make- Apollo / Honeywell / GST/ system sensor/ Ravel /Agni) | 20nos | Each | | | | |
| 4 | SITC of manual push button station (pill box) made of 16/20 SWG MS CRCA sheet, powder coated, signal red colour with 2mm thick break glass area not less than 30sq.cm, diffuse type LED, nickel plated brass hammer with SS chain, facility for cable entry from top, sign writing "In case of Fire Break Glass" suitable for operation on 24V DC supply etc. as required. | 6nos | Each | | | | |

| | | | | | |
|-----|--|-----------|---------|--|--|
| | (Make- Apollo / Honeywell / GST/ system sensor/ Ravel /Agni) | | | | |
| 5 | Supply, installation, testing and commissioning of electronic hooter cum speaker made of 16/18SWG CRCA sheet duly powder coated with PO red colour, output not less than 80db @25mtr, LMT with adjustable sound output of 2.5 watt,5 watt, suitable knock out for cable entry from top suitable for operation on 100/70 volt RMS AC supply etc. as required. (Make- Apollo / Honeywell / GST/ system sensor/ Ravel /Agni) | 6nos | Each | | |
| 6 | Supply, installation testing and commissioning of following Zones UL listed Microprocessor based Fire Alarm Control Panel Made of 16/18 SWG CRCA sheet powder coated, finish suitable for operation with 220V 50HZ AC mains power supply with standby battery backup 24Volt DC power supply and built in charger (without batteries) , normal operating voltage 24 v DC, compatible with all types of conventional detectors, manual call points and normally opened dry contact devices, 16X2 Dot matrix display, fully compatible with UL-864 and NFPA-72 etc. complete as required as per details specifications. | | | | |
| 6.1 | 4 Zone | 1no | Each | | |
| 6.2 | 8 Zone | 1no | Each | | |
| 7 | SITC of 2nos 12V sealed maintenance free battery of not less than 7AH capacity with all accessories etc as reqd.(Excide /Amco/Superior) | 2 sets | Set | | |
| 8 | Supplying and fixing of 600x450mm laminated floor plan mounted on the hard board showing area covered by each zone along with each control panel etc as reqd. | 2nos | Each | | |
| 9 | P/F fire exit sign board on ceiling/wall with suitable bracket of angle iron/flat as required made of 20 gauge MS sheet and aluminium frame of nominal size of 400x200x150mm illumination by miniature fluorescent tube operated on DC emergency supply, exit sign board shall be painted in red on 2mm thick acrylic sheet. | 6nos | Each | | |
| 10 | Supplying & Fixing of mounted photo luminescent signage's non-toxic, non-radioactive maintenance free self glowing safety signage's comprising of supplied chargeable crystals to glow in the dark with | 800sqinch | Sq inch | | |

| | | | | | |
|------|--|---------|------|--|--|
| | high intensity luminous 1.2 mm aluminum sheet properties by chemical coated (Vinyl & Tap not accepted) and covered with UV protection layer printed in multi language ad graphic symbol as per requirement etc as required. (Make Glo-line). | | | | |
| 11 | S/F ABS round box / MS Box on ceiling for fixing the detectors etc as reqd. | 40nos | Each | | |
| 12 | Supply and laying of 2 core 1.5sqmm FRLS PVC insulated and PVC sheathed copper conductor armoured cable on surface/recess for looping the fire alarm devices & providing power supply to sounder cum strobes etc. as required. (ISI) | 500mtrs | Mtr | | |
| 13 | Supplying and making indoor end termination with brass compression gland and aluminium lugs for following size of PVC insulated and sheathed/XLPE aluminium conductor cable of 1.1 KV grade as required. a) 2 core, 6 Sq. mm (19mm) | 150nos | Each | | |
| 14 | Supplying and drawing of following sizes FRLS PVC insulated copper conductor single core cable in the existing surface/recessed steel conduit as required (ISI). a) 2X1.5sqmm | 150mtrs | Mtr | | |
| 15 | Supplying and fixing of following sizes UPVC single compartment trunking/mini trunking on surface of wall/ceiling along with all accessories i.e. external angles, couplers, cable retainers etc. for drawing of wire/cable of fire detection and alarm system etc. as required.(Make: MK/Legrand/Schnieder) | | | | |
| 15.1 | 100mmX50mm | 10mtrs | Mtr | | |
| 15.2 | 50mmX50mm | 10mtrs | Mtr | | |
| 15.3 | 32mmX12.5mm | 50mtrs | Mtr | | |
| 16 | Supplying and fixing of following sizes medium class UPVC pipes on surface of wall/ceiling with all accessories and GI saddles etc. for drawing of wire/cable of fire detection and alarm system etc. as required. (Make: Precision/Universal/supreme/kinjal/ISI) | | | | |
| 16.1 | 20mm dia | 75mtrs | Mtr | | |
| 16.2 | 25mm dia | 50mtrs | Mtr | | |
| 17 | S/f of CO ₂ type fire extinguisher of 4.5 Kg. capacity confirming to IS 2878/86 made from ISI marked seamless cylinder confirming to IS 7285 duly approved by the chief controller of explosive fitted with ISI marked controlled valve confirming to IS3224 | 16nos | Each | | |

| | | | | | |
|--|--|-----------------|--|--|--|
| | with high pressure 1 meter discharge hose & horn complete with initial charging complete with handle, wall mounting bracket and fixing the same on suitable clamps etc. as required. (Make: Ceasefire/Safex /superior) | | | | |
| | | G.TOTAL: | | | |

LIST OF APPROVED MAKES OF BSNL ELECTRICAL WING

| S. No. | Item | Makes |
|--------|---|--|
| 1 | Battery (Lead Acid / Mntc. Free) | Amara Raja / AMCO / Farukawa / Hitachi / Exide/ Prestolite / Standard |
| 2 | MCCB(Ics=Icu) | L&T/ Schneider Electric / Siemens |
| 3 | MCB/ Isolator/ELCB/RCCB/ Distribution Board | Crompton / Havells / Indokopp / MDS Legrand/ L&T / Schneider Electric/ Siemens / Standard /ABB/HPL |
| 4 | MS/ PVC Conduit | ISI mark |
| 5 | Cable Tray | MEM/Bharti/Ratan/Slotco/Profab |
| 6 | HT/LT Cables | ISI mark |
| 7 | PVC insulated copper conductor wire | ISI mark |
| 8 | GI/MS Pipe | ATC / ATL / BST / GSI / ITC / ITS / IIA /JST / Jindal /TTA / Tata/Zenith |
| 9 | Gauge | Feibig / H.Guru / Pricol |
| 10 | Controls | FLICA / Honeywell / Indfoss / Penn- Danfoss / Ranco / Ranutrol / Sporland |
| 11 | Fine Filters | Anfiltra Effluent / ARW /Athlete/ Airtake/ Dyna / Kirsloskar/ Puromatic/ Purafill/ Purolator / Tenacity |
| 12 | GI Sheet | HSU Jindal / National / Nippon Denro /Sail / Tata |
| 13 | Heat Detector | Appollo / Chemtron/ Edward / Fenwal/ Hochiki / Nitton /System Sensor/ Wormald/Honeywell Essar/Notifier |
| 14 | Ionization Detector | Appollo / Cerebrus / Edward/ /Fenwal / Hochiki / Nitton / System Sensor / Wormald |
| 15 | Photo Electric Smoke Detector | Appollo / Cerebrus / Edward /Fenwal/Hochiki / Nitton / Wormald /System Sensor |
| 16 | Fire Panel (Microprocessor based) | Agni Instruments /Agni Devices/Aruna Agencies / Carmel Sensor / Ravel Elect./Honeywell Essar /Notifier / Navin Systems |
| 17 | Sprinkler/ Hose Reel & Hose Pipe | ISI mark |
| 18 | Fire Extinguisher | ISI mark |

CONTRACTOR

EXECUTIVE ENGINEER (E)

Appendix-1
to Section 4 Part A of Chapter 4
(Standard Tender Enquiry Document)

| S. No. | Defaults of the bidder / vendor. | Action to be taken |
|--|--|--|
| A | B | C |
| 1(a) | Submitting fake / forged | i) Rejection of tender bid of respective Vendor. ii) Banning of business for 3 years which implies barring further dealing with the vendor for procurement of Goods & Services including participation in future tenders invited by BSNL for 3 years from date of issue of banning order. iii) Termination/ Short Closure of PO/WO, if issued. This implies non-acceptance of further supplies / work & services except to make the already received material work/ complete work in hand. |
| | a) Bank Instruments with the bid to meet terms & condition of tender in respect of tender fee and/ or EMD; | |
| | b) Certificate for claiming exemption in respect of tender fee and/ or EMD; | |
| | and detection of default at any stage from receipt of bids till award of APO/ issue of PO/WO. | |
| | Note 1:- However, in this case the performance guarantee if alright will not be forfeited. | |
| Note 2:- Payment for already received supplies/ completed work shall be made as per terms & conditions of PO/ WO. | | |
| 1(b) | Submitting fake / forged documents towards meeting eligibility criteria such as experience capability, supply proof, registration with Sales Tax, Income Tax departments etc and as supporting documents towards other terms & conditions with the bid to meet terms & condition of tender : | |
| | <i>(i) If detection of default is prior to award of APO</i> | i) Rejection of Bid & ii) Forfeiture of EMD. |
| | <i>(ii) If detection of default after issue of APO but before receipt of PG/ SD (DD,BG etc.)</i> | i) Cancellation of APO/PO , ii) Rejection of Bid & iii) Forfeiture of EMD. |
| | <i>(iii) If detection of default after receipt of PG/ SD (DD,BG etc.) .</i> | i) Cancellation of APO/PO ii) Rejection of Bid & iii) Forfeiture of PG/ SD. However on realization of PG/ SD amount, EMD, if not already released shall be returned. |
| <i>(iv) If detection of default after issue of PO/ WO</i> | i) Termination/ Short Closure of PO/WO and Cancellation of APO ii) Rejection of Bid & iii) Forfeiture of PG/ SD. However on realization of PG/ SD amount, EMD, if not released shall be returned. | |
| Note 3:- However, settle bills for the material received in correct quantity and quality if pending items do not affect working or use of supplied items. | | |
| Note 4:- No further supplies are to be accepted except that required to make the already supplied items work. | | |

| S. No. | Defaults of the bidder / vendor. | Action to be taken |
|--------|--|---|
| A | B | C |
| 2 | <p>If vendor or his representative uses violent/ coercive means viz. Physical / Verbal means to threatens BSNL Executive / employees and/ or obstruct him from functioning in discharge of his duties & responsibilities for the following :</p> <p>a) Obstructing functioning of tender opening executives of BSNL in receipt/ opening of tender bids from prospective Bidders, suppliers/ Contractors.</p> <p>b) Obstructing/ Threatening other prospective bidders i.e. suppliers/ Contractors from entering the tender venue and/ or submitting their tender bid freely.</p> | Banning of business for 3 years which implies Barring further dealing with the vendor for procurement of Goods & Services including participation in future tenders invited by BSNL for 3 years from date of issue of banning order. |
| 3 | Non-receipt of acceptance of APO/ AWO and SD/ PG by L-1 bidder within time period specified in APO/ AWO. | Forfeiture of EMD. |
| 4.1 | Failure to supply and/ or Commission the equipment and /or execution of the work at all even in extended delivery schedules, if granted against PO/ WO. | <p>i) Termination of PO/ WO.</p> <p>ii) Under take purchase/ work at the risk & cost of defaulting vendor.</p> <p>iii) Recover the excess charges if incurred from the PG/ SD and outstanding bills of the defaulting Vendor.</p> |
| 4.2 | Failure to supply and/ or Commission the equipment and /or execution of the Work in full even in extended delivery schedules, if granted against PO/ WO. | <p>i) Short Closure of PO/ WO to the quantity already received by and/ or commissioned in BSNL and/ or in pipeline provided the same is usable and/or the Vendor promises to make it usable.</p> <p>ii) Under take purchase/ work for balance quantity at the risk & cost of defaulting vendor.</p> <p>iii) Recover the excess charges if incurred from the PG/ SD and outstanding bills of the defaulting Vendor.</p> |
| 5.1 | The supplied equipment does not perform satisfactory in the field in accordance with the specifications mentioned in the PO/ WO/Contract. | <p>i) If the material is not at all acceptable, then return the non-acceptable material (or its part) & recover its cost, if paid, from the o/s bills/ PG/ SD.</p> <p>OR</p> <p>ii) If the material is inducted in network & it is not possible to return it and/ or material is acceptable with degraded performance, the purchaser may determine the price for degraded equipment (Financial penalty = Price – price determined for degraded equipment) himself and/ or through a committee.</p> <p>Undertake recovery of financial penalty from outstanding dues of vendor including PG/ SD.</p> |

| S. No. | Defaults of the bidder / vendor. | Action to be taken |
|--------|--|--|
| A | B | C |
| 5.2 | Major quality problems (as established by a joint team / committee of User unit(s) and QA Circle) / performance problems and non-rectification of defects (based on reports of field units and QA circle). | <p>i) If the material is not at all acceptable, then return the non-acceptable material (or its part) & recover its cost, if paid, from the o/s bills/ PG/ SD;</p> <p>OR</p> <p>ii) If the material is inducted in network & it is not possible to return it and/ or material is acceptable with degraded performance, the purchaser may determine the price for degraded equipment (Financial penalty = Price – price determined for degraded equipment) himself and/ or through a committee.</p> <p>Undertake recovery of financial penalty from outstanding dues of vendor including PG/ SD;</p> <p>and</p> <p>iii) Withdrawal of TSEC/ IA issued by QA Circle.</p> |
| 6 | <p>Submission of claims to BSNL against a contract</p> <p>(a) for amount already paid by BSNL .</p> <p>(b) for Quantity in excess of that supplied by Vendor to BSNL.</p> <p>c) for unit rate and/ or amount higher than that approved by BSNL for that purchase.</p> | <p>i) Recovery of over payment from the outstanding dues of Vendor including EMD/ PG & SD etc. and by invoking 'Set off' clause 21 of Section 5 Part A or by any other legal tenable manner.</p> <p>ii) Banning of Business for 3 years from date of issue of banning order or till the date of recovery of over payment in full, whichever is later.</p> |
| | Note 5:- The claims may be submitted with or without collusion of BSNL Executive/ employees. | |
| | Note 6:- This penalty will be imposed irrespective of the fact that payment is disbursed by BSNL or not. | |
| 7 | <p>Network Security/ Safety/ Privacy:- If the vendor tampers with the hardware, software/ firmware or in any other way that</p> <p>a) Adversely affects the normal working of BSNL equipment(s) and/ or any other TSP through BSNL.</p> | <p>i) Termination of PO/ WO.</p> <p>ii) Banning of business for 3 years which implies barring further dealing with the vendor for procurement of Goods & Services including participation in future tenders invited by BSNL for 3 years from date of issue of banning order.</p> <p>iii) Recovery of any loss incurred on this account from the Vendor from its PG/ SD/ O/s bills etc.</p> |
| | <p>b) Disrupts/ Sabotages functioning of the BSNL network equipments such as exchanges, BTS, BSC/ MSC, Control equipment including IN etc., transmission equipments but not limited to these elements and/ or any other TSP through BSNL.</p> <p>c) tampers with the billing related data/ invoicing/ account of the Customer/ User(s) of BSNL and/ or any other TSP(s).</p> <p>d) hacks the account of BSNL Customer for unauthorized use i.e. to threaten others/ spread improper news etc.</p> <p>e) undertakes any action that affects/ endangers the security of India.</p> | <p>iv) Legal action will be initiated by BSNL against the Vendor if required.</p> |

| S. No. | Defaults of the bidder / vendor. | Action to be taken |
|--------|---|---|
| A | B | C |
| 8 | If the vendor is declared bankrupt or insolvent or its financial position has become unsound and in case of a limited company, if it is wound up or it is liquidated. | i) Termination/ Short Closure of the PO/ WO. ii) Settle bills for the quantity received in correct quantity and quality if pending items do not affect working or use of supplied items. iii) No further supplies are to be accepted except that required to make the already supplied items work. iv) In case of turnkey projects, If the material is commissioned and is usable without any degradation of performance, then settle bills for the acceptable equipment/ material (or its part). v) In case of turnkey projects, if the material is inducted in network & it is not possible to return it and/ or material is acceptable with degraded performance, the purchaser may determine the price for degraded equipment (Financial penalty = Price – price determined for degraded equipment) himself and/ or through a committee. (continues to page 173) |
| | | Undertake recovery of financial penalty from outstanding dues of vendor including PG/ SD. |
| 9 | In the event of the vendor, its proprietor, Director(s), partner(s) is / are convicted by a Court of Law following prosecution for offences involving moral turpitude in relation to the business dealings. | i) Termination/ Short Closure of the PO/ WO. ii) Settle bills for the material received in correct quantity and quality if pending items do not affect working or use of supplied items. iii) No further supplies are to be accepted except that required to make the already supplied items work. iv) In case of turnkey projects, If the material is commissioned and is usable without any degradation of performance, then settle bills for the acceptable equipment/ material (or its part). v) In case of turnkey projects, If the material is inducted in network & it is not possible to return it and/ or material is acceptable with degraded performance, the purchaser may determine the price for degraded equipment (Financial penalty = Price – price determined for degraded equipment) himself and/ or through a committee. Undertake recovery of financial penalty from outstanding dues of vendor including PG/ SD. |
| 10 | If the vendor does not return/ refuses to return BSNL's dues: | i) Take action to appoint Arbitrator to adjudicate the dispute. |
| | a) in spite of order of Arbitrator. | i) Termination of contract, if any. ii) Banning of business for 3 years which implies barring further dealing with the vendor for procurement of Goods & Services including participation in future tenders invited by BSNL from date of issue of banning order or till the date by which vendor clears the BSNL's dues, whichever is later. (continues to page 174) |

| S. No. | Defaults of the bidder / vendor. | Action to be taken |
|---|--|---|
| A | B | C |
| 10 con-td. | | iii) Take legal recourse i.e. filing recovery suite in appropriate court. |
| | b) inspite of Court Orders. | i) Termination of contract, if any. ii) Banning of business for 3 years which implies barring further dealing with the vendor for procurement of Goods & Services including participation in future tenders invited by BSNL from date of issue of banning order or till the date by which vendor clears the BSNL's dues, whichever is later. |
| 11 | If the Central Bureau of Investigation/ Independent External Monitor (IEM) / Income Tax/ Sales Tax/ Excise / Custom Departments recommends such a course | Take Action as per the directions of CBI or concerned department. |
| 12 | The following cases may also be considered for Banning of business: | i) Banning of business for 3 years which implies Barring further dealing with the vendor for procurement of Goods & Services including participation in future tenders invited by BSNL for 3 years from date of issue of banning order. |
| | (a) If there is strong justification for believing that the proprietor, manager, MD, Director, partner, employee or representative of the vendor/ supplier has been guilty of malpractices such as bribery, corruption, fraud, substitution of tenders, interpolation, misrepresentation with respect to the contract in question. | |
| | (b) If the vendor/ supplier fails to execute a contract or fails to execute it satisfactorily beyond the provisions of Para 4.1 & 4.2. | |
| | (c) If the vendor/ supplier fails to submit required documents/ information, where required. | |
| | (d) Any other ground which in the opinion of BSNL is just and proper to order for banning of business dealing with a vendor/ supplier. | |
| Note 7: The above penalties will be imposed provided it does not clash with the provision of the respective tender. | | |
| Note 8: -In case of clash between these guidelines & provision of invited tender, the provision in the respective tender shall prevail over these guidelines. | | |
| Note 9: Banning of Business dealing order shall not have any effect on the existing/ ongoing works/ AMC / CAMC which will continue along with settlement of Bills. | | |
