

NIT NOTIFICATION

The Executive Engineer (Elect.), BSNL Electrical Division, Cuttack invites on behalf of the Bharat Sanchar Nigam Limited sealed item rate tenders for the following works from the contractors satisfying the under mentioned eligibility conditions: -

Sl. No.	Name of work	Estimated cost including GST(Rs.)	E.M.D. (Rs.)	Time allowed for completion	NIT No.
1	Attending day to day breakdown faults, repairing and maintenance of outdoor type transformer substations for various TE/ BTS sites under Cuttack SSA (Phase-I for 2020-21).	199970.00	3999.00	06 months	101/BSNL/ED/CTC/2020-21

Tender paper cost (Non refundable) Rs.	590.00	
Last Date of receipt of application:-	01.12.2020	(upto 4.00PM)
Last Date of tender paper sale:-	01.12.2020	(upto 5.30PM)
Last Date of tender paper receipt:-	02.12.2020	(upto 3.00PM)
Date of opening:-	02.12.2020	(at 3.30 PM).

Eligibility Criteria :-

- 1.1 Average annual turnover during the last 3 years, ending 31 st March of the previous financial year, should be at least 30% of the estimated cost put to tender.

AND

- 1.2 The manufacturer/authorized dealer /OEM of any of the makes of major equipment included in the NIT. The letter of authorization from manufacturer in original/ photocopy attested by BSNL Executive will be submitted.

OR

- 1.3 Experience of having successfully completed similar works in BSNL during last 7 years ending last day of month previous to the one in which applications are invited, should be either of the following :

-> Three similar successfully completed works costing not less than the amount equal to 40% of the estimated cost put to tender.

OR

-> Two similar successfully completed works costing not less than the amount equal to 60% of the estimated cost put to tender.

OR

-> One similar successfully completed work costing not less than the amount equal to 80% of the estimated cost put to tender.

OR

- 1.4 BSNL enlisted contractors in Electrical category of respective class with valid HT electrical licence as per their tendering limits.

NOTE:-

- Valid GST Registration Certificate issued by statutory authority.
 - The company or firm or any other person is not permitted to tender for work in BSNL unit in which his/her near relative(s) is(are) posted .
 - Similar work means repairing work of 25 KVA transformer sub station & above. Testimonials of satisfactory completion of works should be obtained from an officer not below the rank of Executive Engineer, wherever required clearly mentioning the name & scope of work.
 - Valid electrical HT licence issued by any State Government is required in all the cases.
- All other terms & conditions as per BSNL EW-6 and BSNL EW-8 form.
 - The tenderer shall submit the tender in 2 sealed covers marked as cover 1st and 2nd inscribing the name of work. Both should be separate & they should not be enclosed in common third cover. The first cover should contain the earnest money deposited in the shape of demand draft/pay order of a schedule bank/nationalized bank/state bank guaranteed by reserve bank of India drawn in favour of Accounts Officer(Cash), O/o GMTD, BSNL, Cuttack. In case submitting tender down loading from web site, the 1st cover should contain DD towards cost of tender document and EMD drawn in favour of AO (cash), BSNL, O/o GMTD, Cuttack along with attested copies of eligible criteria with mandatory documents. The second cover contains the tender documents. If the 1st cover is not annexed in proper form, the second cover containing tender documents will not be opened at all.
 - If the date of opening is declared as holiday, then the tender shall be opened on next working day.
 - If the performance of the contractor is not satisfactory his tender shall not be opened. EE(E)'s decision shall be final and binding.

LIST OF MANDATORY SELF ATTESTED DOCUMENTS TO BE SUBMITTED WITH THE TENDER(1st COVER)

(1) Demand Draft/Pay Order/Banker's Cheque /FDR/TDR/BG of any Nationalized/ scheduled bank in favour of "Accounts Officer (Cash), BSNL, O/o the GMTD, Cuttack" towards EMD

(2) DD/Pay Order/Bankers Cheque of a Nationalized / Scheduled Bank in favour of "Accounts Officer (Cash), BSNL, O/o the GMTD, Cuttack" towards tender cost.
(3) Documentary proof of satisfying eligibility conditions as per 1.1 to 1.4 above.
(4) Turn Over Certificate from Chartered Accountant for last 03 years.
(5) PAN card issued by Income Tax Department, Govt of India.
(6) Valid GST Registration Certificate issued by statutory authority
(7) Employees Provident Fund (EPF) & ESI Registration Certificates.
(8) Valid Electrical HT licence issued by any State Government.

No:- 10(17)/TED/BSNL/CTK/278

Dt. 18/11/2020

Executive Engineer(E), BSNL Electrical Division, Cuttack

Copy to-

- 1) The C.E(E), BSNL Electrical Odisha Zone, Bhubaneswar
- 2 - 3) The Executive Engineer(E) BSNL Electrical Division, Bhubaneswar/Sambalpur
- 4-15) The Sub-Divisional Engineer(E) BSNL.E.S.D.,BBSR-I/II/Berhampur/SBP-I/II/RKL/ KPT/ DKL/BLS/BGR/CK/DKL.
- 16) The Vigilance Officer, O/o the CGMT, Orissa Circle, Bhubaneswar.
- 17) The Accounts Officer(Cash), O/o GMTD, BSNL, Cuttack
- 18) The Jr. Accounts Officer, BSNL Electrical Division, Cuttack
- 19-20) Notice Board/website.
- 21) Contractors' association.

Executive Engineer(E), BSNL Electrical Division, Cuttack

BHARAT SANCHAR NIGAM LIMITED

(A Government Of India Enterprise)

Item rate tenders are invited on behalf of the BSNL from eligible contractors for the work of :-

Attending day to day breakdown faults, repairing and maintenance of outdoor type transformer substations for various TE/ BTS sites under Cuttack SSA (Phase-I for 2020-21).

The work is estimated to cost Rs.

199970.00

This estimate however is given merely as a rough guide.

1) Tender will be issued to

1.1 Average annual turnover during the last 3 years, ending 31 st March of the previous financial year, should be at least 30% of the estimated cost put to tender.

AND

1.2 The manufacturer/authorized dealer /OEM of any of the makes of major equipment included in the NIT. The letter of authorization from manufacturer in original/ photocopy attested by BSNL Executive will be submitted.

OR

1.3 Experience of having successfully completed similar works in BSNL during last 7 years ending last day of month previous to the one in which applications are invited, should be either of the following :

-> Three similar successfully completed works costing not less than the amount equal to 40% of the estimated cost put to tender.

OR

-> Two similar successfully completed works costing not less than the amount equal to 60% of the estimated cost put to tender.

OR

-> One similar successfully completed work costing not less than the amount equal to 80% of the estimated cost put to tender.

OR

1.4 BSNL enlisted contractors in Electrical category of respective class with valid HT electrical licence as per their tendering limits.

completed work of magnitude as specified in press notification at page No. 4.

2) Agreement shall be drawn with the successful tenderer on prescribed form no. 8 which is available as a Govt. of India publication, tender shall quote his rates as per various terms and conditions of the said form which will form part of the agreement .

3) The time allowed for carrying out the work will be

06 months

4) The availability of individual site will be specified in the letter of intent.

5) Receipt of applications for issue of forms will be stopped by 1600 Hrs. two days before the date fixed for opening of tenders. Issue of tender forms will be stopped three days before the date fixed for opening of tenders. Tender documents consists of plans , specifications, the schedule of quantities of the various classes of work to be done and the set of terms and conditions of contract to be complied with by the whose tender may be accepted and other necessary document can be seen in the office of the Executive Engineer (E), BSNL ELECTRICAL DIVISION, Cuttack between 11.00 AM & 04.00 PM every day except on Sunday and public Holiday. Tender documents, excluding standard form, will be issued from his

office, during the hours specified above on payment of Rs. **590.00** only in DD.

6) The tender must produce an Chattered Accountant certificate in the revised form as modified under Ministry of Finance O.M. No. 67/30/69/ITAL dated 02.07.1970 as amended from time to time before tender papers can be sold to him.

7). Tenders, which should always be in sealed envelope, with the name of work and due date written on the envelope, will be received by the Executive Engineer(E), BSNL Electrical Division, Cuttack up to 03.00 PM on **02.12.2020** and will be opened by him or his authorized representative in his office on the same day at 03.30 PM.

8). The tender shall be accompanied by earnest money (unless exempted) of Rs. **3999.00**

in the form of DD of a scheduled Bank issued in favour of Accounts Officer(Cash), O/o GMTD, BSNL, Cuttack, the amount being credited to Nationalized Bank / State Bank .

9). The description of the work is as follows :-

Name of the work :-

Attending day to day breakdown faults, repairing and maintenance of outdoor type transformer substations for various TE/ BTS sites under Cuttack SSA (Phase-I for 2020-21).

Copies of other drawings and documents pertaining to the works will be open for inspection by the tenderers at the office of the above mentioned officer. Tenderers are advised to inspect and examine the site and its surroundings and satisfy themselves before submitting their tenders as to the ground and sub - soil. (so far as is practicable), the form and nature of the site , the means of access to the site the accommodation they may require and in general shall themselves obtain all necessary information as to risks , contingencies and other circumstances which may influence or affect their tender . A tenderer shall be responsible for arranging and maintaining at his own cost all materials , tools & plants, water electricity access, facilities for workers and all other service required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a tender by a tenderer implies that he has read this notice and all other contract documents and has made himself aware of the scope and specifications of the work to be done and of conditions and rates at which stores, tools and plants, etc. will be issued to him by the department and local conditions and other factors having a bearing on the execution, of the work.

- 1 The competent authority on behalf of the BSNL does not bind himself to accept the lowest or any other tender and reserves to himself the authority to reject any or all the tenders received without the assignment of any reason. **All tenderers in which any of the prescribed condition is not fulfilled or any condition including that of conditional rebate is put forth by the tenderer shall be summarily rejected.** The public enterprises that avail benefits of the purchase preference should be subjected to adequate penalties for cost overruns etc.
- 2 Canvassing whether directly or indirectly, in connection with tenders is strictly prohibited and the tenders submitted by the contractors who restore to canvassing will be liable to rejection.
- 3 The competent authority on behalf of BSNL reserves to himself the right of accepting the whole or any part of the tender and the tenderer shall be bound to perform the same at the rate quoted.
- 4 The contractor shall not be permitted to tender for work in the BSNL (responsible for award and execution of contracts) in which his near relative is posted as divisional account tant or as an officer in any capacity between the grades of Superintending Engineer and Junior Engineer(both inclusive). He shall also intimate the names of persons who are working with him in any capacity or are subsequently employed by him and who are near relatives to any gazetted officer in the BSNL or in the Ministry of communication . Any breach of this condition by the contractor would render him liable to be removed from the approved list of contractors of this Department.
- 5 No Engineer of gazetted rank or other gazetted officer employed in Engineering or Administrative duties in an Engineering Department of he Government of India is allowed to work as a contractor for a period of two years after his retirement from Government service , without the previous permission of the Government of India in writing . This contract is liable to be cancelled if either the contractor or any of his employees is found any time 'to be such a person who had obtained the permission of the Government of 'India as aforesaid before submission of the tender or engagement in the contractor's service. The tender for the works shall remain open for acceptance for a period of ninety days from the date of opening of tenders. If any tender withdraws his tender before the said period or makes any notifications in the terms and condition of the tender which are not acceptable to the department , then the Government shall , without prejudice to any other right or remedy, be at liberty to forfeit 50 % of the earnest money as aforesaid.
- 6 This Notice Inviting Tender shall form a part of the contract document. The successful tenderer/ contractor, on acceptance of his tender by the Accepting Authority, shall , within 15 days from the stipulated date of start of the work sign the contract consisting of :-
 - a) The Notice inviting tender , all the documents including additional conditions, specifications and drawings, if any, forming the tender as issued at the time of invitation of tender and acceptance thereof together with any correspondence leading there to.
 - b) Standard C.P.W.D. form 8.

Executive Engineer(E), BSNL Electrical Division, Cuttack

Near relative(s) of BSNL employee not permitted to tender :

The company or firm or any other person is not permitted to tender for works in BSNL unit in which his near relative(s) is (are) posted . The unit is defined as SSA/ Circle / Chief Engineer / Chief Architect / Corporate office for non- executive employees and all SSA in a circle including circle office / Chief Engineer/ Chief Architect/ Corporate office for executive employees (including those called as Gazetted officers at present).Therefore , it has been decided by the competent authority that a clause must be added in the tender and other related documents that the tenderer should give a certificate that none of his / her such near relatives is working in the units as defined above where he is going to apply for tender.In case of proprietorship form certificate will be given by the proprietor , for partnership firm certificate will be given by the partners and in case of limited company by all the directors of the company.Any breach of these conditions by the company or firm or any other person, the tender / work will be cancelled and earnest money / security deposited will be forfeited any stage whenever it is so notices.

The department will not pay any damages to the company or firm or the concerned person. The company or firm or the person will also be debarred for further participation in the concerned unit.

FORMAT OF THE CERTIFICATE TO BE GIVEN BY THE FIRM/ PERSON:

I _____ S/O _____ R/O _____ here by certify that none of my relative(S) as defined below is/ are employed in BSNL unit as per details given in the tender documents. In case at any stage, it is found that the information given by me is false / incorrect, BSNL shall have absolute right to take any action as deemed fit / without any prior intimation to me.

- a) Members of Hindu Undivided family,
- b) They are husband and wife,
- c) The one is related to the other in the manner as father, mother, son(s) & son's wife (daughter- in - law), Daughter(s) & daughter's husband (son-in law , brother(s) & brother's wife , sister(s) & sister's husband(brother in law).

Signature of the firm / person.

DECLARATION

I (full name of Tenderer) hereby declare that I am fully aware of the terms and conditions of contracts for work presently prevailing in the Civil Wing of BSNL . I also declare that, I have thoroughly gone through the terms and agreements as contained in various clauses clauses and Sub - Clauses of terms P.W.D. - 8 l/c up to date amendments therein . I (full name of contractor)further declare that while submitting the tender for(full name of work).I fully agree to abide by the aforesaid terms and conditions of the contract and shall be bound to enter into the agreement in case my tender is accepted. I undertake to bear all liabilities i.e. duties etc. of constitution of India.arising out of 46th amendments

Date :-

(Full signature of the tenderer)

Executive Engineer(E), BSNL Electrical Division, Cuttack

Declaration by Contractor for EW-6, EW-8 (To be furnished by the firm)

I / We do hereby undertake to have gone through the terms & conditions / clauses of all the tender documents including Form **EW-06, EW-08** being adopted by the BHARAT SANCHAR NIGAM LIMITED (Electrical Wing) & agree to abide by the same. In case of failure to comply as above, our offer will stand withdrawn and our tender documents would not be opened by the tender opening officer. The decision of tender opening officer in this regard shall be final & binding on me.

(Full signature of the tenderer)

GENERAL SPECIFICATIONS.

- 1) The work shall be carried out as per current department / CPWD specifications.
- 2) Layout of the work shall be given at site of work by the Engineer - in Charge or his duty authorized representative.
- 3) Samples of the all articles shall be got approved from the Engineer - in Charge before they are used.
- 4) The work shall be supervised by the qualified supervisor from the contractor's side.
- 5) Any damage done o the building / equipment of the department shall be made good by the contractor without any extra cost.
- 6) No T & P shall be issued to the contractor by the department.
- 7) Testing shall be done in the presence of the Engineer - in - Change or his duly authorized representative.
- 8) The contract shall stand for guarantee against defective materials of manufacturing defects and workmanship for the work carried out by him for the period of one year from it's commissioning & make good / repair / replace the faults during this period without any extra cost , failing which the same shall got done at the risk and cost of the contactor.
- 9) Security deposited of the contractor shall be released only after satisfactory completion of guarantee period.
- 10) Makes of product shall be as per product directory enclosed or approved by the Engineer - in - Change.

- 11) Without prejudice of any of the rights or remedies under this contract, if the contractor dies, the Engineer in charge on behalf of the BSNL shall have the option of terminating the contract without compensation to the contractor.
- 12) INDULGING OF CONTRACTOR IN CRIMINAL/ANTISOCIAL ACTIVITIES AND CASES UNDER INVESTIGATION / CHARGE SHEETED BY CBI OR ANY OTHER GOVERNMENT AGENCIES ETC. : If the CBI/Independent External Monitor (IEM) / Income Tax /Sales Tax/ Central Excise/ Custom Departments recommend such a course – Action will be taken as per the directions of CBI or concerned department.

Executive Engineer(E), BSNL Electrical Division, Cuttack

"ESSENTIAL CONDITIONS OF CONTRACT "

The firm shall read carefully the following conditions and shall quote accordingly conforming all the points in their offer. Firm should specifically note that if they do not enclose E.M.D. with their tender , their tender will not be opened at all.

1 TAXES AND DUTIES :

BSNL shall deduct income tax and other statutory deductions / cess from payments due to the firm as per rules of the State / Central Government. The Accounts Officer of the concerned Division shall issue certificates for such deductions to the firm. In case of statutory variation in GST within the stipulated date of completion of individual agreement, the same shall be paid or recovered as per the actual against documentary proof for major equipments/ materials. However, beyond this period BSNL will take advantage of any duty reduction but will not pay extra on account of duty increase.

2 Evaluation of Tenders:-The evaluation and comparison of responsive tenders shall be done on the basis of Net cost to BSNL, considering GST as Input Tax Credit.

3 Loading , unloading , transportation, insurance etc. shall all be included in their offer.

4 All the materials will be under the charge of the contractor till it is completed and handed over . No materials will be removed from site without written permission of the Engineer - in Charge.

5 Firm shall confirm to carry out the work as per the N.I.T. conditions.

6 PAYMENTS TERMS :

No advance payments will be made. Stipulations like levy of interest if any payment is not made in specified time is not acceptable to the department.

7 Offer should be clear .

Any ambiguous offer is liable for rejection by the department. **There will be no negotiation with the lowest tenderer.** Hence the firms are requested to quote carefully. Department's decision in this regard shall be final and binding on the tenderer . Offer with condition will be summarily rejected.

8 GST:

8.1 All taxes and Duties are as per applicable GST. Variation if any will be guided by Statutes pertaining to GST.

8.2 The Firm shall furnish Invoices to BSNL for availing of applicable Input Tax Credit.

8.3 Vendors should furnish the correct HSN/SAC code. If the Input Tax Credit (ITC) under GST is found to be not admissible at any stage subsequently owing to wrong furnishing of data, the vendor will be liable such non-admissible amount, if already paid along with penalty if charged by the concerned authority.

8.4 If the Vendors fail to furnish necessary supporting documents for availing of input tax credit by BSNL, the amount pertaining to such input credit will be deducted from the payment due to the firm.

8.5 Invoices should clearly indicate break up details of composite price i.e. unit price of goods/services/materials and GST etc.

8.6 In case of any statutory variations in regard to GST or any other taxes, within the currency of contract including extension period if any, the same shall be admissible as per prevailing GST laws as applicable subject to the condition that, the reason for such extension of time period is not attributable to the agency

9 The currency of contract shall be 06 months. However the currency of the contract may be extended for another 06 months at mutual consent of the contractor & BSNL.

10 In urgency the agency may be asked to carry out the work in adjacent SSAs as per the requirement. The decision of Engineer-in-charge in this regard shall be final & binding.

Executive Engineer(E), BSNL Electrical Division, Cuttack

SPECIFICATION

E.I & FANS :

- 1 The work is to be carried out as per CPWD specifications (External) and I.E Rule amended up to date.
- 2 Good workmanship is an essential requirement to be complied with. The entire work of manufacturer, fabrication, assembly and installation shall conform to sound engineering practice.
- 3 Rates quoted shall be inclusive of all taxes, packing , forwarding, insurance , freight, delivery at site watch and ward of all materials.
- 4 All Sundry fittings , accessories , hardware items, foundation bolts, termination lugs for electrical connection as required and all other sundry items which are useful & necessary for proper assembly and efficient working of the various components of the works shall be deemed to have included in the tender.
- 5 Following works shall be carried out by the contractor and therefore their cost shall be deemed to be included in their tendered cost.
 - a) The contractor shall be responsible for repairing all damages and restoring the same to their original finish. He shall also remove at his cost all unwanted and waste materials arising out of his work from his site.
 - b) All chases required in connection with the electrical works shall be provided and filled by the contractor to the original finish.
 - c) Temporary shed if required over the storage space and locking arrangement ,watch and ward of the materials shall be provided by firm till completion of the work and final taking over of the installation by the department.
- 6 The contractor shall employ qualified engineer/Supervisor as required and intimate names of such persons to the Engineer- in- Charge on commencement of work. Failure to employ will attract penalty as per agreement.
- 7 If any conduit is laid before award of work recovery for the same will be made from contractor at the rate of S.R. - 16 + Abatement of respective S/H of this tender.
- 8 All non- metallic conduit pipes and accessories shall be of I.S.I marked , conduit accessories shall be of grip type / threaded type.
- 9 PVC conduit to be used shall be ISI marked heavy gauge and fire retardant quality.
- 10 The switch box shall be made of mild steel of size 16 / 18 SWG as per CPWD specification except the front side. The clear depth of M>S> switch shall not be less than 60 mm. Phenolic laminated sheet cover of 3 mm thick shall be provided in the front side of box.
- 11 Earthing shall be carried out in presence of representative of the department.
- 12 Numbering and sign writing of entire installation shall be carried out by the contractor as per instructions of the Engineering - in- Charge for which nothing extra shall be paid.
- 13 On completion of installation following tests shall be carried out:-
 - a) Insulation resistance test.
 - b) Polarity test.
 - c) Earth continuity test.
 - d) Earth electrode resistance test.
- 14 On completion of electrical installation a certificate shall be furnished by the contractor in prescribed proforma, this certificate shall be in addition to the certificate required by local electric supply company.
- 15 Breaking capacity of MCBs should be 10 KA.

Executive Engineer(E), BSNL Electrical Division, Cuttack

SCHEDULE OF WORK

Name of work:		Attending day to day breakdown faults, repairing and maintenance of outdoor type transformer substations for various TE/ BTS sites under Cuttack SSA (Phase-I for 2020-21).							
Sl. No.	Description of item	Quantity	Unit	Unit Price excluding GST (Rs.)	GST=(CGST+ SGST) /IGST		Total Unit Price including GST (Rs.)	Total Amount including GST (Rs.)	Total Amount excluding GST (Rs.)
					%	Amount			
Col .1	Col.2	Col.3	Col.4	Col.5		Col.6	Col.7 = col. (5+6)	Col.8 = Col.3 X Col.7	Col.9 = Col.3 X Col.5
1	Attending to break down calls, physical inspection of Sub station accessories, overhead lines, feeder panels, meter box, LT distribution panel, MCBDBs internal wirings etc. to find out the faults and taking corrective measures for restoration of power supply by rewiring of DO/HG fuses, reconnection of jumper wires in DP structure and replacement of HRC fuses, rewiring of rewirable fuses, cutting of burnt out portion of LT cables, fixing of cable glands, lugs/sockets, reconnection, tightening of loose connections & resetting of MCBs, MCCBs in feeder panel, Distribution panel, MCBDBs etc. complete as required.	5 Jobs	Job						
2	Liaissioning with supply authority for inspection of site by their maintenance/MRT personnel and taking shut down of 11KV line to carry out the repairing and maintenance works of the sub station and re-energisation, checking the parameters, load testing etc. complete as required.	5 Jobs	Job						
3	Dismantling the 25 KVA faulty transformer from the existing D.P. structure & installation of standby/repared transformer as a stop gap arrangement by engagement of labour, required tools & plant with proper precautionary measures etc. as required.	3 Jobs	Job						

4	Dismantalling the standby/repared transformer fitted as a stop gap arrangement, refixing of original transformer by engagement of labour, required tools & plant with proper precautionary measures as required.	1 Job	Job						
---	--	-------	-----	--	--	--	--	--	--

5	Repairing of 25 KVA Aluminium wound transformer by arranging of dismantling the faulty transformer, re-insulating the windings, heating, reassembling i/c replacement of gaskets, nuts & bolts, washers, breather with silica gel, painting of transformer with suitable grade weather proof paint, carry out factory tests etc. complete as required. (Rewinding of Transformer is not in the scope of this item)	1 Job	Job						
6	Transportation of transformer from BSNL Electrical Sub-Division to individual sites & from site to BSNL Electrical Sub-Division on road by engagement of required man power, tools & plants, lifting cranes, suitable transportation medium including loading and unloading at both ends etc. complete as required. (The rate should be inclusive of toll gate fee/charges wherever applicable, nothing extra will be paid. Distance will be on shortest route only).								
a)	For distance less than 50 Km.	1 Job	Job						
b)	For distance more than 50 Km but upto/including 100 Km.	1 Job	Job						
c)	For distance more than 100 Km but upto/including 150 Km.	1 Job	Job						
7	Thorough servicing of AB Switch, adjusting of bearings, male/female contacts, lubricating of moving items including replacement of necessary minor defective spares like bolts, clamps, checking the functional operation, checking of horn gap/ drop out fuse, checking of risers, adjustment of horn gap distance etc. complete as required.	10 Jobs	Job						
8	Replacement of the following defective spare parts of 11 KV air break switch/ drop out fuse by new one including fitting etc. as reqd.								
a)	Male contact made of brass for 200 Amps air break switch.	2 nos.	Each						

b)	Female contact made of brass for 200 Amps air break switch.	2 nos.	Each						
c)	Rotor mechanism for 200 Amps air break switch.	2 nos.	Each						
d)	Copper barbed wire strip	3 nos.	Each						
e)	Back plate	3 nos.	Each						
f)	Square bar	3 nos.	Each						
g)	Heavy duty operating pipe along with accessories for air break switch including fabrication.	1 no.	Each						
h)	Post insulator of the horn gap fuse / air break switch unit with all accessories.	6 nos.	Each						
i)	Horn gap fuse risers made of brass except post insulator.	3 pairs	Pair						
j)	DO Fuse element	6 nos.	Each						
k)	DO back plate	4 nos.	Each						
9	Supplying & fixing of non-linear resistor type distribution class lightning arrester suitable for 11 KV supply system with rated voltage of 9 KV (RMS) with a nominal discharge current rating of 5 KA and complete with galvanised clamping arrangement etc. complete as required.	3 nos.	Each						

10	Supplying and pouring of transformer oil (IS:325) of suitable make & grade for topping up level etc. complete as required.	50 ltrs.	Ltr						
11	Supplying & fixing of silicagel breather for 25 KVA transformer in place of defective/damaged ones.	2 nos.	Each						
12	Supply & fixing of 11 KV pin insulator with large steel head G.I. pin, nuts, washers on existing HT pole/DP structure etc. complete as required.	15 nos.	Each						
13	Supply & fixing of 11 KV disc insulator with galvanised insulator fittings, ball and socket type and complete with galvanised strain clamps, bolts, nuts, washers etc. as required.	12 nos.	Each						
14	Supply & drawing of 55 sqmm. AAA conductor for overhead line and DP structures including binding with insulators etc. complete as required.	100 mtrs	Mtr						
15	Supply of following sizes PVC insulated & PVC sheathed Aluminium conductor armoured cable 650/1100 V. grade conforming to IS : 7098 (Part-1) 1988 including transportation to respective sites etc. as required.								
a)	4 core 16 sqmm	50 mtrs.	Mtr						

	b) 3 ½ core 25 sqmm	25 mtrs	Mtr						
16	Laying of one number PVC insulated and PVC sheathed / XLPE power cable of 1.1 KV grade of following size direct in ground including excavation and refilling the trench etc. as required, but excluding sand cushioning and protective covering.								
	a) Up to 35sqmm	25 mtrs	Mtr						
17	Laying of one number PVC insulated and PVC sheathed / XLPE power cable of 1.1 KV grade of following size in the existing RCC/ HUME/ METAL pipe as required.								
	a) Up to 35sqmm	25 mtrs	Mtr						
18	Laying of one number PVC insulated and PVC sheathed / XLPE power cable of 1.1 KV grade of following size in the existing Duct/Air as required.								
	a) Up to 35sqmm	25 mtrs	Mtr						

19	Supplying and making end termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed / XLPE aluminium conductor cable of 1.1 KV grade etc. as required.								
a)	4 X 16 sq. mm (28mm)	6 sets	Set						
b)	3½ X 25 sq. mm (28mm)	4 sets	Set						
20	Supplying & fixing/crimping of following sizes & ratings aluminium/copper sockets/lugs for PVC sheathed / XLPE aluminium/copper conductor cable of 1.1 KV grade as required.								
a)	16/25 sqmm Al socket.	30 nos.	Each						
b)	35 sqmm Al socket.	9 nos.	Each						
c)	50 sqmm Al socket.	10 nos.	Each						
21	Replacement of MCBs/SDFUs by new ones of following ratings including dismantling of old defective ones, fixing, connection & testing etc. as required. (BSNL approved make)								
a)	63 Amps 415 volts TPN SDFU with HRC fuses	2 nos.	Each						
b)	63 Amps 415 volts 4 pole MCB	3 nos.	Each						
c)	6-32A SP MCB	8 nos.	Each						
22	Supplying and making outdoor cable end termination with heat shrinkable jointing kit complete with all accessories including lugs suitable for 3 core, 35 sqmm, XLPE aluminium conductor cable of 11 KV grade etc. as required.	1 job	Job						

26	PVC conduit		ISI Marked
27	Submersible pump		KSB / Calama / Amrut / Kirloskar / PEC / BE.
28	ELCB		Standard / MDS/ Havells/ Datar /Siemens / GE Power Controls / HPL- Techno.
29	RCCB		Indo Asian
30	Contractors		Siemens / L & T / GE Power controls / Shneider / MEI / Laxmi.

Executive Engineer(E), BSNL Electrical Division, Cuttack

PROFORMA OF SCHEDULES

(Operative Schedules to be supplied separately to each intending tenderer)

SCHEDULE 'A'

Schedule of quantities :Enclosed.

SCHEDULE 'B'

Schedule of materials to be issued to the contractor.

Sl. No.	Description of item	Quantity	Rates in figures and words at which the material will be charged to the contractor	Place of Issue
1	2	3	4	5
NIL				

SCHEDULE 'C'

Tools and plants to be hired to the contractor

Sl. No.	Description of item	Hire charges per day	Place of Issue
1	2	3	4
NIL			

SCHEDULE 'D'

Extra schedule for specific requirement/documents for the work if any.

- A. General conditions & specifications :Enclosed
- B. List of approved makes :Enclosed
- C. Correction slips :Enclosed

SCHEDULE 'F'

Reference to General Conditions of contract.

Name of work:

Attending day to day breakdown faults, repairing and maintenance of outdoor type transformer substations for various TE/ BTS sites under Cuttack SSA (Phase-I for 2020-21).

Estimated cost of work:

199970.00

Earnest money:

3999.00

Security Deposit:

5 % of the tendered value of the work.

Performance guarantee

5% of the tendered value of the work. The same to be submitted to EE(E) within 15 days after receipt of award letter

GENERAL RULES and DIRECTIONS:

Officer inviting tender:

Executive Engineer(E), BSNL Electrical Division, Cuttack

Maximum percentage for quantity of items of work to be executed beyond which rates are to be determined in accordance with clauses 12.2 and 12.3.

25%

Definitions:

2(v) Engineer-in-Charge

Executive Engineer(E), BSNL Electrical Division, Cuttack

2(viii) Accepting Authority

Executive Engineer(E), BSNL Electrical Division, Cuttack

2(x) Percentage on cost of materials and labour to cover all overheads and profits.

10%

2(xi) Standard Schedule of Rates

DSR-E&M-2018

2(xii) Department

BSNL

9(ii) Standard CPWD contract Form

CPWD Form 8 as modified & corrected upto date

Clause 2

Authority for fixing compensation under Clause 2.

Superintending Engineer (E), O/o the C.E(E), BSNL Electrical Odisha Zone, Bhubaneswar.

Clause 5

Time allowed for execution of work. Authority to give fair and reasonable extension of time for completion of work.

06 months

Clause 7

Gross work to be done together with net payment/ adjustment of advances for material collected, if any, since the last such payment for being eligible to interim payment.

As Applicable.

Clause 11

Specifications to be followed for execution of work

CPWD internal and external specification up to date

Clause 12

12.1.2 (iii) Schedule of rates for determining rates for additional, altered or, substituted items that cannot be determined under 12.1.2 (i)and(ii)

DSR-E&M-2018

12.1.2 (iii) ± the % over the rate entered in the schedule of rates.

NA

12.1.2 (vi) A. Deviation Limit beyond which sub-clauses (i) to (v) shall not apply and clauses 12.2 and 12.3 shall apply

25%

12.1.2 (vi) B(a). Limit for value of any item of any individual trade beyond which sub-clauses (i) to (v) shall not apply and clauses 12.2 and 12,3 shall apply.

NA

Clause 16

Competent Authority for deciding reduced rates.

Superintending Engineer (E), O/o the C.E(E), BSNL
Electrical Odisha Zone, Bhubaneswar.

Clause 36 (i)

Minimum Qualifications and experience required for Principal Technical Representative.

a) For works with estimated cost put to tender more than

i) Rs. 10 lakhs for Civil work

ii) Rs. 5 Lakhs for Elect/ Mech.Works

Graduate or retired AE possessing at least recognised diploma

b) For works with estimated cost put to tender more than

i) Rs. 5 lakhs but less than Rs. 10 lakhs for Civil works

ii) Rs. 1 lakh but less than Rs.5 Lakhs for Elect/ Mech. Works

Recognised diploma holder

c) Discipline to which the Principal Technical Representative should belong.

:Electrical/ Mechanical

d) Minimum experience of works

: Three (3) years.

e) Recovery to be effected from the contractor in the event of not fulfilling provision of clause 36(1)

:Rs.4,000/- p.m. for Graduate Rs 2,000/- p.m for
Diploma holder

____ **END OF NIT** ____